

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) LaSalle County Station Unit 1										DOCKET NUMBER (2) 0 5 0 0 0 3 7 3 1					PAGE (3) 1 OF 2								
TITLE (4) Unsecured High Radiation Area																							
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)													
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)										
1	1	2	4	8	4	0	8	3	0	0	1	2	2	0	8	4	0	5	0	0	0		
OPERATING MODE (9) 4			THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5. (Check one or more of the following) (11)																				
POWER LEVEL (10) 9 0 0			20.402(b)				20.408(a)				80.73(a)(2)(iv)				73.71(b)								
			20.408(a)(1)(i)				80.36(a)(1)				80.73(a)(2)(v)				73.71(a)								
			20.408(a)(1)(ii)				80.36(a)(2)				80.73(a)(2)(vi)				OTHER (Specify in Abstract below and in Text, NRC Form 386A)								
			20.408(a)(1)(iii)				80.73(a)(2)(ii)				80.73(a)(2)(vii)(A)												
			20.408(a)(1)(iv)				80.73(a)(2)(iii)				80.73(a)(2)(vii)(B)												
			20.408(a)(1)(v)				80.73(a)(2)(iii)				80.73(a)(2)(ix)												
LICENSEE CONTACT FOR THIS LER (12)																							
NAME L. R. Aldrich, extension 238										TELEPHONE NUMBER 8 1 1 5 3 5 1 7 1 6 1 7 6 1													
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																							
CAUSE	SYSTEM	COMPONENT	MANUFAC TURE	REPORTABLE TO NPD		CAUSE	SYSTEM	COMPONENT	MANUFAC TURE	REPORTABLE TO NPD													
X	Z	Z	9 9 9	Z	9 9 9	N																	
SUPPLEMENTAL REPORT EXPECTED (14)																							
YES (If yes, complete EXPECTED SUBMISSION DATE)										NO							EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR		

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

At 0100 on November 24, 1984, a Mechanical Maintenance Foreman found a pipe chase opening, located above the Unit 1 Drywell Personnel Access Hatch on 740 elevation of the Reactor Building, which could allow access into this High Radiation area. Although this access was unsecured and unposted, access could not be made unintentionally, due to the torturous path needed to avoid using the posted, locked, normal access. The pipe chase opening was maintained under constant surveillance until a security guard was posted at the area, to provide security control, at 0410 on November 24, 1984. Work Request 43798 was written to fabricate a cover over the pipe chase to provide a permanent barrier. The permanent barrier was erected and the Work Request was signed off as complete on November 27, 1984. Security terminated the security post at 1709 on November 27, 1984.

8412310019 841220
PDR ADOCK 05000373
S PDRIE22
11

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES: 8/31/86

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (3)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
LaSalle County Station Unit 1	0500037384	—	083	—	002	OF 02

TEXT (If more space is required, use additional NRC Form 388A's) (17)

I. EVENT DESCRIPTION

At 0100 on November 24, 1984, a Mechanical Maintenance Foreman found a pipe chase opening located above the Unit 1 drywell personnel access hatch on 740 elevation of the Reactor Building, which could allow access into this High Radiation area. Contrary to Technical Specification 6.1.1, the access to the area was found to be unsecured and unattended.

II. CAUSE

The pipe chase opening referenced above should have been covered with a permanent barrier to prevent unauthorized access during construction. A similar pipe chase opening on Unit 2 was secured properly during construction.

II. PROBABLE CONSEQUENCES OF THE OCCURRENCE

No unauthorized radiation exposure of greater than 50 mrem has occurred. No unauthorized access into this area has been detected. No unauthorized entry into the Primary Containment has been detected by the Control Room annunciation of the opening of the personnel access hatch doors.

IV. CORRECTIVE ACTION

The pipe chase opening was maintained under constant surveillance until a security guard was posted at the area to provide access control at 0410 on November 24, 1984. Work Request 43798 was written to fabricate a cover over the pipe chase to provide a permanent barrier. The permanent barrier was erected and the Work Request was signed off as complete on November 27, 1984. Security terminated the security post at 1709 on November 27, 1984.

V. PREVIOUS OCCURRENCES

LER 373/84-025 describes the only other occurrence of discovering a previously unidentified access to a High Radiation area.

VI. NAME AND TELEPHONE NUMBER OF PREPARER

L. R. Aldrich, 815/357-6761, extension 238.



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

December 20, 1984

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Reportable Occurrence Report #84-083-00, Docket #050-373 is being submitted to your office in accordance with 10CFR 50.73.

R. J. Diederich
for G. J. Diederich
Superintendent
LaSalle County Station

GJD/MLD/kg

Enclosure

xc: NRC, Regional Director
INPO-Records Center
File/NRC

IE22
11