



Carolina Power & Light Company

Brunswick Steam Electric Plant

JUL 02 1992

File: B09-13510C

10CFR 2.201

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 & 50-324/LICENSE NOS. DPR-71 & DPR-62
SUPPLEMENT TO REPLY TO NOTICE OF VIOLATION

Gentlemen:

This is to inform you of an inadvertent error as it appears in the Brunswick Steam Electric Plant's May 27, 1992 response to Notice of Violation 92-04. On page 5 in the section addressing corrective actions which have been taken, the statement is made that a revision to the original Short Term Structural Integrity (STSI) engineering evaluation was performed to include a safety evaluation addressing the impact of temporary blind flange installation on the operability of the Residual Heat Removal (RHR) system. In actuality, although the STSI evaluation was revised to incorporate a safety evaluation prior to submittal of the response, final management approval of the evaluation did not occur until June 30, 1992 due to the time required to resolve management comments. The safety evaluation determined that the temporary installation of blind flanges did not adversely impact the capability of the B loop of the RHR Service Water system to perform its intended safety function.

Any additional information if needed may be obtained from Mr. S. Floyd of my staff.

Yours very truly,

J. W. Spencer for

J. W. Spencer, General Manager
Brunswick Nuclear Project

SFT/

Enclosure

cc: Mr. S. D. Ebner
Mr. R. H. Lo
BSEP NRC Resident Office

9207070042 920702
PDR ADOCK 05000324
G PDR

JEDI 1/0