



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, D.C. 20555-0001

April 14, 2020

LICENSEE: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF APRIL 6, 2020, PRESUBMITTAL TELECONFERENCE MEETING WITH ENERGY NORTHWEST, TO DISCUSS A TECHNICAL SPECIFICATION CHANGE LICENSE AMENDMENT REQUEST FOR COLUMBIA GENERATING STATION (EPID L-2020-LRM-0022)

On April 6, 2020, a Category 1 public meeting was held by teleconference between the U.S. Nuclear Regulatory Commission (NRC) and representatives of Energy Northwest (the licensee). The purpose of the meeting was to discuss a planned license amendment request (LAR) regarding a change to Technical Specification (TS) 3.8.7 "Distribution Systems – Operating," for Columbia Generating Station (Columbia). The meeting notice and agenda, dated March 24, 2020, are available in the Agencywide Documents Access and Management System (ADAMS) at Accession No. ML20084N951. Enclosed is a list of attendees at the meeting.

During the meeting, the licensee presented information which was meant to further define the pending future submission. The licensee's presentation used for the meeting is available in ADAMS at Accession No. ML20093F016. The licensee's presentation outlined the licensing and technical aspects of the upcoming LAR including the scope of work, key features, and intended schedule plan for the amendment.

Also during the meeting, the NRC staff and the licensee discussed sufficiency items that should be considered as part of the upcoming submittal. Those items include:

1. a description of the TS completion time change and its basis reflective of operational experience;
2. a complete list of any and all compensatory measures associated with this license amendment;
3. a description of why the bucket could not be replaced online;
4. a description of why this LAR request is not applicable to other, similar control power transformers in the plant;
5. a clear description of whether the TS completion time request applies to the replacement of the electrical bucket or its starter coil, or both.

Members of the public were not in attendance. Public Meeting Feedback forms were not received.

Please direct any inquiries to me at 301-415-5136, or by e-mail at John.Klos@nrc.gov.

/RA/

L. John Klos, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure:
List of Attendees

cc: Listserv

LIST OF ATTENDEES
APRIL 6, 2020, PRESUBMITTAL TELECONFERENCE MEETING
WITH ENERGY NORTHWEST
REGARDING A PROPOSED LICENSE AMENDMENT REQUEST
TO CHANGE TECHNICAL SPECIFICATION 3.8.7 FOR
COLUMBIA GENERATING STATION

<u>NAME</u>	<u>ORGANIZATION</u>
Steve Smith	NRC ¹ (NRR ²)
Mehdi Reisi Fard	NRC (NRR)
John Klos	NRC (NRR)
Charles Moulton	NRC (NRR)
Jorge Cintron-Rivera	NRC (NRR)
Khoi Nguyen	NRC (NRR)
Richard Garcia	Energy Northwest
Desiree Wolfgramm	Energy Northwest
Mike Pezzetti	Energy Northwest
Keven Van Speybroeck	Energy Northwest
David Clymer	Energy Northwest
Woody Layne	Energy Northwest
James Darling	Energy Northwest
Habib Shtaih	Energy Northwest

¹ U.S. Nuclear Regulatory Commission

² Office of Nuclear Reactor Regulation

SUBJECT: SUMMARY OF APRIL 6, 2020, PRESUBMITTAL TELECONFERENCE
MEETING WITH ENERGY NORTHWEST, TO DISCUSS A TECHNICAL
SPECIFICATION CHANGE LICENSE AMENDMENT REQUEST FOR
COLUMBIA GENERATING STATION (EPID L-2020-LRM-0022) APRIL 14, 2020

DISTRIBUTION:

PUBLIC	MReisi Fardi, NRR
PM File Copy	CMoulton, NRR
RidsACRS_MailCTR Resource	JCintron-Rivera, NRR
RidsNrrDorl Resource	KNguyen, NRR
RidsNrrDorlLpl4 Resource	LBetancourt, NRR
RidsNrrPMColumbia Resource	CdeMessieres, NRR
RidsNrrLAPBlechman Resource	OLopez-Santiago, OEDO
RidsRgn4MailCenter Resource	MMcCoppin, OEDO
SSmith, NRR	

ADAMS Accession Nos.:

Meeting Notice ML20084N951

Meeting Summary ML20101L535

***via e-mail**

OFFICE	NRR/DORL/LPL4/PM	NRR/DORL/LPL4/LA*	NRR/DORL/LPL4/BC	NRR/DORL/LPL4/PM
NAME	JKlos	PBlechman	JDixon-Herrity	JKlos
DATE	04/09/2020	04/14/2020	04/14/2020	04/14/2020

OFFICIAL RECORD COPY