


**TEXAS UTILITIES GENERATING COMPANY**

SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

**BILLY R. CLEMENTS**  
VICE PRESIDENT, NUCLEAR OPERATIONS

December 17, 1984  
TXX-4379



Mr. D.R. Hunter, Chief  
Reactor Project Branch 2  
U.S. Nuclear Regulatory Commission  
Office of Inspection & Enforcement  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76012

Docket Nos.: 50-445  
50-446

COMANCHE PEAK STEAM ELECTRIC STATION  
VENTILATION EXHAUST DAMPERS  
QA FILE: CP-84-27, SDAR-152  
FILE NO.: 10110

Dear Mr. Hunter:

On September 13, 1984 we verbally notified your Mr. D. Hunnicutt of a deficiency regarding ventilation exhaust dampers that have been observed to be designed/installed to fail closed which would divert radioactive releases to rooms in which operator action is required. We have submitted interim reports logged TXX-4333 and TXX-4365 dated October 12, 1984 and November 20, 1984, respectively.

We are continuing our evaluation and anticipate completion by February 6, 1984.

Very truly yours,

*Billy R. Clements*

BRC:tlg

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

8501040068 B41217  
PDR ADOCK 05000445  
S PDR

IE-27  
1/0