

DMB




**LOUISIANA**  
**POWER & LIGHT**

142 DELARONDE STREET  
P. O. BOX 6008 • NEW ORLEANS, LOUISIANA 70174 • (504) 366-2345

April 4, 1984

W3P84-0927  
0-3-A20.03.17

Mr. John T. Collins  
Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive  
Suite 1000  
Arlington, Texas 76011




SUBJECT: Waterford 3 SES  
Docket No. 50-382  
IE Bulletin 83-08  
Electrical Circuit Breakers With An Undervoltage Trip Feature In  
Use In Safety-Related Applications Other Than The Reactor Trip  
System

Dear Mr. Collins:

As required by IE Bulletin 83-08, a review has been performed of circuit breakers in safety-related applications at Waterford 3, other than as reactor trip breakers. This review concluded that none of the subject circuit breakers (supplied exclusively by General Electric) incorporate the use of an undervoltage trip feature as discussed in IE Bulletin 83-04.

Based on the above information, LP&L considers all required action complete for IE Bulletin 83-08. If you have any questions or require additional information, please advise.

Very truly yours,

  
K.W. Cook

Nuclear Support and Licensing Manager

KWC/DWH/mlm

cc: W.M. Stevenson, E.L. Blake, G.L. Constable, J. Wilson,  
D.M. Crutchfield

8501070053 840404  
PDR ADDCK 05000382  
PDR  
Q

1611

Before the  
UNITED STATES NUCLEAR REGULATORY COMMISSION  
Docket No. 50-382

---

In the Matter of  
LOUISIANA POWER & LIGHT COMPANY

---

Response to IE Bulletin 83-08

Louisiana Power & Light Company, Applicant in the above captioned proceeding,  
hereby files a response to IE Bulletin 83-08, for Waterford SES Unit No. 3.

Respectfully submitted,  
LOUISIANA POWER & LIGHT COMPANY

By: 

R.M. Nelson  
Nuclear Support & Licensing  
Manager (acting)


DATE: April 4, 1984

STATE OF LOUISIANA)  
                                  ) SS  
PARISH OF ORLEANS )

R.M. Nelson, being duly sworn, states that he is Nuclear Support and Licensing Manager (acting) of Louisiana Power & Light Company and that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission this response to IE Bulletin 83-08.

  
R.M. Nelson

SUBSCRIBED AND SWORN to before me, a Notary Public, in and for the Parish and State above named, this 4TH day of APRIL, 1984.

  
Notary Public

MY COMMISSION EXPIRES:

AT DEATH