

DUKE POWER COMPANY

P.O. BOX 33189

CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

85 JAN 22 P 1: 55

January 14, 1985

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission - Region II
101 Marietta Street - Suite 2900
Atlanta, Georgia 30323

Subject: McGuire Nuclear Station - Unit 1
Docket Number 50-370

On December 13, 1984 Diesel Generator (D/G) 1A experienced 3 invalid failures following maintenance, apparently as a result of improper reassembly following maintenance. The investigation of this event is as yet incomplete. A complete report on the Diesel Generator failure will be submitted by February 14, 1985.

Very truly yours,

H.B. Tucker
Hal B. Tucker

SAG/mjf

cc: Mr. W. T. Orders
Senior Resident Inspector
McGuire Nuclear Station

8502060326 850114
PDR ADOCK 05000370
S PDR

OFFICIAL COPY
IE 22
1/0