



GULF STATES UTILITIES COMPANY

POST OFFICE BOX 2951 • BEAUMONT, TEXAS 77704

AREA CODE 409-838-6631

January 21, 1985


RBG-19962

File Nos. G9.5, G9.25.1.1

Mr. Robert D. Martin, Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV, Office of Inspection and Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Dear Mr. Martin:

River Bend Station Unit 1
Docket No. 50-458
Interim Report/DR-275



An interim or final status report concerning the welded studs for the variable inlet vane assembly on four fans supplied by Buffalo Forge Company for the Standby Gas Treatment System and Fuel Building charcoal filtration units will be provided by February 7, 1985.

Sincerely,

L. R. England

for J. E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

ME
JEB/PJD/lp

cc: Director of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

NRC Resident Inspector-Site

8502060552 850121
PDR ADOCK 05000458
S PDR

IL-27
110