

ATTACHMENT A

EXISTING TECHNICAL SPECIFICATIONS AND BASES
UNIT 3

9209150014 920909
PDR ADOCK 05000362
P PDR

INDEX

LIMITING CONDITION FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
HOT SHUTDOWN.....	3/4 4-3
COLD SHUTDOWN - LOOPS FILLED.....	3/4 4-5
COLD SHUTDOWN - LOOPS NOT FILLED.....	3/4 4-6
3/4.4.2 SAFETY VALVES - OPERATING.....	3/4 4-7
3/4.4.3 PRESSURIZER.....	3/4 4-8
3/4.4.4 STEAM GENERATORS.....	3/4 4-9
3/4.4.5 REACTOR COOLANT SYSTEM LEAKAGE	
LEAKAGE DETECTION SYSTEMS.....	3/4 4-17
OPERATIONAL LEAKAGE.....	3/4 4-18
3/4.4.6 CHEMISTRY.....	3/4 4-21
3/4.4.7 SPECIFIC ACTIVITY.....	3/4 4-24
3/4.4.8 PRESSURE/TEMPERATURE LIMITS	
REACTOR COOLANT SYSTEM.....	3/4 4-28
PRESSURIZER - HEATUP/COOLDOWN.....	3/4 4-32
OVERPRESSURE PROTECTION SYSTEMS	
RCS TEMPERATURE $< 302^{\circ}\text{F}$	3/4 4-33
RCS TEMPERATURE $> 302^{\circ}\text{F}$	3/4 4-35
3/4.4.9 STRUCTURAL INTEGRITY.....	3/4 4-36
3/4.4.10 REACTOR COOLANT GAS VENT SYSTEM.....	3/4 4-37
<u>3/4.5 EMERGENCY CORE COOLING SYSTEMS</u>	
3/4.5.1 SAFETY INJECTION TANKS.....	3/4 5-1
3/4.5.2 ECCS SUBSYSTEMS - $T_{\text{avg}} \geq 350^{\circ}\text{F}$	3/4 5-3
3/4.5.3 ECCS SUBSYSTEMS - $T_{\text{avg}} < 350^{\circ}\text{F}$	3/4 5-7
3/4.5.4 REFUELING WATER STORAGE TANK.....	3/4 5-8

INDEX

LIST OF FIGURES

<u>FIGURE</u>		<u>PAGE</u>
3.1-1	MINIMUM BORIC ACID STORAGE TANK VOLUME AND TEMPERATURE AS A FUNCTION OF STORED BORIC ACID CONCENTRATION.....	3/4 1-13
3.1-2	CEA INSERTION LIMITS VS FRACTION OF ALLOWABLE THERMAL POWER.....	3/4 1-24
3.2-1	DNBR MARGIN OPERATING LIMIT BASED ON COLSS.....	3/4 2-7
3.2-2	DNBR MARGIN OPERATING LIMIT BASED ON CORE PROTECTION CALCULATORS (COLSS OUT OF SERVICE).....	3/4 2-8
3.3-1	DEGRADED BUS VOLTAGE TRIP SETTING.....	3/4 3-40
4.4-1	TUBE WALL THINNING ACCEPTANCE CRITERIA.....	3/4 4-16
3.4-1	DOSE EQUIVALENT I-131 PRIMARY COOLANT SPECIFIC ACTIVITY LIMIT VERSUS PERCENT OF RATED THERMAL POWER WITH THE PRIMARY COOLANT SPECIFIC ACTIVITY >1.0 μ Ci/GRAM DOSE EQUIVALENT I-131.....	3/4 4-27
3.4-2	HEATUP RCS PRESSURE/TEMPERATURE LIMITATIONS FOR 0-5 YEARS.....	3/4 4-30
3.4-3	COOLDOWN RCS PRESSURE/TEMPERATURE LIMITATIONS FOR 0-5 YEARS.....	3/4 4-30a
3.4-4	RCS PRESSURE/TEMPERATURE LIMITATIONS FOR 4-8 EFY.....	3/4 4-31
3.4-5	RCS PRESSURE/TEMPERATURE LIMITS MAXIMUM ALLOWABLE COOLDOWN RATES (4-8 EFY).....	3/4 4-31a
3.7-1	MINIMUM REQUIRED FEEDWATER INVENTORY FOR TANK T-121 FOR MAXIMUM POWER ACHIEVED TO DATE.....	3/4 7-7
5.1-1	EXCLUSION AREA.....	5-2
5.1-2	LOW POPULATION ZONE.....	5-3
5.1-3	SITE BOUNDARY FOR GASEOUS EFFLUENTS.....	5-4
5.1-4	SITE BOUNDARY FOR LIQUID EFFLUENTS.....	5-5
5.6-1	UNITS 2 AND 3 FUEL MINIMUM BURNUP VS. INITIAL ENRICHMENT FOR REGION II RACKS.....	5-12
5.6-2	UNIT 1 FUEL MINIMUM BURNUP VS. INITIAL ENRICHMENT FOR REGION II RACKS.....	5-13
5.6-3	FUEL STORAGE PATTERNS FOR REGION II RACKS.....	5-14

INDEX

LIST OF FIGURES

<u>FIGURE</u>		<u>PAGE</u>
5.6-4	FUEL STORAGE PATTERNS FOR REGION II RACKS RECONSTITUTION STATION.....	5-15
6.2-1	OFFSITE ORGANIZATION.....	6-3
6.2-2	UNIT ORGANIZATION.....	6-4
6.2-3	CONTROL ROOM AREA.....	6-6

REACTOR COOLANT SYSTEM

3/4.4.8 PRESSURE/TEMPERATURE LIMITS

REACTOR COOLANT SYSTEM

LIMITING CONDITION FOR OPERATION

3.4.8.1 With the reactor vessel head bolts tensioned*, the Reactor Coolant System (except the pressurizer) temperature and pressure shall be limited in accordance with the limit lines shown on Figures 3.4-2, 3.4-3, 3.4-4, and 3.4-5 during heatup, cooldown, criticality, and inservice leak and hydrostatic testing with:

- a. A maximum heatup as specified by Figure 3.4-3 in any 1-hour period with RCS cold leg temperature less than 153°F. A maximum heatup of 60°F. in any 1-hour period with RCS cold leg temperature greater than 153°F.
- b. A maximum cooldown as specified by Figure 3.4-5 in any 1-hour period with RCS cold leg temperature less than 126°F. A maximum cooldown of 100°F in any 1-hour period with RCS cold leg temperature greater than 126°F.
- c. A maximum temperature change of 10°F in any 1-hour period during inservice hydrostatic and leak testing operations above the heatup and cooldown limit curves.
- d. A minimum temperature of 86°F to tension reactor vessel head bolts.

With the reactor vessel head bolts detensioned, the Reactor Coolant System (except the pressurizer) temperature shall be limited to a maximum heatup or cooldown of 60°F in any 1-hour period.

APPLICABILITY: At all times.

ACTION:

With any of the above limits exceeded, restore the temperature and/or pressure to within the limit within 30 minutes; perform an engineering evaluation to determine the effects of the out-of-limit condition on the structural integrity of the Reactor Coolant System; determine that the Reactor Coolant System remains acceptable for continued operations or be in at least HOT STANDBY within the next 6 hours and reduce the RCS T_{avg} and pressure to less than 200°F and 500 psia, respectively, within the following 30 hours.

*With the reactor vessel head bolts detensioned, RCS cold leg temperature may be less than 86°F.

REACTOR COOLANT SYSTEM

3/4 4.8 PRESSURE/TEMPERATURE LIMITS

REACTOR COOLANT SYSTEM

LIMITING CONDITION FOR OPERATION

SURVEILLANCE REQUIREMENTS

4.4.8.1.1 The Reactor Coolant System temperature and pressure shall be determined to be within the limits at least once per 30 minutes during system heatup, cooldown, and inservice leak and hydrostatic testing operations.

4.4.8.1.2 The reactor vessel material irradiation surveillance specimens shall be removed and examined, to determine changes in material properties, at the intervals required by 10 CFR 50 Appendix H in accordance with the schedule in Table 4.4-5. The results of these examinations shall be used to update Figures 3.4-2 and 3.4-3. Recalculate the Adjusted Reference Temperature based on the greater of the following:

- a. The actual shift in reference temperature for plate C-6802-1 as determined by impact testing, or
- b. The predicted shift in reference temperature for weld seams 2-203A, 2-203B, or 2-203C as determined by Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials," May 1988.





FIGURE 3.4-2

SONGS 3 RCS PRESSURE/TEMPERATURE
LIMITATION FOR 4-8 EFPY



NOTE: A MAXIMUM HEATUP RATE OF 80°F/HR IS
ALLOWED AT ANY TEMPERATURE ABOVE 153°F

FIGURE 3.4-3

SONGS 3 RCS PRESSURE/TEMPERATURE LIMITS
MAXIMUM ALLOWABLE HEATUP RATES (4-8 EFY)





FIGURE 3.4-4

SONGS 3 RCS PRESSURE/TEMPERATURE
LIMITATIONS FOR 4-8 EFPY



NOTE: A MAXIMUM COOLDOWN RATE OF 100°F/HR IS
ALLOWED AT ANY TEMPERATURE ABOVE 128°F

FIGURE 3.4-5

SONGS 3 RCS PRESSURE/TEMPERATURE LIMITS
MAXIMUM ALLOWABLE COOLDOWN RATES (4-8 EFY)

Table 3.4-3

<u>Low Temperature RCS Overpressure Protection Range</u>		
<u>Operating Period, EFPY</u>	<u>Cold Leg Temperature, °F</u>	
	<u>During Heatup</u>	<u>During Cooldown</u>
4 to 8	≤ 302	≤ 267

REACTOR COOLANT SYSTEM

OVERPRESSURE PROTECTION SYSTEMS

RCS TEMPERATURE $\leq 302^{\circ}\text{F}$

LIMITING CONDITION FOR OPERATION

3.4.8.3.1 At least one of the following overpressure protection systems shall be OPERABLE:

- a. The Shutdown Cooling System Relief Valve (PSV9349) with:
 - 1) A lift setting of 406 ± 10 psig*, and
 - 2) Relief valve isolation valves 3HV9337, 3HV9339, 3HV9377, and 3HV9378 open, or,
- b. The Reactor Coolant System depressurized with an RCS vent of greater than or equal to 5.6 square inches.

APPLICABILITY: MODE 4 when the temperature of any one RCS cold leg is less than or equal to that specified in Table 3.4-3; MODE 5; MODE 6 with the reactor vessel head on.

ACTION:

- a. With the SDCS Relief Valve inoperable, reduce T_{avg} to less than 200°F , depressurize and vent the RCS through a greater than or equal to 5.6 square inch vent within the next 8 hours.
- b. With one or both SDCS Relief Valve isolation valves in a single SDCS Relief Valve isolation valve pair (valve pair 3HV9337 and 3HV9339 or valve pair 3HV9377 and 3HV9378) closed, open the closed valve(s) within 7 days or reduce T_{avg} to less than 200°F , depressurize and vent the RCS through a greater than or equal to 5.6 inch vent within the next 8 hours.
- c. In the event either the SDCS Relief Valve or an RCS vent is used to mitigate an RCS pressure transient, a Special Report shall be prepared and submitted to the Commission pursuant to Specification 6.9.2 within 30 days. The report shall describe the circumstances initiating the transient, the effect of the SDCS Relief Valve or RCS vent on the transient and any corrective action necessary to prevent recurrence.
- d. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.4.8.3.1.1 The SDCS Relief Valve shall be demonstrated OPERABLE by:

- a. Verifying at least once per 72 hours when the SDCS Relief Valve is being used for overpressure protection that SDCS Relief Valve isolation valves 3HV9337, 3HV9339, 3HV9377, and 3HV9378 are open.

*The lift setting pressure applicable to valve temperatures of less than or equal to 130°F .

REACTOR COOLANT SYSTEM

OVERPRESSURE PROTECTION SYSTEMS

RCS TEMPERATURE > 302°F

LIMITING CONDITION FOR OPERATION

3.4.8.3.2 At least one of the following overpressure protection systems shall be OPERABLE:

- a. The Shutdown Cooling System Relief Valve (PSV9349) with:
 - 1) A lift setting of 406 ± 10 psig*, and
 - 2) Relief valve isolation valves 3HV9337, 3HV9339, 3HV9377, and 3HV9378 open, or,
- b. A minimum of one pressurizer code safety valve with a lift setting of $2500 \text{ psia} \pm 1\%^{**}$.

APPLICABILITY: MODE 4 with RCS temperature above that specified in Table 3.4-3.

ACTION:

- a. With no safety or relief valve OPERABLE, be in COLD SHUTDOWN and vent the RCS through a greater than or equal to 5.6 square inch vent within the next 3 hours.
- b. In the event the SDCS Relief Valve or an RCS vent is used to mitigate an RCS pressure transient, a Special Report shall be prepared and submitted to the Commission pursuant to Specification 6.9.2 within 30 days. The report shall describe the circumstances initiating the transient, the effect of the SDCS Relief Valve code safety valve or RCS vent on the transient and any corrective action necessary to prevent recurrence.

SURVEILLANCE REQUIREMENTS

4.4.8.3.2.1 The SDCS Relief Valve shall be demonstrated OPERABLE by:

- a. Verifying at least once per 72 hours that the SDCS Relief Valve isolation valves 3HV9337, 3HV9339, 3HV9377 and 3HV9378 are open when the SDCS Relief Valve is being used for overpressure protection.
- b. Verifying relief valve setpoint at least once per 30 months when tested pursuant to Specification 4.0.5.

4.4.8.3.2.2 The pressurizer code safety valve has no additional surveillance requirements other than those required by Specification 4.0.5.

4.4.8.3.2.3 The RCS vent shall be verified to be open at least once per 12 hours when the vent is being used for overpressure protection, except when the vent pathway is provided with a valve which is locked, sealed, or otherwise secured in the open position, then verify these valves open at least once per 31 days.

*The lift setting pressure applicable to valve temperatures of less than or equal to 130°F.

**The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

REACTOR COOLANT SYSTEM

BASES

PRESSURE/TEMPERATURE LIMITS (Continued)

The heatup and cooldown limit curves (Figures 3.4-2 and 3.4-3) are composite curves which were prepared by determining the most conservative case, with either the inside or outside wall controlling, for any heatup rate of up to 60°F/hr or cooldown rate of up to 100°F/hr. The heatup and cooldown curves were prepared based upon the most limiting value of the predicted adjusted reference temperature at the end of the service period indicated on Figures 3.4-2 and 3.4-3.

The reactor vessel materials have been tested to determine their initial RT_{NDT} ; the results of these tests are shown in Table B 3/4.4-1. Reactor operation and resultant fast neutron (E greater than 1 MeV) irradiation will cause an increase in the RT_{NDT} . Therefore, an adjusted reference temperature, based upon the fluence and copper and nickel content of the material in question, can be predicted using FSAR Table 5.2-5 and the recommendations of Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials." The heatup and cooldown limit curves, Figures 3.4-2 and 3.4-3, include predicted adjustments for this shift in RT_{NDT} at the end of the applicable service period, as well as adjustments for possible errors in the pressure and temperature sensing instruments.

The actual shift in RT_{NDT} of the vessel material will be established periodically during operation by removing and evaluating, in accordance with ASTM E185-73 and 10 CFR Appendix H, reactor vessel material irradiation surveillance specimens installed near the inside wall of the reactor vessel in the core area. The surveillance specimen withdrawal schedule is shown in Table 4.4-5. Since the neutron spectra at the irradiation samples and vessel inside radius are essentially identical, the measured transition shift for a sample can be applied with confidence to the adjacent section of the reactor vessel taking into account the location of the sample closer to the core than the vessel wall by means of the Lead Factor. The heatup and cooldown curves must be recalculated when the delta RT_{NDT} determined from the surveillance capsule is different from the calculated delta RT_{NDT} for the equivalent capsule radiation exposure.

The pressure-temperature limit lines shown on Figures 3.4-2 and 3.4-3 for reactor criticality and for inservice leak and hydrostatic testing have been provided to assure compliance with the minimum temperature requirements of Appendix G to 10 CFR 50.

The maximum RT_{NDT} for all Reactor Coolant System pressure-retaining materials, with the exception of the reactor pressure vessel, has been determined to be 90°F. The Lowest Service Temperature limit line shown on Figures 3.4-2 and 3.4-3 is based upon this RT_{NDT} since Article NB-2332 (Summer Addenda of 1972) of Section III of the ASME Boiler and Pressure Vessel Code requires the Lowest Service Temperature to be $RT_{NDT} + 100°F$ for piping, pumps and valves. Below this temperature, the system pressure must be limited to a maximum of 20% of the system's hydrostatic test pressure of 3125 psia.

The limitations imposed on the pressurizer heatup and cooldown rates and spray water temperature differential are provided to assure that the pressurizer is operated within the design criteria assumed for the fatigue analysis performed in accordance with the ASME Code requirements.

TABLE B 3/4.4-1

REACTOR VESSEL TOUGHNESS

Piece No.	Code No.	Material	Vessel Location	Drop Weight Results	Temperature of Charpy V-Notch		Minimum Upper Shelf Cv energy for Longitudinal Direction-ft lb
					@ 30	@ 50	
					ft - lb	ft - lb	
215-01	C-6801-1	A533GRBCL1	Upper Shell Plate	-20	28	64	115
215-01	C-6801-2	A533GRBCL1	Upper Shell Plate	-20	-6	34	106
215-01	C-6801-3	A533GRBCL1	Upper Shell Plate	-20	18	36	115
215-02	C-6802-4	A533GRBCL1	Lower Shell Plate	-30	32	62	115
215-02	C-6802-5	A533GRBCL1	Lower Shell Plate	0	36	64	110
215-02	C-6802-6	A533GRBCL1	Lower Shell Plate	-10	32	100	90
215-03	C-6802-1	A533GRBCL1	Intermediate Shell	-20	56	100	95
215-03	C-6802-2	A533GRBCL1	Intermediate Shell	-20	40	66	113
215-03	C-6802-3	A533GRBCL1	Intermediate Shell	-10	44	80	101
203-02	C-6823	A508CL2	Vessel Flange Forging	0	-30	-15	NA
209-02	C-6824-1	A508CL2	Closure Head Flange Forging	-40	-100	-100	NA
205-02	C-6829-1	A508CL2	Inlet Nozzle Forging	10	-35	-5	109
205-02	C-6829-2	A508CL2	Inlet Nozzle Forging	0	-55	-35	156
205-02	C-6829-3	A508CL2	Inlet Nozzle Forging	10	-25	35	112
205-02	C-6829-4	A508CL2	Inlet Nozzle Forging	10	-30	25	108
205-06	C-6830-1	A508CL2	Outlet Nozzle Forging	-10	-30	-15	125
205-06	C-6830-2	A508CL2	Outlet Nozzle Forging	-10	-20	-5	131
235-01	C-6840-1	A533GRBCL1	Bottom Head Torus	-50	-10	0	107
265-02	C-6841-1	A533GRBCL1	Bottom Head Dome	-40	10	20	79

ISSUED TO A

CONTROLLED LOCATION

NOV 15 1982

ATTACHMENT B

PROPOSED TECHNICAL SPECIFICATIONS AND BASES
UNIT 3

INDEX

LIMITING CONDITION FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
HOT SHUTDOWN.....	3/4 4-3
COLD SHUTDOWN - LOOPS FILLED.....	3/4 4-5
COLD SHUTDOWN - LOOPS NOT FILLED.....	3/4 4-6
3/4.4.2 SAFETY VALVES - OPERATING.....	3/4 4-7
3/4.4.3 PRESSURIZER.....	3/4 4-8
3/4.4.4 STEAM GENERATORS.....	3/4 4-9
3/4.4.5 REACTOR COOLANT SYSTEM LEAKAGE	
LEAKAGE DETECTION SYSTEMS.....	3/4 4-17
OPERATIONAL LEAKAGE.....	3/4 4-18
3/4.4.6 CHEMISTRY.....	3/4 4-21
3/4.4.7 SPECIFIC ACTIVITY.....	3/4 4-24
3/4.4.8 PRESSURE/TEMPERATURE LIMITS	
REACTOR COOLANT SYSTEM.....	3/4 4-28
PRESSURIZER - HEATUP/COOLDOWN.....	3/4 4-32
OVERPRESSURE PROTECTION SYSTEMS	
RCS TEMPERATURE ≤ 302 265°F.....	3/4 4-33
RCS TEMPERATURE > 302 265°F.....	3/4 4-35
3/4.4.9 STRUCTURAL INTEGRITY.....	3/4 4-36
3/4.4.10 REACTOR COOLANT GAS VENT SYSTEM.....	3/4 4-37
<u>3/4.5 EMERGENCY CORE COOLING SYSTEMS</u>	
3/4.5.1 SAFETY INJECTION TANKS.....	3/4 5-1
3/4.5.2 ECCS SUBSYSTEMS - $T_{avg} \geq 350^{\circ}\text{F}$	3/4 5-3
3/4.5.3 ECCS SUBSYSTEMS - $T_{avg} < 350^{\circ}\text{F}$	3/4 5-7
3/4.5.4 REFUELING WATER STORAGE TANK.....	3/4 5-8

INDEX

LIST OF FIGURES

<u>FIGURE</u>		<u>PAGE</u>
3.1-1	MINIMUM BORIC ACID STORAGE TANK VOLUME AND TEMPERATURE AS A FUNCTION OF STORED BORIC ACID CONCENTRATION.....	3/4 1-13
3.1-2	CEA INSERTION LIMITS VS FRACTION OF ALLOWABLE THERMAL POWER.....	3/4 1-24
3.2-1	DNBR MARGIN OPERATING LIMIT BASED ON COLSS.....	3/4 2-7
3.2-2	DNBR MARGIN OPERATING LIMIT BASED ON CORE PROTECTION CALCULATORS (COLSS OUT OF SERVICE).....	3/4 2-8
3.3-1	DEGRADED BUS VOLTAGE TRIP SETTING.....	3/4 3-40
4.4-1	TUBE WALL THINNING ACCEPTANCE CRITERIA.....	3/4 4-16
3.4-1	DOSE EQUIVALENT I-131 PRIMARY COOLANT SPECIFIC ACTIVITY LIMIT VERSUS PERCENT OF RATED THERMAL POWER WITH THE THE PRIMARY COOLANT SPECIFIC ACTIVITY $>1.0 \mu\text{Ci}/\text{GRAM}$ DOSE EQUIVALENT I-131.....	3/4 4-27
3.4-2	SONGS 3 HEATUP RCS PRESSURE/TEMPERATURE LIMITATIONS FOR 0-5 YEARS 8 EFY - NORMAL OPERATION.....	3/4 4-30
3.4-3	COOLDOWN SONGS 3 RCS PRESSURE/TEMPERATURE LIMITS ATION 0-5 YEARS MAXIMUM ALLOWABLE HEATUP RATES (8 EFY) - NORMAL OPERATION.....	3/4 4-30a
3.4-4	SONGS 3 COOLDOWN RCS PRESSURE/TEMPERATURE LIMITATIONS FOR 4 8 EFY -NORMAL OPERATION.....	3/4 4-31
3.4-5	SONGS 3 RCS PRESSURE/TEMPERATURE LIMITS MAXIMUM ALLOWABLE COOLDOWN RATES (4 8 EFY) -NORMAL OPERATION.....	3/4 4-31a
3.4-6	SONGS 3 COOLDOWN RCS PRESSURE/TEMPERATURE LIMITATIONS FOR 8 EFY -REMOTE SHUTDOWN OPERATION.....	3/4 4-31b
3.4-7	SONGS 3 RCS PRESSURE/TEMPERATURE LIMITS MAXIMUM ALLOWABLE COOLDOWN RATES (8 EFY) - REMOTE SHUTDOWN OPERATION.....	3/4 4-31c
3.7-1	MINIMUM REQUIRED FEEDWATER INVENTORY FOR TANK T-121 FOR MAXIMUM POWER ACHIEVED TO DATE.....	3/4 7-7
5.1-1	EXCLUSION AREA.....	5-2
5.1-2	LOW POPULATION ZONE.....	5-3
5.1-3	SITE BOUNDARY FOR GASEOUS EFFLUENTS.....	5-4
5.1-4	SITE BOUNDARY FOR LIQUID EFFLUENTS.....	5-5

INDEX

LIST OF FIGURES

<u>FIGURE</u>		<u>PAGE</u>
5.6-1	UNITS 2 AND 3 FUEL MINIMUM BURNUP VS. INITIAL ENRICHMENT FOR REGION II RACKS.....	5-12
5.6-2	UNIT 1 FUEL MINIMUM BURNUP VS. INITIAL ENRICHMENT FOR REGION II RACKS.....	5-13
5.6-3	FUEL STORAGE PATTERNS FOR REGION II RACKS.....	5-14
6.2-1	OFFSITE ORGANIZATION.....	6-3
6.2-2	UNIT ORGANIZATION.....	6-4
6.2-3	CONTROL ROOM AREA.....	6-6

REACTOR COOLANT SYSTEM

3/4.4.8. PRESSURE/TEMPERATURE LIMITS

REACTOR COOLANT SYSTEM

LIMITING CONDITION FOR OPERATION

3.4.8.1 With the reactor vessel head bolts tensioned*, the Reactor Coolant System (except the pressurizer) temperature and pressure shall be limited in accordance with the limit lines shown on Figures 3.4-2, 3.4-3, 3.4-4, and 3.4-5, 3.4-6, and 3.4-7 during heatup, cooldown, criticality, and inservice leak and hydrostatic testing with:

- a. A maximum heatup as specified by Figure 3.4-3 in any 1-hour period with RCS cold leg temperature less than ~~±53~~ 180°F. A maximum heatup of 60°F in any 1-hour period with RCS cold leg temperature greater than ~~±53~~ 180°F.
- b. A maximum cooldown as specified by Figure 3.4-5 in any 1-hour period with RCS cold leg temperature less than ~~±26~~ 175°F. A maximum cooldown of 100°F in any 1-hour period with RCS cold leg temperature greater than ~~±26~~ 175°F.
- c. A maximum temperature change of 10°F in any 1-hour period during inservice hydrostatic and leak testing operations above the heatup and cooldown limit curves.
- d. A minimum temperature of 86°F to tension reactor vessel head bolts.

With the reactor vessel head bolts detensioned, the Reactor Coolant System (except the pressurizer) temperature shall be limited to a maximum heatup or cooldown of 60°F in any 1-hour period.

APPLICABILITY: At all times.

ACTION:

With any of the above limits exceeded, restore the temperature and/or pressure to within the limit within 30 minutes; perform an engineering evaluation to determine the effects of the out-of-limit condition on the structural integrity of the Reactor Coolant System; determine that the Reactor Coolant System remains acceptable for continued operations or be in at least HOT STANDBY within the next 6 hours and reduce the RCS T_{avg} and pressure to less than 200°F and 500 psia, respectively, within the following 30 hours.

* With the reactor vessel head bolts detensioned, RCS cold leg temperature may be less than 86°F.

REACTOR COOLANT SYSTEM

3/4.4.8 PRESSURE/TEMPERATURE LIMITS

REACTOR COOLANT SYSTEM

LIMITING CONDITION FOR OPERATION

SURVEILLANCE REQUIREMENTS

4.4.8.1.1 The Reactor Coolant System temperature and pressure shall be determined to be within the limits at least once per 30 minutes during system heatup, cooldown, and inservice leak and hydrostatic testing operations.

4.4.8.1.2 The reactor vessel material irradiation surveillance specimens shall be removed and examined, to determine changes in material properties, at the intervals required by 10 CFR 50 Appendix H in accordance with the schedule in Table 4.4-5. The results of these examinations shall be used to update Figures 3.4-2 and 3.4-3 through 3.4-7. Recalculate the Adjusted Reference Temperature based on the greater of the following: in accordance with Regulatory Guide 1.99 Revision 2, "Radiation Embrittlement of Reactor Vessel Materials," May 1988.

- a. ~~The actual shift in reference temperature for plate C 6802-1 as determined by impact testing, or~~
- b. ~~The predicted shift in reference temperature for weld seams 2-203A, 2-203B, or 2-203C as determined by Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials," May 1988.~~





FIGURE 3.4-2
SONGS 3 HEATUP RCS PRESSURE/TEMPERATURE
LIMITATIONS FOR —4— 8 EFY
Normal Operation



NOTE: A MAXIMUM HEATUP RATE OF 60°F/HR IS ALLOWED
AT ANY TEMPERATURE ABOVE 153°F 180°F

FIGURE 3.4-3

SONGS 3 RCS PRESSURE/TEMPERATURE LIMITS
MAXIMUM ALLOWABLE HEATUP RATES (—4— 8 EFPY)
Normal Operation





FIGURE 3.4-4

SONGS 3 COOLDOWN RCS PRESSURE/TEMPERATURE
LIMITATIONS FOR —4— 8 EFPY
Normal Operation



NOTE: A MAXIMUM COOLDOWN RATE OF 100°F/HR IS ALLOWED
AT ANY TEMPERATURE ABOVE 175°F

FIGURE 3.4-5

SONGS 3 RCS PRESSURE/TEMPERATURE LIMITS
MAXIMUM ALLOWABLE COOLDOWN RATES (—4— 8 EFY)
Normal Operation

INDICATED PRESSURIZER PRESSURE (PSIA)





FIGURE 3.4-6

SONGS 3 COOLDOWN RCS PRESSURE/TEMPERATURE
LIMITATIONS FOR 8 EFY
Remote Shutdown Operation



NOTE: A MAXIMUM COOLDOWN RATE OF 100°F/HR IS ALLOWED
AT ANY TEMPERATURE ABOVE 184°F

FIGURE 3.4-7

SONGS 3 RCS PRESSURE/TEMPERATURE LIMITS
MAXIMUM ALLOWABLE COOLDOWN RATES (8 EFY)
Remote Shutdown Operation

TABLE 3.4-3

Low Temperature RCS Overpressure Protection Range

<u>Operating Period, EFPY</u>	<u>Cold Leg Temperature, °F</u>	
	<u>During Heatup</u>	<u>During Cooldown</u>
4 Up to 8 (Normal Operation)	≤ 302 265	≤ 267 249
Up to 8 (Remote Shutdown Operation)	*	≤ 249

* Heatup operations are not normally performed from the Remote Shutdown panels.

REACTOR COOLANT SYSTEM

OVERPRESSURE PROTECTION SYSTEMS

RCS TEMPERATURE ≤ 302 265°F

LIMITING CONDITION FOR OPERATION

3.4.8.3.1 At least one of the following overpressure protection systems shall be OPERABLE:

- a. The Shutdown Cooling System Relief Valve (PSV 9349) with:
 - 1) A lift setting of 406 ± 10 psig*, and
 - 2) Relief valve isolation valves 3HV9337, 3HV9339, 3HV9377, and 3HV9378 open, or,
- b. The Reactor Coolant System depressurized with an RCS vent of greater than or equal to 5.6 square inches.

APPLICABILITY: Mode 4 when the temperature of any one RCS cold leg is less than or equal to that specified in Table 3.4-3; MODE 5; MODE 6 with the reactor vessel head on.

ACTION:

- a. With the SDCS Relief Valve inoperable, reduce T_{avg} to less than 200°F, depressurize and vent the RCS through a greater than or equal to 5.6 square inch vent within the next 8 hours.
- b. With one or both SDCS Relief Valve isolation valves in a single SDCS Relief Valve isolation valve pair (valve pair 3HV9337 and 3HV9339 or valve pair 3HV9377 and 3HV9378) closed, open the closed valve(s) within 7 days or reduce T_{avg} to less than 200°F, depressurize and vent the RCS through a greater than or equal to 5.6 inch vent within the next 8 hours.
- c. In the event either the SDCS Relief Valve or an RCS vent is used to mitigate an RCS pressure transient, a Special Report shall be prepared and submitted to the Commission pursuant to Specification 6.9.2 within 30 days. The report shall describe the circumstances initiating the transient, the effect of the SDCS Relief Valve or RCS vent on the transient and any corrective action necessary to prevent recurrence.
- d. The provisions of Technical Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.4.8.3.1.1 The SDCS Relief Valve shall be demonstrated OPERABLE by:

- a. Verifying at least once per 72 hours when the SDCS Relief Valve is being used for overpressure protection that SDCS Relief Valve isolation valves 3HV9337, 3HV9339, 3HV9377 and 3HV9378 are open.

*The lift setting pressure applicable to valve temperatures of less than or equal to 130°F.

REACTOR COOLANT SYSTEM

OVERPRESSURE PROTECTION SYSTEMS

RCS TEMPERATURE >302 265°F

LIMITING CONDITION FOR OPERATION

3.4.8.3.2 At least one of the following overpressure protection systems shall be OPERABLE:

- a. The Shutdown Cooling System Relief Valve (PSV 9349) with:
 - 1) A lift setting of 406 ± 10 psig*, and
 - 2) Relief valve isolation valves 3HV9337, 3HV9339, 3HV9377, and 3HV9378 open, or,
- b. A minimum of one pressurizer code safety valve with a lift setting of 2500 psia $\pm 1\%$ **.

APPLICABILITY: Mode 4 with RCS temperature above that specified in Table 3.4-3.

ACTION:

- a. With no safety or relief valve OPERABLE, be in COLD SHUTDOWN and vent the RCS through a greater than or equal to 5.6 square inch vent within the next 8 hours.
- b. In the event the SDCS Relief Valve or an RCS vent is used to mitigate an RCS pressure transient, a Special Report shall be prepared and submitted to the Commission pursuant to Specification 6.9.2 within 30 days. The report shall describe the circumstances initiating the transient, the effect of the SDCS Relief Valve code safety valve or RCS vent on the transient and any corrective action necessary to prevent recurrence.

SURVEILLANCE REQUIREMENTS

4.4.8.3.2.1 The SDCS Relief Valve shall be demonstrated OPERABLE by:

- a. Verifying at least once per 72 hours that the SDCS Relief Valve isolation valves 3HV9337, 3HV9339, 3HV9377 and 3HV9378 are open when the SDCS Relief Valve is being used for overpressure protection.
- b. Verifying relief valve setpoint at least once per 30 months when tested pursuant to Specification 4.0.5

4.4.8.3.2.2 The pressurizer code safety valve has no additional surveillance requirements other than those required by Specification 4.0.5.

4.4.8.3.2.3 The RCS vent shall be verified to be open at least once per 12 hours when the vent is being used for overpressure protection, except when the vent pathway is provided with a valve which is locked, sealed, or otherwise secured in the open position, then verify these valves open at least once per 31 days.

* The lift setting pressure applicable to valve temperatures of less than or equal to 130°F.

**The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

REACTOR COOLANT SYSTEM

BASES

PRESSURE/TEMPERATURE LIMITS (Continued)

The heatup and cooldown limit curves for normal operation (Figures 3.4-2 and 3.4-34) and the cooldown limit curve for remote shutdown operation (Figure 3.4-6) are composite curves which were prepared by determining the most conservative case, with either the inside or outside wall controlling, for any heatup rate of up to 60°F/hr or cooldown rate of up to 100°F/hr. The limit curves for Remote Shutdown operation are determined using the Total Loop Uncertainties (TLUs) for temperature and pressure for the Remote Shutdown Panel instruments in which the pressure TLUs are higher than those for the Control Room shutdown instruments. The heatup and cooldown curves were prepared based upon the most limiting value of the predicted adjusted reference temperature at the end of the service period indicated on Figures 3.4-2 and 3.4-34 for normal operation and Figure 3.4-6 for Remote Shutdown operation.

The reactor vessel materials have been tested prior to reactor startup to determine their initial RT_{NDT} . The results of these tests and the updates in response to Generic Letter 92-01, "Reactor Vessel Structural Integrity," Revision 1 are shown in Table B 3/4.4-1. Reactor operation and resultant fast neutron (E greater than 1 MeV) irradiation will cause an increase in the RT_{NDT} . Therefore, an adjusted reference temperature based upon the fluence and copper and nickel content of the material in question, can be predicted using UFSAR Table 5.2-5.6 and the recommendations of Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials." The heatup limit curve (Figure 3.4-2) and the cooldown limit curves, Figures 3.4-24, and 3.4-36, include predicted adjustments for this shift in RT_{NDT} at the end of the applicable service period, as well as adjustments for possible errors in the pressure and temperature sensing instruments.

The actual shift in RT_{NDT} of the vessel material will be established periodically during operation by removing and evaluating, in accordance with ASTM E185-73 and 10 CFR 50 Appendix H, reactor vessel material irradiation surveillance specimens installed near the inside wall of the reactor vessel in the core area. The surveillance specimen withdrawal schedule is shown in Table 4.4-5. Since the neutron spectra at the irradiation samples and vessel inside radius are essentially identical, the measured transition shift for a sample can be applied with confidence to the adjacent section of the reactor vessel taking into account the location of the sample closer to the core than the vessel wall by means of the Lead Factor. The heatup and cooldown curves must be recalculated when the delta RT_{NDT} determined from the surveillance capsule is different from the calculated delta RT_{NDT} for the equivalent capsule radiation exposure.

The pressure-temperature limit lines shown on Figures 3.4-2 and ~~3.4-3~~ for reactor criticality and for inservice leak and hydrostatic testing have been provided to assure compliance with the minimum temperature requirements of Appendix G to 10 CFR 50.

REACTOR COOLANT SYSTEM

BASES

PRESSURE/TEMPERATURE LIMITS (Continued)

The maximum RT_{NDT} for all Reactor Coolant System pressure-retaining materials, with the exception of the reactor pressure vessel, has been determined to be 90°F. The Lowest Service Temperature limit line shown on Figures 3.4-2, 3.4-4, and 3.4-36 is based upon this RT_{NDT} since Article NB-2332 (Summer Addenda of 1972) of Section III of the ASME Boiler and Pressure Vessel Code requires the Lowest Service Temperature to be $RT_{NDT} + 100^\circ\text{F}$ for piping, pumps and valves. Below this temperature, the system pressure must be limited to a maximum of 20% of the system's hydrostatic test pressure of 3125 psia.

The limitations imposed on the pressurizer heatup and cooldown rates and spray water temperature differential are provided to assure that the pressurizer is operated within the design criteria assumed for the fatigue analysis performed in accordance with the ASME Code requirements.

The Low Temperature Overpressure Protection (LTOP) enable temperatures are based upon the recommendations of NUREG-0800 Branch Technical Position (BTP) RSB 5-2, Revision 1, "Overpressurization Protection of Pressurized Water Reactors While Operating at Low Temperatures." BTP RSB 5-2, Revision 1 defines the enable temperature as "the water temperature corresponding to a metal temperature of at least $RT_{NDT} + 90^\circ\text{F}$ at the beltline location (1/4t or 3/4t) that is controlling in the Appendix G limit calculations."

TABLE B 3/4.4-1
REACTOR VESSEL TOUGHNESS

Piece No.	Code No.	Material	Vessel Location	Drop Weight Results	Temperature of Charpy V-Notch @ 30 @ 50 ft - lb - ft - lb		Minimum Upper Shelf Cv energy for Longitudinal Direction-ft lb
215-01	C-6801-1	A533GRBCL1	Upper Shell Plate	-20	28	64	115
215-01	C-6801-2	A533GRBCL1	Upper Shell Plate	-20	-6	34	106
215-01	C-6801-3	A533GRBCL1	Upper Shell Plate	-20	18	36	115
215-02	C-6802-4	A533GRBCL1	Lower Shell Plate	-30	3240	6270	1158
215-02	C-6802-5	A533GRBCL1	Lower Shell Plate	0	3640	6470	1106
215-02	C-6802-6	A533GRBCL1	Lower Shell Plate	-40	3240	10080	9092
215-03	C-6802-1	A533GRBCL1	Intermediate Shell	-2010	56110	100135	9594
215-03	C-6802-2	A533GRBCL1	Intermediate Shell	-20	40	6670	1135
215-03	C-6802-3	A533GRBCL1	Intermediate Shell	-10	4460	80	1045
203-02	C-6823	A508CL2	Vessel Flange Forging	0	-30	-15	NA
209-02	C-6824-1	A508CL2	Closure Head Flange Forging	-40	-100	-100	NA
205-02	C-6829-1	A508CL2	Inlet Nozzle Forging	10	-35	-5	109
205-02	C-6829-2	A508CL2	Inlet Nozzle Forging	0	-55	-35	156
205-02	C-6829-3	A508CL2	Inlet Nozzle Forging	10	-25	35	112
205-02	C-6829-4	A508CL2	Inlet Nozzle Forging	10	-30	25	108
205-06	C-6830-1	A508CL2	Outlet Nozzle Forging	-10	-30	-15	125
205-06	C-6830-2	A508CL2	Outlet Nozzle Forging	-10	-23	-5	131
232-01	C-6840-1	A533GRBCL1	Bottom Head Torus	-50	-13	0	107
232-02	C-6841-1	A533GRBCL1	Bottom Head Dome	-40	10	20	99

ENCLOSURE 2

CHANGES TO TS 3.4.8.3.1 PAGES WHICH WERE PREVIOUSLY REQUESTED IN
AMENDMENT APPLICATION NO. 97 (PCN-358) DATED DECEMBER 20, 1991
AND ARE BEING REQUESTED IN PCN-359

SAN ONOFRE UNIT 3

REACTOR COOLANT SYSTEM

OVERPRESSURE PROTECTION SYSTEMS

RCS TEMPERATURE ≤ 302 265°F

PCN
359

LIMITING CONDITION FOR OPERATION

3.4.8.3.1 No more than two high-pressure safety injection pumps shall be OPERABLE and at least one of the following overpressure protection systems shall be OPERABLE:

PCN
358

- a. The Shutdown Cooling System Relief Valve (PSV9349) with:
 - 1) A lift setting of 406 ± 10 psig*, and
 - 2) Relief valve isolation valves 3HV9337, 3HV9339, 3HV9377, and 3HV9378 open ~~or~~,
- or,
- b. The Reactor Coolant System depressurized with an RCS vent of greater than or equal to 5.6 square inches.

PCN
358

APPLICABILITY: MODE 4 when the temperature of any one RCS cold leg is less than or equal to that the enable temperatures specified in Table 3.4-3; MODE 5; and MODE 6 with when the reactor vessel head is on the reactor vessel and the RCS is not vented.

PCN
358

ACTION:

- a. With the SDCS Relief Valve inoperable, reduce T_{avg} to less than 200°F, depressurize and vent the RCS through a greater than or equal to 5.6 square inch vent within the next 8 hours.
- b. With one or both SDCS Relief Valve isolation valves in a single SDCS Relief Valve isolation valve pair (valve pair 3HV9337 and 3HV9339 or valve pair 3HV9377 and 3HV9378) closed, open the closed valve(s) or power-lock open the other SDCS Relief Valve isolation valve pair within ~~7 days~~ 24 hours, or reduce T_{avg} to less than 200°F, depressurize and vent the RCS through a greater than or equal to 5.6 inch vent within the next 8 hours.
- c. With more than two high-pressure safety injection pumps OPERABLE, secure the third high-pressure safety injection pump by racking out its motor circuit breaker or locking close its discharge valve within 8 hours.

PCN
358

PCN
358

* The lift setting pressure applicable to valve temperatures of less than or equal to 130°F.