

ATTACHMENT 2
PROPOSED TECHNICAL SPECIFICATION 4.3.4

TSC\J2-083 001

9209300222 720526
PDR ADOCK 0507049E
F PDR

INSTRUMENTATION

ATTACHMENT 2
ST-HL-AE-4050
PAGE 1 OF 1

3/4.3.4 TURBINE OVERSPEED PROTECTIONLIMITING CONDITION FOR OPERATION

3.3.4 At least one Turbine Overspeed Protection System shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With one stop valve or one governor valve per high pressure turbine steam line inoperable and/or with one reheat stop valve or one reheat intercept valve per low pressure turbine steam line inoperable, restore the inoperable valve(s) to OPERABLE status within 72 hours, or close at least one valve in the affected steam line(s) or isolate the turbine from the steam supply within the next 6 hours.
- b. With the above required Turbine Overspeed Protection System otherwise inoperable, within 6 hours isolate the turbine from the steam supply.

SURVEILLANCE REQUIREMENTS

4.3.4.1 The provisions of Specification 4.0.4 are not applicable.

4.3.4.2 The above required Turbine Overspeed Protection System shall be demonstrated OPERABLE:

- a. At least once per 31 days in MODES 1 and 2 when the main turbine is operating by cycling each of the following valves through at least one complete cycle from the running position:
 - 1) Four high pressure turbine stop valves,
 - 2) Four high pressure turbine governor valves,
 - 3) Six low pressure turbine reheat stop valves, and
 - 4) Six low pressure turbine reheat intercept valves.
- b. At least once per 31 days in MODES 1 and 2 when the main turbine is operating by direct observation of the movement of each of the above valves through one complete cycle from the running position,
- c. At least once per 18 months by performance of a CHANNEL CALIBRATION on the Turbine Overspeed Protection Systems, and
- d. At least once per 40 months by disassembling at least one of each of the above valves and performing a visual and surface inspection of valve seats, disks, and stems and verifying no unacceptable flaws or excessive corrosion. If unacceptable flaws or excessive corrosion are found, all other valves of that type shall be inspected.*

*Disassembly and inspection of the low pressure turbine reheat intercept valves are not required prior to the end of the first 40 month interval.

SOUTH TEXAS - UNITS 1 & 2

3/4 3-89

Unit 1 valves will be disassembled and inspected at the Unit 1 fifth refueling outage, following a one-time extension of the inspection interval from 40 months (50 months with the 25% grace period) to approximately 52 months.