



South Carolina Electric & Gas Company  
P.O. Box 88  
Jenkinsville, SC 29065  
(803) 345-4040

John L. Skoids  
Vice President  
Nuclear Operations

September 23, 1992

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION (VCSNS)  
DOCKET NO. 50/395  
OPERATING LICENSE NO. NPF-12  
TECHNICAL SPECIFICATIONS CHANGE REQUEST  
REMOVAL OF TABLE 3.6-1 PER GENERIC LETTER 91-08 (TSP 920003-0)

In accordance with 10CFR50.90, South Carolina Electric & Gas Company (SCE&G) is submitting an amendment request to License NPF-12 to change the Technical Specifications (TS) for VCSNS. The proposed amendment is to remove Table 3.6-1, Containment Isolation Valves, per the guidance provided in Generic Letter 91-08. The request is contained in the following attachments:

- Attachment 1 The Technical Specification pages as proposed by this amendment request.
- Attachment 2 Description of Amendment Request and Safety Evaluation.
- Attachment 3 Description of Amendment Request and No Significant Hazards Determination.

SCE&G enters its 7th refueling outage in March 1993. A modification is scheduled for this outage to install a new containment isolation valve downstream of the reactor coolant drain tank level control valve (currently the inboard CIV). In order to facilitate this modification, SCE&G requests that the review of this amendment be processed by January 4, 1993. If approved, SCE&G also requests that the amendment be issued with an allowed implementation date of not earlier than March 1, 1993.

These changes have been reviewed and approved by the Plant Safety Review Committee and the Nuclear Safety Review Committee.

I declare that the statements and matters set forth herein are true and correct to the best of my knowledge, information, and belief.

28-000


9210010034 920923  
PDR ADOCK 05000395  
P PDR

A001  
111

Document Control Desk  
TSP 920003  
Page 2 of 2

Should you have any questions concerning this issue, please call Mr. David C. Haile at (803) 345-4322 at your convenience.

Very truly yours,



John L. Skolds

DCH:lcd  
Attachments

cc: O. W. Dixon  
R. R. Mahan  
R. J. White  
S. D. Ebnetter  
G. F. Wunder  
General Managers  
NRC Resident Inspector  
J. B. Knotts Jr.  
H. G. Shealy  
RTS (TSP 920003)  
File (813.20)