



Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

August 14, 1984

Mr. James G. Keppler
Regional Administrator
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Subject: LaSalle County Station Unit 2
Supplement to Response for
Inspection Report 50-374/84-23
NRC Docket No. 50-374

References (a): C. E. Norelius letter to Cordell
Reed dated July 13, 1984.


(b): D. L. Farrar letter to J. G.
Keppler dated July 31, 1984.

Dear Mr. Keppler:

This letter provides additional information requested by Mr. M. J. Jordan of your staff and supplements the Commonwealth Edison Company response to Inspection Report No. 50-374/84-23 (Reference (b)).

If you have any further questions regarding this matter, please direct them to this office.

Very truly yours,


D. L. Farrar,
Director of Nuclear Licensing

lm

cc: Resident Inspector - LSCS

Attachment

9074N

8410230440 841013
PDR ADOCK 05000374
Q PDR

AUG 17 1984

ATTACHMENT

Commonwealth Edison Company

LaSalle Unit 2

Supplemental Response to Notice of Violation

ITEM FOR WHICH CLARIFICATION WAS REQUESTED

During the enforcement conference, we discussed our concerns regarding the system for managing surveillance tests. Specifically, the controls over conducting testing on both electrical divisions of one system and on more than one system simultaneously. In your response please describe changes in your system for managing surveillance testing to preclude recurrence of such violations.

ADDITIONAL CORRECTIVE ACTION TAKEN TO AVOID FURTHER NONCOMPLIANCE

Unless required by a pending due or critical date surveillance or another specific reason simultaneous performance of two (2) or more procedures on the same system or more than one (1) system will not be permitted. When two (2) or more procedures must be conducted simultaneously the Shift Engineer will discuss the precautions and limitations with the shift control room engineer and the unit nuclear station operator. Upon concurrence between these individuals the procedures can be performed.

DATE WHEN FULL COMPLIANCE WILL BE ACHIEVED

This item will be completed by August 31, 1984.