

REACTIVITY CONTROL SYSTEMS

MODERATOR TEMPERATURE COEFFICIENT

LIMITING CONDITION FOR OPERATION

3.1.1.4 The moderator temperature coefficient (MTC) shall be:

- a. For the all rods withdrawn, beginning of core life condition
 $\leq 0.6 \times 10^{-4} \Delta k/k/^{\circ}F$ below 70 percent RATED THERMAL POWER
 $\leq 0.0 \times 10^{-4} \Delta k/k/^{\circ}F$ at or above 70 percent RATED THERMAL POWER
- b. Less negative than $-4.0 \times 10^{-4} \Delta k/k/^{\circ}F$ for the all rods withdrawn, end of core life at RATED THERMAL POWER.

APPLICABILITY: Specification 3.1.1.4.a - MODES 1 and 2* only#
Specification 3.1.1.4.b - MODES 1, 2 and 3 only#

ACTION:

- a. With the MTC more positive than the limit of 3.1.1.4.a above:
 1. Establish and maintain control rod withdrawal limits sufficient to restore the MTC to within its limit within 24 hours or be in HOT STANDBY within the next 6 hours. These withdrawal limits shall be in addition to the insertion limits of Specification 3.1.3.6.
 2. Maintain the control rods within the withdrawal limits established above until subsequent measurement verifies that the MTC has been restored to within its limit for the all rods withdrawn condition.
 3. Prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 10 days, describing the value of the measured MTC, the interim control rod withdrawal limits and the predicted average core burnup necessary for restoring the positive MTC to within its limit for the all rods withdrawn condition.
- b. With the MTC more negative than the limit of 3.1.1.4.b above, be in HOT SHUTDOWN within 12 hours.

*With $K_{eff} \geq 1.0$

#See Special Test Exception 3.10.3

8502120285 850207
PDR ADOCK 05000338
P PDR

REACTIVITY CONTROL SYSTEMS

MODERATOR TEMPERATURE COEFFICIENT

LIMITING CONDITION FOR OPERATION

3.1.1.4 The moderator temperature coefficient (MTC) shall be:

- a. For the all rods withdrawn, beginning of core life condition
 $\leq 0.6 \times 10^{-4} \Delta k/k/^{\circ}F$ below 70 percent RATED THERMAL POWER
 $\leq 0.0 \times 10^{-4} \Delta k/k/^{\circ}F$ at or above 70 percent RATED THERMAL POWER
- b. Less negative than $-4.0 \times 10^{-4} \Delta k/k/^{\circ}F$ for the all rods withdrawn, end of core life at RATED THERMAL POWER.

APPLICABILITY: Specification 3.1.1.4.a - MODES 1 and 2* only#
Specification 3.1.1.4.b - MODES 1, 2 and 3 only#

ACTION:

- a. With the MTC more positive than the limit of 3.1.1.4.a above:
 1. Establish and maintain control rod withdrawal limits sufficient to restore the MTC to within its limit within 24 hours or be in HOT STANDBY within the next 6 hours. These withdrawal limits shall be in addition to the insertion limits of Specification 3.1.3.6.
 2. Maintain the control rods within the withdrawal limits established above until subsequent measurement verifies that the MTC has been restored to within its limit for the all rods withdrawn condition.
 3. Prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 10 days, describing the value of the measured MTC, the interim control rod withdrawal limits and the predicted average core burnup necessary for restoring the positive MTC to within its limit for the all rods withdrawn condition.
- b. With the MTC more negative than the limit of 3.1.1.4.b above, be in HOT SHUTDOWN within 12 hours.

*With $K_{eff} \geq 1.0$

#See Special Test Exception 3.10.3