



New York Power  
Authority

Ralph E. Beedle  
Executive Vice President  
Nuclear Generation

September 25, 1992  
JPN-92-057

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

SUBJECT: James A. FitzPatrick Nuclear Power Plant  
Docket No. 50-333  
Proposed Changes to the Technical Specifications to  
Reflect a Fire Protection Modification (JPTS-91-020)

REFERENCE: 1. NYPA letter, R.E. Beedle to U.S. NRC, dated  
August 16, 1991, (JPN-91-043), regarding schedule  
for short term fire protection actions.

Dear Sir,

This application for an amendment to the James A. FitzPatrick Technical Specifications adds operability and surveillance requirements to Tables 3.12.1 and 4.12.1 to reflect a plant modification that will improve fire protection at the Authority's FitzPatrick nuclear power plant. The modification installs an automatic fire suppression system in the battery room corridor. The Authority committed to install this modification prior to restart from the current refueling outage (Reference 1).

The signed original of the Application for Amendment to Operating License is enclosed for filing. Attachments I and II to this application contain the proposed changes to the Technical Specifications and the associated Safety Evaluation.

A copy of this application and the associated attachments are being provided to the designated New York State official in accordance with 10 CFR 50.91.

If you have any questions, please contact J. A. Gray, Jr.

Very truly yours,

Ralph E. Beedle

050035

9210060355 920925  
PDR ADDCK 05000333  
P PDR

AD06

att: as stated

cc: Regional Administrator  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Office of the Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 136  
Lycoming, NY 13093

Mr. Brian C. McCabe  
Project Directorate I-1  
Division of Reactor Projects - I/II  
U.S. Nuclear Regulatory Commission  
Mail Stop 14 B2  
Washington, DC 20555

Ms. Donna Ross  
New York State Energy Office  
2 Empire State Plaza  
16<sup>th</sup> Floor  
Albany, NY 12223