

## LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Kewaunee Nuclear Power Plant										DOCKET NUMBER (2) 0 5 0 0 0 3 0 5					PAGE 18 1 OF 0 2	
TITLE (4) Inadvertent Actuation of Train "B" Zone SV																
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)						
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES NA				DOCKET NUMBER(S) 0 5 0 0 0			
0 9	1 4	8 4	4 8	4	0 1 6	0 0	1 0	1 2	8 4					0 5 0 0 0		
OPERATING MODE (9) N		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5 (Check one or more of the following) (11)														
POWER LEVEL (10) 1 0 0		20 402(b)				20 406(c)				X 80 73(a)(2)(iv)				73.71(b)		
		20 406(a)(1)(i)				80 36(c)(1)				80 73(a)(2)(v)				73.71(c)		
		20 406(a)(1)(ii)				80 36(c)(2)				80 73(a)(2)(vi)				OTHER (Specify in Abstract below and in Text, NRC Form 366A)		
		20 406(a)(1)(iii)				80 73(a)(2)(i)				80 73(a)(2)(vii)(A)						
		20 406(a)(1)(iv)				80 73(a)(2)(ii)				80 73(a)(2)(vii)(B)						
		20 406(a)(1)(v)				80 73(a)(2)(iii)				80 73(a)(2)(viii)						
LICENSEE CONTACT FOR THIS LER (12)																
NAME Sherry Bernhoft - Technical Support Engineer										TELEPHONE NUMBER AREA CODE 4 1 4 3 8 8 - 2 5 6 0						
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE				SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC				
A																
SUPPLEMENTAL REPORT EXPECTED (14)																
YES (If yes, complete EXPECTED SUBMISSION DATE)										X NO		EXPECTED SUBMISSION DATE (15) NA		MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single space typewritten lines) (16)

On September 14, 1984, with the plant at 100% power operation, Train "B" of the Auxiliary Building Special Ventilation System (ABSV) was inadvertently started by an Instrument & Controls person performing a work request on RM-14, the Auxiliary Building Vent Radiation Monitor. Investigation of the work request led him to believe that there was a loose connection in the control room instrument drawer. In order to examine the connection, he pulled the control and power cable out of the instrument drawer. This action, unknown to him at the time, generated a trip signal on the radiation monitor which automatically started Train "B" of the ABSV system. The control room operators, after verifying the cause of the start, secured the system and realigned it for normal operation.

A copy of this event has been routed to the different work groups in the plant to stress the importance of proper communications before work is performed.

The ventilation system performed as designed, and this event resulted in no impact on the health and safety of the public.

8410240475 841012  
PDR ADOCK 05000305  
S PDRIE22  
11

## LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104

EXPIRES 8/31/85

FACILITY NAME (1)  Kewaunee Nuclear Power Plant	DOCKET NUMBER (2)  0 5 0 0 0 3 0 5	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		8 4	- 0 1 6	- 0 0	0 2	OF 0 2

TEXT (If more space is required, use additional NRC Form 365A's) (17)

On September 14, 1984, with the plant at 100% power operation, Train "B" of the Auxiliary Building Special Vent System (VJ) was inadvertently started by an I&C person performing a work request on RM-14, the Auxiliary Building Vent Radiation Monitor (MON). Investigation of the work request led him to believe that there was a loose connection (CON) in the control room instrument drawer (CAB). In order to examine the connection he pulled the control and power cable (CBL) out of the instrument drawer. This action, unknown to him at the time, generated a trip signal in the radiation monitor which automatically started Train "B" of the ABSV system. The control room operators, after verifying the cause of the start, secured the system and realigned it for normal operation.

The ABSV system is designed to collect any potential containment vessel (VSL) leakage which might bypass the Shield Building Annulus (VC) and cause it to pass through charcoal filters (FLT) before reaching the environment. It also provides emergency ventilation in certain zones of the Auxiliary Building. The system will automatically start on a safety injection signal, high radiation signal from the Auxiliary Building vent radiation monitors and a steam exclusion signal. There are two redundant trains to the system; radiation monitor RM-13 provides a signal to Train "A" and RM-14 actuates Train "B".

The loose connection is a ribbon type connector which is secured in place by small fingers. Over time these fingers have broken off allowing the connector to vibrate loose. The same connector is used for other radiation monitors in the plant and is exhibiting the same failure mode. Past attempts to locate spare parts have been unsuccessful. Following this incident the Westinghouse Site Services Manager was contacted to assist in locating spare parts. If this attempt is unsuccessful, a design change will be initiated to purchase and install replacement connectors.

The person involved was made aware of his error. A copy of the incident report has been routed to the different work groups in the plant to stress the importance of proper communications before work is started.

The ventilation system performed as designed, and this event resulted in no impact on the health and safety of the public.

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

October 12, 1984

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Docket 50-305  
Operating License DPR-43  
Kewaunee Nuclear Power Plant  
Reportable Occurrence 84-016-00

In accordance with the requirements of 10 CFR 50.73 "Licensee Event Report System", the attached Licensee Event Report for reportable occurrence 84-016-00 is being submitted.

Very truly yours,

A handwritten signature in dark ink, appearing to read "D. C. Hintz".

D. C. Hintz  
Manager - Nuclear Power

JGT/js

Attach.

cc - INPO Records Center  
Suite 1500, 1100 Circle 75 Parkway  
Atlanta, GA 30339  
Mr. Robert Nelson, NRC Resident Inspector  
RR #1, Box 999, Kewaunee, WI 54216  
Mr. S. A. Varga, Chief  
US NRC, Washington, DC 20555  
Mr. J. G. Keppler, Regional Administrator  
Region III, US NRC, 799 Roosevelt Road  
Glen Ellyn, IL 60137

IE 22  
11