

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

Log # TXX-4412
File # 906.3
905.4 c10

JOHN W. BECK
MANAGER-LICENSING

February 7, 1985

Director of Nuclear Reactor Regulation
Attention: Mr. B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
ADDITIONAL INSPECTION OF CPSES SAFETY
INJECTION PUMPS

Dear Mr. Youngblood:

By letter dated December 3, 1984, the NRC requested formal notification of TUGCO's intent to comply with the staff's position for additional inspection of the multi-vane diffuser shroud in CPSES Safety Injection Pumps.

TUGCO has incorporated the NRC Staff's position as follows:

1. Revision 2 to TUGCO maintenance procedure MMI-307, "Safety Injection Pump Inspection" provides for both visual and surface examinations of the diffuser shroud to be performed in conjunction with the 9th refueling outage inspection of pump internals.
2. A section has been added to the ISI 10-Year Plan addressing the examinations described above for the safety injection pumps.

Should you have additional questions in this matter, please contact this office.

Sincerely,

John W. Beck
John W. Beck

BSD/grr

Distribution: Original plus 15 copies

c - J. Stefano

8502130268 850267
PDR ADOCK 05000445
G PDR

Boo1
1/0