

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER * 400 NORTH OLIVE STREET, L.B. 81 * DALLAS, TEXAS 75201

BILLY R. CLEMENTS
VICE PRESIDENT, NUCLEAR OPERATIONS

October 12, 1984
TXX-4333

Mr. D.R. Hunter, Chief
Reactor Project Branch 2
U.S. Nuclear Regulatory Commission
Office of Inspection & Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76012


Docket No.: 50-445
50-446

COMANCHE PEAK STEAM ELECTRIC STATION
VENTILATION EXHAUST DAMPERS
QA FILE: CP-84-27, SDAR-152
FILE NO.: 10110

Dear Mr. Hunter:

On September 13, 1984 we verbally notified your Mr. D. Hunnicutt of a deficiency regarding ventilation exhaust dampers that have been observed to be designed/installed to fail closed which would divert radioactive releases to rooms in which reactor action is required.

We are continuing our evaluation and anticipate completion by November 20, 1984.



Very truly yours,

Billy R. Clements

BRC:tlg

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8410300039 841012
PDR ADDCK 05000445
S PDR

1/0
IE-27