



Log # TXX-96090
File # 916 (3/4.9)
10010
Ref. # 10CFR50.90
10CFR50.36

C. Lance Terry
Group Vice President

March 13, 1996

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES) - UNITS 1 AND 2
DOCKET NOS. 50-445 AND 50-446
SUPPLEMENT TO LICENSE AMENDMENT REQUEST (LAR) 95-007
REGARDING REMOVAL OF REQUIREMENT TO MAINTAIN
ONE PERSONNEL AIRLOCK DOOR CLOSED DURING REFUELING

REF: TU Electric letter logged TXX-95289 from C. L. Terry to the NRC
dated November 21, 1995.

Gentlemen:

During a phone conversation between Mr. T. Polich of NRR and Mr. Roger D. Walker of TU Electric on March 13, 1996, NRR requested that TU Electric place the proposed administrative controls for LAR 95-007, submitted in letter logged TXX-96062 on February 22, 1996, into Technical Specification 3.9.4. TU Electric has evaluated the requested change and has concluded that placing the administrative controls in the Technical Specifications does not alter the intent by which TU Electric plans to implement the proposed change. Thus, placing the proposed administrative controls into Technical Specification 3.9.4 has no net impact on CPSES operations. Therefore, in order to obtain approval of this LAR, TU Electric agrees to include the additional administrative controls in the Technical Specifications.

TU Electric hereby supplements the License Amendment Request LAR-95-007 to the CPSES Unit 1 Operating License (NPF-87) and CPSES Unit 2 Operating License (NPF-89) by incorporating the attached changes into the CPSES Units 1 and 2 Technical Specifications. License Amendment Request 95-007 revises the Technical Specification Limiting Condition for Operation (LCO) 3.9.4 to allow both doors of the personnel airlock (PAL) to remain open as long as one PAL door is capable of being closed. This supplement specifies that appropriate individuals be aware of the open status of the personnel airlock doors, that a designated individual or individuals be available (e.g. in the protected area, but not necessarily at the PAL) to ensure the airlock door is closed following a required containment evacuation (e.g., following a design basis fuel handling accident), and that there are no obstructions through the personnel airlock doors that could not be quickly removed (i.e., in approximately the same amount of time as it takes to evacuate containment) to allow closure of an airlock door.

9603190033 960313
PDR ADOCK 05000445
P PDR

DOZ

Attachment 1 is the required affidavit. This supplement is bounded by the safety analysis of LAR 95-007 (see referenced letter) and TU Electric's determination that the proposed changes do not involve a significant hazard consideration remains valid. Attachment 2 provides the affected Technical Specification pages marked-up to reflect the proposed changes of LAR-95-007 and the supplemental changes.

In accordance with 10CFR50.91(b), TU Electric is providing the State of Texas with a copy of this proposed amendment.

Should you have any questions, please contact Mr. Jimmy Seawright at (214) 812-4375 or Mr. Don Woodlan at (214) 812-8225.

Sincerely,

C. L. Terry
C. L. Terry

By: *Roger D. Walker*
Roger D. Walker
Regulatory Affairs Manager

JDS/grp
Attachments:

1. Affidavit
2. Affected Technical Specification pages as revised by LAR 95-007 and its supplements

c - Mr. L. J. Callan, Region IV
Mr. T. J. Polich, NRR
Mr. W. D. Johnson, Region IV
Resident Inspectors, CPSES

Mr. Arthur C. Tate
Bureau of Radiation Control
Texas Department of Public Health
1100 West 49th Street
Austin, Texas 78704

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)	
)	
Texas Utilities Electric Company)	Docket Nos. 50-445
)	50-446
(Comanche Peak Steam Electric)	License Nos. NPF-87
Station, Units 1 & 2))	NPF-89

AFFIDAVIT

Roger D. Walker being duly sworn, hereby deposes and says that he is Regulatory Affairs Manager of TU Electric, that he is duly authorized to sign and file with the Nuclear Regulatory Commission this supplement to License Amendment Request 95-007; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information and belief.

Roger D. Walker
Roger D. Walker
Regulatory Affairs Manager

STATE OF TEXAS)

COUNTY OF *Johnson*)

Subscribed and sworn to before me, a Notary Public, on this 13th day of March, 1996.



Carolyn L. Cosentino
Notary Public

ATTACHMENT 2 TO TXX-96090
AFFECTED TECHNICAL SPECIFICATION PAGES