



300 Madison Avenue  
Toledo, OH 43652-0001  
419-249-2300

John P. Stetz  
Vice President - Nuclear  
Davis-Besse

Docket Number 50-346

License Number NPF-3

Serial Number 2365

March 5, 1996

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Subject: Request for Relief From Certain ASME Code Requirements for  
Inservice Inspection for the Davis-Besse Nuclear Power

Gentlemen:

By letter dated August 14, 1995 (Serial Number 2302), Toledo Edison submitted Relief Request RR-A11 for Nuclear Regulatory Commission (NRC) approval pursuant to 10CFR50.55a(g)(5)(iii). Relief was requested from ASME Code examination coverage requirements for five Pressurizer Nozzle to Head welds and six Steam Generator Nozzle to Head Welds and their associated Inside Radius Sections subject to subsection IWB, Table IWB-2500-1, Examination Category B-D, Item Numbers B3.120 and B3.140. Additional information to support this relief request was submitted by letter dated January 26, 1996 (Serial Number 2352). Upon further discussion with the NRC Toledo Edison has elected to withdraw the portion of Relief Request RR-A11 related to the Inside Radius Section Examinations.

Should you have any questions or require additional information, please contact Mr. James L. Freels, Manager - Regulatory Affairs, at (419) 321-8466.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'John P. Stetz'.

NKP/eld

180163

cc: L. L. Gundrum, NRC Project Manager  
H. J. Miller, Regional Administrator, NRC Region III  
S. Stasek, DB-1 NRC Senior Resident Inspector  
Utility Radiological Safety Board

9603190107 960305  
PDR ADOCK 05000346  
P PDR

Operating Companies  
Cleveland Electric Illuminating  
Toledo Edison

Handwritten initials or a signature in the bottom right corner of the page, possibly reading 'A. H. 1/0'.