

Nebraska Public Power District

COOPER NUCLEAR STATION
P.O. BOX 98, BROWNVILLE, NEBRASKA 68321
TELEPHONE (402)825-3811
FAX (402)825-5205

NLS960047

March 15, 1996

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555


Subject: Monthly Operating Status Report for February 1996, Docket No.
50-298.

Gentlemen:

Enclosed for your information and use is the Cooper Nuclear Station
Monthly Operating Status Report for February 1996. The report includes
Operating Status, Average Daily Unit Power Level, Unit Shutdown Data and
a Narrative Summary of Operating Experience for the month of February.

Should you have any comments, or require additional information
regarding this report, please contact me.

Sincerely,



J. T. Herron
Plant Manager

JTH:PLB:tlb

Enclosures

cc: ANI Library
R. W. Beck and Associates
T. H. Black
T. L. Bundy
L. J. Callan
J. M. Cline
A. L. Dostal
R. L. Gumm
G. R. Horn
INPO Records Center
E. A. Lanning
J. L. Long
W. R. Mayben
J. R. McPhail
J. H. Mueller
NRC Senior Resident Inspector
R. J. Singer
F. E. Yost

9603190383 960229
PDR ADOCK 05000298
R PDR

190052

IF24
11

OPERATING DATA REPORT

DOCKET NO. 050-0298
UNIT CNS
DATE March 15, 1996
TELEPHONE (402) 825-5295

OPERATING STATUS

1. Unit Name: Cooper Nuclear Station Notes
2. Reporting Period: February 1996
3. Licensed Thermal Power (MWt): 2381
4. Nameplate Rating (Gross MWe): 836
5. Design Electrical Rating (Net MWe): 778
6. Maximum Dependable Capacity (Gross MWe): 787
7. Maximum Dependable Capacity (Net MWe): 764
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reasons For Restriction, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours in Reporting Period	696.0	1,440.0	189,937.0
12. Number of Hours Reactor Was Critical	696.0	1,440.0	140,481.4
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	696.0	1,424.1	138,368.0
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1,651,824.0	3,199,008.0	287,525,436.0
17. Gross Electric Energy Generated (MWH)	550,010.0	1,060,908.0	93,441,218.0
18. Net Electric Energy Generated (MWH)	533,452.0	1,027,770.0	90,253,899.0
19. Unit Service Factor	100.0	98.9	72.8
20. Unit Availability Factor	100.0	98.9	72.8
21. Unit Capacity Factor (Using MDC Net)	100.3	93.4	62.2
22. Unit Capacity Factor (Using DER Net)	98.5	91.7	61.1
23. Unit Forced Outage Rate	0.0	0.0	8.4

24. Shutdown Scheduled Over Next 6 Months (Time, Date, and Duration of Each): None
25. If Shut Down At End of Report Period, Estimated Date of Startup: N/A
26. Units In Test Status (Prior to Commercial Operation):
- | | | |
|----------------------|----------|----------|
| INITIAL CRITICALITY | Forecast | Achieved |
| INITIAL ELECTRICITY | _____ | _____ |
| COMMERCIAL OPERATION | _____ | _____ |

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 050-0298
UNIT CNS
DATE March 15, 1996
TELEPHONE (402) 825-5295

MONTH February 1996

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

01	767		17	769
02	767		18	769
03	766		19	771
04	767		20	770
05	768		21	769
06	768		22	769
07	769		23	770
08	769		24	746
09	769		25	732
10	769		26	769
11	769		27	768
12	769		28	768
13	768		29	768
14	769			
15	769			
16	769			

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO.	050-0298
UNIT NAME	Cooper Nuclear Station
DATE	March 15, 1996
COMPLETED BY	P. L. Ballinger
TELEPHONE	(402) 825-5295

REPORT MONTH February 1996[illegible]

1 F: Forced
S: Scheduled

2 Reason:

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training & License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

3 Method:

- 1 - Manual
- 2 - Manual Scram
- 3 - Automatic Scram
- 4 - Continued
- 5 - Reduced Load
- 6 - Other

4 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5 Exhibit I - Same Source

OPERATIONS NARRATIVE COOPER NUCLEAR STATION

February 1996

The plant operated at steady state full power operations for the month of February. Normal monthly turbine testing was performed on February 24-25, 1996. A capacity factor of 100% was attained for the month of February.

The following table identifies those actions committed to by the District in this document. Any other actions discussed in the submittal represent intended or planned actions by the District. They are described to the NRC for the NRC's information and are not regulatory commitments. Please notify the Licensing Manager at Cooper Nuclear Station of any questions regarding this document or any associated regulatory commitments.

[illegible]