



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038-0236

Nuclear Business Unit

MAR 12 1996

LR-N96055

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

**RETRACTION OF A 50.72 FOUR HOUR REPORT
HOPE CREEK GENERATING STATION
DOCKET NO. 50-354**

On January 31, 1996, Public Service Electric and Gas Company (PSE&G) made a four hour report pursuant to the provisions of 10CFR50.72(b)(2)(iii). The report concerned an event where the Hope Creek Control Room Ventilation Radiation Monitoring Detectors were declared inoperable. They were declared inoperable because they did not meet the design specifications for the range of temperature and humidity to which they would be subjected.

On February 22, 1996, Engineering completed an evaluation that determined the Control Room Ventilation Radiation Monitoring Detectors would perform their intended design basis function. Since the Radiation Monitoring Detectors are operable, the associated four hour report was retracted on February 23, 1996.

Should you have any questions or comments regarding this submittal, please contact us.

Sincerely,

Mark E. Reddemann
General Manager -
Hope Creek Operations

180107

9603200094 960312
PDR ADOCK 05000354
S PDR

The power is in your hands.

IFR2
1/0

MAR 12 1996

C Mr. T. T. Martin, Administrator - Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. D. Jaffe, Licensing Project Manager - Hope Creek
U. S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

Mr. R. Summers (X24)
USNRC Senior Resident Inspector - Hope Creek

Mr. K. Tosch, Manager, IV
Bureau of Nuclear Engineering
33 Arctic Parkway
CN 415
Trenton, NJ 08625