



Westinghouse
Electric Corporation

Energy Systems

Box 355
Pittsburgh Pennsylvania 15230-0355

NSD-NRC-96-4685
DCP/NRC0492
Docket No.: STN-52-003

April 4, 1996

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

ATTENTION: T. R. QUAY

SUBJECT: AP600 LARGE BREAK LOCA PHENOMENA IDENTIFICATION AND
RANKING TABLE

Reference 1: WCAP-14171, WCOBRA/TRAC Applicability to AP600 Large-Break Loss-
of-Coolant Accident

Reference 2: Westinghouse Letter NTD-NRC-95-4442, "Response to RAI Concerning
WCAP-12945", dated April 24, 1995

Dear Mr. Quay:

The enclosed table provides the Phenomena Identification and Ranking Table (PIRT) for the AP600 Large Break Loss of Coolant Accident (LBLOCA). The PIRT was previously provided as part of References 1 and 2 and has been revised in response to discussions between Westinghouse and NRC during a March 15, 1996 meeting. This revised PIRT is provided at this time for NRC staff review and will be included in a revision to WCAP-14171, "WCOBRA/TRAC Applicability to AP600 LOCA" to be issued by July 31, 1996. This submittal closes the action item from the March 15, 1996 meeting.

110006

2733A

9604100269 960404
PDR ADOCK 05200003
A PDR


*E004 per S. Fridley
1/1*

NSD-NRC-96-4685
DCP/NRC0492

-2-

April 4, 1996

Please contact John C. Butler on (412) 374-5268 if you have any questions concerning this transmittal.



B. A. McIntyre, Manager
Advanced Plant Safety and Licensing

/nja

Enclosures
Attachment

cc: T. Kenyon, NRC (w/o Enclosures/Attachments)
W. Huffman, NRC (1E1, 1E2)
R. C. Jones, NRC (w/o Enclosures/Attachments)
G. D. McPherson, NRC (w/o Enclosures/Attachments)
F. Eltawila, NRC (w/o Enclosures/Attachments)
L. Lois, NRC (1E1)
P. Boehnert, ACRS (1E1)
N. J. Liparulo, Westinghouse (w/o Enclosures/Attachments)

TABLE 2-3

PIRT FOR LARGE BREAK PROCESSES
CURRENT PLANT'S VS. AP600

Process	BLD	BLD	BLD	RFL	RFL	RFL	RFD	RFD	RFD
	EXPERT	AP600	W3&4 LOOP	EXPERT	AP600	W3&4 LOOP	EXPERT	AP600	W3&4 LOOP
FUEL ROD									
Stored Energy	9	9	9		5	5			
Oxidation							8	5	7
Decay Heat					5	5	8	8	8
Reactivity - Void		6	6						
Reactivity - Boron								5	5
Gap Conductance		8	8				8		
CORE*									
DNB		8	8						
Post-CHF	7	8	8	8	8	8			
Rewet	8	7	6	7	5	5			
Reflood Heat Transfer							9	7	9
Nucleate Boiling									
1-Phase Vapor Natural Circ.									
3-D Flow		7	7				9	5	5
Void Generation/Dist.		7	7				9		
Entrainment/Deentrainment								6	8
Flow Reversal/Stagnation		8	8						
Radiation Heat Transfer									
Level								8	8
UPPER HEAD									
Initial Water Temperature		8	5						
Flow Path Area		8	5						
Blowdown Flow		8	5						
UPPER FLENUM									
Hot Assembly Location		7	7						
Entrainment/Deentrainment							9	6	6
Phase Separation								6	6
CCF Drain/Fallback									
2-Phase Convection									

*Core heat transfer includes the effects of spacer grids.

TABLE 2-3 (Continued)

PIRT FOR LARGE BREAK PROCESSES
CURRENT PLANTS VS. AP600

Process	BLD	BLD	BLD	RFL	RFL	RFL	RFD	RFD	RFD
	EXPERT	AP600	W3&4 LOOP	EXPERT	AP600	W3&4 LOOP	EXPERT	AP600	W3&4 LOOP
HOT LEG									
Entrainment/Deentrainment							9		
Flow Reversal		5	5						
Void Distribution									
2-Phase Convection									
PRESSURIZER									
Early Quench/Flow	7	5	5						
Critical Flow in SL									
Flashing									
ADS Interaction		N/A			N/A			N/A	
STEAM GENERATOR									
Steam Binding							9	7	7
Delta P, Form Losses									
PRHR		-			-			-	
PUMP									
2-Phase Performance	9	5	5						
Delta P, Form Losses		8	8		5	5	8	7	7
COLD LEG/ ACCUMULATOR									
Condensation				9	N/A	8		-	5
Non-Condensable Gases							9	5	5
Discharge					8	8		9	6
Flow Asymmetries		6	5						
HPI Mixing									
CMT Mixing/Interaction		-			N/A			N/A	
DOWNCOMER									
Entrainment/Deentrainment				8	8	8		6	7
Condensation				9	8	8			
Countercurrent, Siug, Noneq.					8	8			
Hot Wall (Vessel/Barrel)				5			7	7	7
Hot Wall (Radial Reflector)								5	
2-Phase Convection									

TABLE 2-3 (Continued)

PIRT FOR LARGE BREAK PROCESSES
CURRENT PLANTS VS. AP600

Process	BLD	BLD	BLD	RFL	RFL	RFL	RFD	RFD	RFD
	EXPERT	AP600	W3&4 LOOP	EXPERT	AP600	W3&4 LOOP	EXPERT	AP600	W3&4 LOOP
Saturated Nucleate Boiling									
3-D Effects		5	5	9	8	8			
Flashing									
Liquid Level Oscillations								7	7
Direct Vessel Injection - ACCUM	-				8		-	7	-
IRWST Mixing	-	N/A			N/A		-	N/A	-
CMT Mixing/Interaction	-	-			N/A		-	N/A	-
LOWER PLENUM									
Sweep Out				7	6	6			
Hot Wall							7	7	7
Multi-dimensional Effects									
BREAK									
Critical Flow	9	9	9	7	6	6			
Flashing									
Containment Pressure								6	8
ADS Flow	-	N/A	-	-	N/A		-	N/A	-
LOOP									
2-Phase Delta-P	7								
Oscillations				7			9		
Flow Split		8	8	7	5	5			