



GPU Nuclear Corporation  
Post Office Box 480  
Route 441 South  
Middletown, Pennsylvania 17057-0191  
717 944-7621  
TELEX 84-2386  
Writer's Direct Dial Number:  
5211-85-2026

February 14, 1985

Office of Nuclear Reactor Regulation  
Attn: J. F. Stolz, Chief  
Operating Reactor Branch No. 4  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555


Dear Mr. Stolz:

Three Mile Island Nuclear Station Unit 1 (TMI-1)  
Operating License No. DPR-50  
Docket No. 50-289  
Detailed Control Room Design Review (DCRDR)

This letter provides information requested by Mr. Ray Ramirez of your staff regarding the Detailed Control Room Design Review (DCRDR) performed at TMI-1. Supplement 1 to NUREG 0737 (Generic Letter 82-33) provides requirements for Control Room Design Reviews and references NUREG 0700 as final guidelines for conducting a DCRDR. As you are aware, in previous submittals regarding our DCRDR report and supplementary information, the bulk of our DCRDR was completed before the final issuance of NUREG 0700. The basis of the guidelines used in our DCRDR were referenced in our December 1980 report on the CRDR submitted during the ASLB hearings in January 1981 and are: MIL-STD-1472 B, Human Engineering Design Criteria for Military Systems, Equipment and Facilities (1974) and Van Cott and Kinkade Editions, Human Engineering Guide to Equipment Design (1972). Subsequent to our DCRDR we reviewed the guidelines provided in NUREG 0700 as compared to the TMI-1 guidelines and although there were some small differences between the MIL-STD-1472 B and NUREG 0700 criteria, in the judgement of the review team, the review we performed meets the intent of the NUREG 0700 Guidelines.

Sincerely,

8502200283 850214  
PDR ADOCK 05000289  
F PDR

  
H. D. Hukill  
Director, TMI-1

HDH/MRK/spb

cc: J. Van Vliet  
R. Ramirez

GPU Nuclear Corporation is a subsidiary of the General Public Utilities Corporation

A003  
1/0