

TABLE 3.7-1

MAXIMUM ALLOWABLE POWER RANGE NEUTRON FLUX HIGH SETPOINT WITH  
INOPERABLE STEAM LINE SAFETY VALVES DURING FOUR LOOP OPERATION

<u>MAXIMUM NUMBER OF INOPERABLE SAFETY VALVES ON ANY OPERATING STEAM GENERATOR</u>	<u>MAXIMUM ALLOWABLE POWER RANGE NEUTRON FLUX HIGH SETPOINT (PERCENT OF RATED THERMAL POWER)</u>
1	87
2	65
3	43