

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. One or more Section D.1 containment isolation valve(s) inoperable.	E.1 Secure the inoperable valve(s) in its ESFAS actuated position. <u>AND</u> E.2 Restore the inoperable valve(s) to OPERABLE status.	4 hours Prior to entering MODE 4 from MODE 5 if MODE 5 entered within 30 days, otherwise within 30 days
F. One or more Section D.2 containment isolation valve(s) inoperable.	F.1 Secure the inoperable valve(s) in its ESFAS actuated position. <u>AND</u> F.2 Restore the inoperable valve(s) to OPERABLE status.	4 hours Prior to entering MODE 4 from MODE 5.
G. Required Action and associated Completion Time not met.	G.1 Be in MODE 3. <u>AND</u> G.2 Be in MODE 5.	6 hours 36 hours

ATTACHMENT "B"

AMENDMENT NO. 116 APPROVED SPECIFICATIONS
UNIT 3

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. One or more Section D.1 containment isolation valve(s) inoperable.	<p>E.1 Secure the inoperable valve(s) in its ESFAS actuated position.</p> <p><u>AND</u></p> <p>E.2 Restore the inoperable valve(s) to OPERABLE status.</p>	<p>4 hours</p> <p>Prior to entering MODE 4 from MODE 5 if MODE 5 entered within 30 days, otherwise within 30 days</p>
F. One or more Section D.2 containment isolation valve(s) inoperable.	<p>F.1 Secure the inoperable valve(s) in its ESFAS actuated position.</p> <p><u>AND</u></p> <p>F.2 Restore the inoperable valve(s) to OPERABLE status.</p>	<p>4 hours</p> <p>Prior to entering MODE 4 from MODE 5.</p>
G. Required Action and associated Completion Time not met.	<p>G.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>G.2 Be in MODE 5.</p>	<p>6 hours</p> <p>36 hours</p>

ATTACHMENT "C"

PROPOSED SPECIFICATIONS
Unit 2

Containment Isolation Valves
3.6.3

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. One or more Section D.1 containment isolation valve(s) inoperable.	E.1 Secure the inoperable valve(s) in its ESFAS actuated position.	4 hours In accordance with the applicable LCO pertaining to the valve or system in which it is installed.
	<u>AND</u> E.2 Restore the inoperable valve(s) to OPERABLE status.	Prior to entering MODE 4 from MODE 5 if MODE 5 entered within 30 days, otherwise within 30 days
F. One or more Section D.2 containment isolation valve(s) inoperable.	F.1 Secure the inoperable valve(s) in its ESFAS actuated position.	4 hours In accordance with the applicable LCO pertaining to the valve or system in which it is installed.
	<u>AND</u> F.2 Restore the inoperable valve(s) to OPERABLE status.	Prior to entering MODE 4 from MODE 5.
G. Required Action and associated Completion Time not met.	G.1 Be in MODE 3.	6 hours
	<u>AND</u> G.2 Be in MODE 5.	36 hours

ATTACHMENT "D"

PROPOSED SPECIFICATIONS
Unit 3

Containment Isolation Valves
3.6.3

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. One or more Section D.1 containment isolation valve(s) inoperable.	E.1 Secure the inoperable valve(s) in its ESFAS actuated position.	4 hours In accordance with the applicable LCO pertaining to the valve or system in which it is installed.
	<u>AND</u> E.2 Restore the inoperable valve(s) to OPERABLE status.	Prior to entering MODE 4 from MODE 5 if MODE 5 entered within 30 days, otherwise within 30 days
F. One or more Section D.2 containment isolation valve(s) inoperable.	F.1 Secure the inoperable valve(s) in its ESFAS actuated position.	4 hours In accordance with the applicable LCO pertaining to the valve or system in which it is installed.
	<u>AND</u> F.2 Restore the inoperable valve(s) to OPERABLE status.	Prior to entering MODE 4 from MODE 5.
G. Required Action and associated Completion Time not met.	G.1 Be in MODE 3.	6 hours
	<u>AND</u> G.2 Be in MODE 5.	36 hours