

UNIT SHUTDOWN AND POWER REDUCTIONS  
Explanation Sheet

Docket No.: 50-339

Report Month February Unit Name: NA-2

Year: 1996 Date: March 5, 1996

Contact: J. A. Stall

\* No entries this month.

# NORTH ANNA POWER STATION

UNIT NO.: 2  
MONTH: February

## SUMMARY OF OPERATING EXPERIENCE

Page 1 of 1

Listed below in chronological sequence is a summary of operating experiences for this month which required load reductions or resulted in significant non-load related incidents.

<u>Date</u>	<u>Time</u>	<u>Data</u>
March 01, 1996	0000	Began month with unit stable at 100% power, 951 MWe.
March 22, 1996	1000	Commenced unit ramp down for Turbine Valve Freedom Test (TVFT).
	1035	Unit stabilized at 91% power, 880 MWe.
	1112	Completed TVFT. Commenced ramp to 100% power.
	1140	Unit stable at 100% power, 948 MWe.
March 31, 1996	2400	Ended month with unit stable at 100% power, 954 MWe.