

Log # TXX-4422  
File # 909.5  
10010 clo

**TEXAS UTILITIES GENERATING COMPANY**  
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

February 19, 1985

JOHN W. BECK  
MANAGER-LICENSING

Director of Nuclear Reactor Regulation  
Attention: Mr. B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION  
DOCKET NOS. 50-445 AND 50-446  
FIRE PROTECTION OPEN ITEMS

Dear Mr. Youngblood:

Enclosed are 15 copies of each of the following submittals concerning open items previously identified and discussed with the staff:

1. Engineering justification for non-standard placement of automatic sprinklers in certain fire areas (identified during the on-site fire protection review).
2. Deviation 2g-1 - Partial sprinkler coverage in Fire Area AA, Zone 21C (identified during the on-site fire protection review).
3. Deviation 4e - Use of valves downstream of the Main Steam Isolation Valves (MSIV's) in the event of the loss of the MSIV's during a fire (identified during Appendix "R" audit).
4. Deviation 5b - Partial suppression in Valve Isolation Tank Room, Fire Area SB2c (identified during on-site fire protection review).
5. Deviations 6c and 6c-1 - Turbine Building slab not three hour rated construction (identified to the staff subsequent to Appendix "R" audit).

Should you have any questions concerning these submittals please contact this office.

8502250496 850219  
PDR ADOCK 05000445  
F PDR

Respectfully,

*John W. Beck*  
John W. Beck

BSD/grr  
Enclosures

Distribution: Original + 15 copies

c - J. J. Stefano

A DIVISION OF TEXAS UTILITIES ELECTRIC COMPANY

B002  
1/15

TEXAS UTILITIES GENERATING COMPANY  
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

Log # TXX-4422  
File # 909.5  
10010 clo

February 19, 1985

JOHN W. BECK  
MANAGER-LICENSING

Director of Nuclear Reactor Regulation  
Attention: Mr. B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION  
DOCKET NOS. 50-445 AND 50-446  
FIRE PROTECTION OPEN ITEMS

Dear Mr. Youngblood:

Enclosed are 15 copies of each of the following submittals concerning open items previously identified and discussed with the staff:

1. Engineering justification for non-standard placement of automatic sprinklers in certain fire areas (identified during the on-site fire protection review).
2. Deviation 2g-1 - Partial sprinkler coverage in Fire Area AA, Zone 21C (identified during the on-site fire protection review).
3. Deviation 4e - Use of valves downstream of the Main Steam Isolation Valves (MSIV's) in the event of the loss of the MSIV's during a fire (identified during Appendix "R" audit).
4. Deviation 5b - Partial suppression in Valve Isolation Tank Room, Fire Area SB2c (identified during on-site fire protection review).
5. Deviations 6c and 6c-1 - Turbine Building slab not three hour rated construction (identified to the staff subsequent to Appendix "R" audit).

Should you have any questions concerning these submittals please contact this office.

Respectfully,

*John W. Beck*  
John W. Beck

BSD/grr  
Enclosures

Distribution: Original + 15 copies

c - J. J. Stefano