

In the Matter of the Facility Operating License)  
of ) Docket No. 50-267  
PUBLIC SERVICE COMPANY OF COLORADO )

OF THE  
PUBLIC SERVICE COMPANY OF COLORADO  
FOR THE  
FORT ST. VRAIN NUCLEAR GENERATING STATION

Respectfully submitted,  
PUBLIC SERVICE COMPANY OF COLORADO  
By O. R. Lee, Vice President

KELLY, STANSFIELD & O'DONNELL  
Bryant O'Donnell  
Robert E. Thompson  
Public Service Company Building  
Denver, Colorado 80202

Attorneys for Applicant

8502250725 850206  
FDR ADOCK 05000267  
P PDR

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In The Matter

Public Service Company of Colorado  
Fort St. Vrain Unit No. 1

)  
)  
) Docket No. 50-267  
)

AFFIDAVIT

O. R. Lee, being duly sworn, hereby desposes and says that he is Vice President of Electric Production of Public Service Company of Colorado, the Licensee herein; that he has read the foregoing Application for Amendment to Appendix A of Facility Operating License, and knows the contents thereof, and that the statements and matters set forth therein are true and correct to the best of his knowledge, information, and belief.

*OR Lee*

O. R. Lee  
Vice President

STATE OF Colorado

COUNTY OF Boulder

Subscribed and sworn to before me, a Notary Public on this  
14th day of February, 1985.

*Shirley C. Mitchell*  
Notary Public

My commission expires 8/17, 1988.

ATTACHMENT 1

SUMMARY OF PROPOSED CHANGES

SUMMARY OF PROPOSED  
CHANGES

- |             |   |
|-------------|---|
| LCO 4.6.1   | 1.) Deleted.  |
| LCO 4.6.1.1 | 1.) Describes minimum electrical system requirements for power operation.   |
| LCO 4.6.1.2 | 1.) Describes minimum electrical system requirements for low power, shutdown and reference conditions.  |
| SR 5.6.1    | <ul style="list-style-type: none"><li>1.) Clarified normal starting conditions and start signal.</li><li>2.) Deleted requirement to check the day tank for accumulated water after a run of 2 hours or more.</li><li>3.) Increased minimum load time from 60 to 90 seconds.</li><li>4.) Added requirement for the water-jacket heaters on the diesel engines to be operable.</li><li>5.) Expanded Table 5.6.1-1 to be more similar to the Standard Technical Specification (STS).</li><li>6.) Added Table 5.6.1-2 on diesel generator reliability for completeness.</li><li>7.) Described the diesel engine protective functions in detail.</li></ul> |
| SR 5.6.2.   | <ul style="list-style-type: none"><li>1.) Deleted requirement on battery charger supplying the name plate rating for eight hours.</li><li>2.) Changed "partial discharge test"... to "service discharge test"...</li><li>3.) Added requirement to run performance discharge tests once per 60 months, including acceptance criteria.</li><li>4.) Adjusted rows in TABLE 5.6.2-1 to make it more easily read.</li></ul>  |