

VOGTLE ELECTRIC GENERATING PLANT  
GEORGIA POWER COMPANY

AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

Prepared

by

Bechtel Power Corporation, Los Angeles, California

October 1984

8411050204 841031  
PDR ADOCK 05000424  
A PDR

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1.0 INTRODUCTION	1
2.0 DESCRIPTION OF STRUCTURE	2
2.1 General Description	2
2.2 Location and Foundation Support	2
2.3 Geometry and Dimensions	3
2.4 Key Structural Elements	3
2.5 Major Equipment	3
2.6 Special Features	3
3.0 DESIGN BASES	4
3.1 Criteria	4
3.2 Loads	4
3.3 Load Combinations and Stress/Strength Limits	9
3.4 Materials	9
4.0 STRUCTURAL ANALYSIS AND DESIGN	11
4.1 Selection of Governing Load Combination	11
4.2 Vertical Load Analysis	12
4.3 Lateral Load Analysis	12
4.4 Combined Effects of Three Component Earthquake Loads	13
4.5 Roof Slabs	14
4.6 Shear Walls	15
4.7 Basemat	16

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

TABLE OF CONTENTS (cont)

<u>Section</u>	<u>Page</u>
5.0 MISCELLANEOUS ANALYSIS AND DESIGN	17
5.1 Stability Analysis	17
5.2 Tornado Load Effects	18
5.3 Foundation Bearing Pressure	19/20
6.0 CONCLUSION	19/20
7.0 REFERENCES	19/20

TABLES

FIGURES

APPENDICES

- A Definition of Loads
- B Load Combinations
- C Design of Structures for Tornado Missile Impact

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

LIST OF TABLES

<u>Tables</u>		<u>Page</u>
1	Auxiliary Feedwater Pumphouse Seismic Acceleration Values	21
2	Tornado Missile Data	22
3	Design Results	23
4	Design Results for Shear Wall 7	25
5	Factors of Safety for Structural Stability	26
6	Tornado Missile Analysis Results	27
7	Maximum Foundation Bearing Pressures	28



VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

LIST OF FIGURES

Figure

- |   |  |
|---|--|
| 1 | Location of Auxiliary Feedwater Pumphouse - Unit 1       |
| 2 | Location of Auxiliary Feedwater Pumphouse - Unit 2       |
| 3 | Auxiliary Feedwater Pumphouse Floor Plan - Unit 1        |
| 4 | Auxiliary Feedwater Pumphouse Roof Plan and<br>Elevation |
| 5 | Location of Shear Walls                                  |
| 6 | Dynamic Incremental Soil Pressure Profile                |
| 7 | Wind and Tornado Effective Velocity Pressure<br>Profiles |
| 8 | Concrete Reinforcing Details                             |

## VEGP-AUXILIARY FEEDWATER PUMPHOUSE DESIGN REPORT

### 1.0 INTRODUCTION

The Nuclear Regulatory Commission Standard Review Plan, NUREG-0800, requires the preparation of design reports for Category 1 structures.

This design report represents one of a series of 11 design reports and one seismic analysis report prepared for the Vogtle Electric Generating Plant (VEGP). These reports are listed below:

- Containment Building Design Report
- Containment Internal Structure Design Report
- Auxiliary Building Design Report
- Control Building Design Report
- Fuel Handling Building Design Report
- NSCW Tower and Valve House Design Report
- Diesel Generator Building Design Report
- Auxiliary Feedwater Pumphouse Design Report
- Category 1 Tanks Design Report
- Diesel Fuel Oil Storage Tank Pumphouse Design Report
- Category 1 Tunnels Design Report
- Seismic Analysis Report

The Seismic Analysis Report describes the seismic analysis methodology used to obtain the acceleration responses of Category 1 structures and forms the basis of the seismic loads in all 11 design reports.

The purpose of this design report is to provide the Nuclear Regulatory Commission with specific design and construction information for the auxiliary feedwater pumphouse, in order to assist in planning and conducting a structural audit. Quantitative information is provided regarding the scope of the actual design computations and the final design results.

The report includes a description of the structure and its function, design criteria, loads, materials, analysis and design procedures, and a design summary of representative key structural elements, including the governing design forces.

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

2.0 DESCRIPTION OF STRUCTURE

2.1 GENERAL DESCRIPTION

The auxiliary feedwater pumphouse is a rectangular, box type, one story, reinforced concrete structure. There is one pumphouse per plant unit. The pumphouse houses the safety-related auxiliary feedwater pumps and related equipment. It also serves as a transition structure between the condensate storage tanks and the auxiliary feedwater tunnel. Interior walls are provided for train separation. The center portion is raised to allow access to the condensate storage tank missile structure area. Additional walls are provided at the north and south ends of the structure for missile protection of the access areas.

2.2 LOCATION AND FOUNDATION SUPPORT

All Category 1 structures are founded within the area of the power block excavation. The excavation removed in-situ soils to elevation 130'± where the marl bearing stratum was encountered. All Category 1 structures are located either directly on the marl bearing stratum or on Category 1 backfill placed above the marl bearing stratum. The backfill consists of densely compacted select sand and silty sand. The nominal finished grade elevation is 220'-0". The high groundwater table is at elevation 165'-0".

Each auxiliary feedwater pumphouse is located in the Category 1 yard area between the condensate storage tanks and the main steam tunnel (see figures 1 and 2). It is slightly embedded, extending approximately 24 feet above grade. The structure is supported by a 3-foot-thick mat foundation. The top of the basemat is approximately 4 feet below grade. The basemat plan dimensions are 40 feet by 86 feet. The basemat is founded on approximately 80 feet of Category 1 backfill placed on the marl bearing stratum. It is approximately 50 feet above the high water table.

## VEGP-AUXILIARY FEEDWATER PUMPHOUSE DESIGN REPORT

### 2.3 GEOMETRY AND DIMENSIONS

The auxiliary feedwater pumphouse is 40 feet by 86 feet in plan. The top of roof levels are 26 feet and 18 feet above the top of the basemat. All walls are 2 feet thick and all roofs are 21 inches thick. Structure plans and section are shown in figures 3 and 4.

### 2.4 KEY STRUCTURAL ELEMENTS

The auxiliary feedwater pumphouse is analyzed and designed as a shear wall structure. The key structural elements are the basemat, shear walls, and roof diaphragm. The shear walls considered are shown in figure 5.

### 2.5 MAJOR EQUIPMENT

The auxiliary feedwater pumphouse contains the train A and B electric auxiliary feedwater pumps, the train C steam turbine pump, and related equipment.

### 2.6 SPECIAL FEATURES

#### 2.6.1 Sump

The auxiliary feedwater pumphouse contains a 13-foot by 15-foot sump which extends 8 feet 4 inches below the bottom of the basemat. It is structurally separated from the basemat by an expansion joint.

#### 2.6.2 Hatches

There are three, removable, reinforced concrete hatches in the roof of the auxiliary feedwater pumphouse. They are missile proof and are provided for equipment removal.



VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

3.0 DESIGN BASES

3.1 CRITERIA

The following documents are applicable to the design of the auxiliary feedwater pumphouse.

3.1.1 Codes and Standards

- American Concrete Institute (ACI), Building Code Requirements for Reinforced Concrete, ACI 318-71, including 1974 Supplement.
- American Institute of Steel Construction (AISC), Specification for the Design, Fabrication, and Erection of Structural Steel for Buildings, adopted February 12, 1969, and Supplements No. 1, 2, and 3.

3.1.2 Regulations

- 10 CFR 50, Domestic Licensing of Production and Utilization Facilities.

3.1.3 General Design Criteria (GDC)

- GDC 1, 2, 4, and 5 of Appendix A, 10 CFR 50

3.1.4 Industry Standards

Nationally recognized industry standards, such as American Society for Testing and Materials (ASTM), American Concrete Institute, and American Iron and Steel Institute (AISI), are used to specify material properties, testing procedures, fabrication, and construction methods.

3.2 LOADS

The auxiliary feedwater pumphouse is designed for all credible loading conditions. The loads are listed and load terms defined in Appendix A. The loads are further defined as follows.

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

3.2.1 Normal Loads

3.2.1.1 Dead Loads (D)

- Reinforced concrete 150 pcf
- Piping 50 psf slabs  
and walls as applicable
- Major Equipment Electric AFW pumps -  
(Refer to figure 3 for 19.5 k each  
location) Steam-turbine pump - 21.7 k

3.2.1.2 Live Loads (L)

- Distributed snow or other 30 psf  
load on roofs
- Distributed load on basemat 100 psf
- Distributed load on platforms 100 psf
- Concentrated load on slabs 5 k  
(Applied to maximize moment  
and shear)
- At-rest lateral soil pressure  $.7\gamma_m H$  (Refer to  
section 3.4.6)

3.2.1.3 Operating Thermal Loads ( $T_o$ )

The maximum temperature in the auxiliary feedwater pumphouse under operating conditions is 120°F.

3.2.1.4 Pipe Reactions ( $R_o$ )

There are no significant pipe reactions applicable to the auxiliary feedwater pumphouse.

3.2.2 Severe Environmental Loads

3.2.2.1 Operating Basis Earthquake, OBE (E)

Based on the plant site geologic and seismologic investigations, the peak ground acceleration for OBE is established as 0.12g. The free-field response spectra and the development of horizontal



## VEGP-AUXILIARY FEEDWATER PUMPHOUSE DESIGN REPORT

and vertical floor accelerations and in-structure response spectra at the basemat and roof levels are discussed in the Seismic Analysis Report. The horizontal and vertical OBE floor accelerations are provided in table 1.

The OBE damping values, as percentages of critical damping, applicable to the auxiliary feedwater pumphouse are as follows:

Reinforced concrete structures	4
Welded steel structures	2
Bolted steel structures	4

Dynamic lateral earth pressures are developed by the Mononabe-Okabe method for active earth pressure above the water table using the peak ground accelerations. The dynamic incremental soil pressure profile is shown in figure 6.

### 3.2.2.2 Design Wind (W)

The applicable wind load is the 100-year mean recurrence interval 110 mph wind based on ANSI A58.1-1972 (reference 1). Coefficients are per Exposure C, applicable for flat open country. The wind effective velocity pressure profile is shown in figure 7.

### 3.2.3 Extreme Environmental Loads

#### 3.2.3.1 Safe Shutdown Earthquake, SSE (E')

Based on the plant site geologic and seismologic investigations, the peak ground acceleration for SSE is established as 0.20g.

Free-field response spectra and the development of horizontal and vertical floor accelerations and in-structure response spectra at the basemat and roof levels are discussed in the Seismic Analysis Report. The horizontal and vertical SSE floor accelerations are provided in table 1.

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

The SSE damping values, as a percentage of critical damping, applicable to the auxiliary feedwater pumphouse are as follows:

Reinforced concrete structures	7
Welded steel structures	4
Bolted steel structures	7

Dynamic lateral earth pressures are developed by the Mononabe-Okabe method for active earth pressure above the water table using the peak ground accelerations. The dynamic incremental soil pressure profile is shown in figure 6.

#### 3.2.3.2 Tornado Loads ( $W_t$ )

Loads due to the design tornado include wind pressures, atmospheric pressure differentials, and tornado missile strikes. The design tornado parameters, which are in conformance with the Region I parameters defined in Regulatory Guide 1.76, are as follows:

- Rotational tornado speed 290 mph
- Translational tornado speed 70 mph maximum  
5 mph minimum
- Maximum wind speed 360 mph
- Radius of tornado at maximum rotational speed 150 feet
- Atmospheric pressure differential 3 psi
- Rate of pressure differential change 2 psi/sec

The tornado effective velocity pressure profile used in the design (see figure 7) is in accordance with reference 2.

The auxiliary feedwater pumphouse is also designed to withstand the tornado missile impact effects from airborne objects transported by the tornado. The tornado missile parameters are listed in table 2. Missile trajectories up to and including 45 degrees

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

off of horizontal use the listed horizontal velocities. Those trajectories greater than 45 degrees use the listed vertical velocities.

Tornado loading ( $W_t$ ) is defined as the worst case of the following combinations of tornado load effects.

$$\begin{aligned}W_t &= W_{tg} \text{ (Velocity pressure effects)} \\W_t &= W_{tp} \text{ (Atmospheric pressure drop effects)} \\W_t &= W_{tm} \text{ (Missile impact effects)} \\W_t &= W_{tg} + 0.5 W_{tp} \\W_t &= W_{tg} + W_{tm} \\W_t &= W_{tg} + 0.5 W_{tp} + W_{tm}\end{aligned}$$

3.2.3.3 Probable Maximum Precipitation, PMP (N)

The load due to probable maximum precipitation is applied to the auxiliary feedwater pumphouse roof areas. Special roof scuppers are provided with sufficient scupper capacity to ensure that the depth of ponding water due to the PMP rainfall does not exceed 18 inches. This results in an applied PMP load of 94 psf.

3.2.3.4 Blast Load (B)

The blast load accounts for a postulated site-proximity explosion. The blast load is conservatively taken as a peak positive incident overpressure of 2 psi (acting inwards or outwards) applied as a static load.

3.2.4 Abnormal Loads ( $P_a$ ,  $T_a$ ,  $R_o$ ,  $Y_r$ ,  $Y_j$ ,  $Y_m$ )

Pressure ( $P_a$ ) and jet impingement ( $Y_j$ ) loads are developed for the high-energy pipe lines in the auxiliary feedwater pumphouse. These are applied to the impacted structural elements. The magnitude of the most severe of these loads are as follows:

- $P_a = 1.7 \text{ psi}$
- $Y_j = 63.5 \text{ psi}$

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

There are no other significant abnormal loads applicable to the auxiliary feedwater pumphouse.

### 3.3 LOAD COMBINATIONS AND STRESS/STRENGTH LIMITS

The load combinations and stress/strength limits for structural steel and reinforced concrete are provided in Appendix B.

### 3.4 MATERIALS

The following materials and material properties were used in the design of the auxiliary feedwater pumphouse:

#### 3.4.1 Concrete

- Compressive strength  $f'_c = 4.0 \text{ ksi}$
- Modulus of elasticity  $E_c = 3605 \text{ ksi}$
- Shear modulus  $G = 1440 \text{ ksi}$
- Poisson's ratio  $\nu = 0.17 - 0.25$

#### 3.4.2 Reinforcement - ASTM A615 Grade 60

- Minimum yield stress  $F_y = 60 \text{ ksi}$
- Minimum tensile strength  $F_{ult} = 90 \text{ ksi}$
- Minimum elongation 7-9% in 8 inches

#### 3.4.3 Structural Steel - ASTM A36

- Minimum yield stress  $F_y = 36 \text{ ksi}$
- Minimum tensile strength  $F_{ult} = 58 \text{ ksi}$
- Modulus of elasticity  $E_s = 29,000 \text{ ksi}$

#### 3.4.4 Structural Bolts - ASTM A325: (1/2 inch to 1 inch inclusive)

- Minimum yield stress  $F_y = 92 \text{ ksi}$
- Minimum tensile strength  $F_{ult} = 120 \text{ ksi}$

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

3.4.5 Anchor Bolts and Headed Anchor Studs

3.4.5.1 ASTM A36

- Minimum yield stress  $F_y = 36 \text{ ksi}$
- Minimum tensile strength  $F_{ult} = 58 \text{ ksi}$

3.4.5.2 ASTM A108

- Minimum yield stress  $F_y = 50 \text{ ksi}$
- Minimum tensile strength  $F_{ult} = 60 \text{ ksi}$

3.4.5.3 ASTM A307

- Minimum yield stress  $F_y$  is not applicable
- Minimum tensile strength  $F_{ult} = 60 \text{ ksi}$

3.4.6 Foundation Media

3.4.6.1 General Description

See section 2.2.

3.4.6.2 Category 1 Backfill

- Moist unit weight  $\gamma_m = 126 \text{ pcf}$
- Saturated unit weight  $\gamma_t = 132 \text{ pcf}$
- Shear modulus
 

$G$	<u>Depth (Feet)</u>
1530 ksf	0-10
2650 ksf	10-20
3740 ksf	20-40
5510 ksf	40-Marl bearing stratum
- Angle of internal friction  $\phi = 34^\circ$
- Cohesion  $C = 0$



VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

3.4.6.3 Net Bearing Capacities

• Ultimate	92.5 ksf
• Allowable static	30.8 ksf
• Allowable dynamic	46.3 ksf

4.0 STRUCTURAL ANALYSIS AND DESIGN

This section provides the methodologies employed to analyze the auxiliary feedwater pumphouse and to design its key structural elements, using the applicable loads and load combinations specified in section 3.0.

A preliminary proportioning of key structural elements is based on plant layout and separation requirements, and, where applicable, the minimum thickness requirements for the prevention of concrete scabbing or perforation due to tornado missile impact. The proportioning of these elements is finalized by confirming that strength requirements and, where applicable, ductility and/or stiffness requirements are satisfied.

The structural analysis and design are primarily performed by manual calculations. The building structure is considered as an assemblage of slabs and walls. The analysis is performed using standard structural analysis techniques. The analysis techniques, boundary conditions, and application of loads are provided to illustrate the methods of analysis and design.

In addition, representative analysis and design results are provided to illustrate the response of the key structural elements for governing load combinations.

4.1 SELECTION OF GOVERNING LOAD COMBINATION

An evaluation of load magnitudes, load factors, and load combinations is performed to determine the load combination that governs the overall response of the structure. It is determined that load combination equation 3 for concrete design (Appendix B, Table B.2) containing OBE governs over all other



## VEGP-AUXILIARY FEEDWATER PUMPHOUSE DESIGN REPORT

load combinations, and hence forms the basis for the overall structural analysis and design of the auxiliary feedwater pumphouse. All other load combinations, including the effects of abnormal loads and tornado loads, are evaluated where applicable on a local area basis, i.e., section 5.2. The localized response is combined with the analysis results of the overall structural response, as applicable, to confirm that design integrity is maintained.

### 4.2 VERTICAL LOAD ANALYSIS

The vertical load carrying elements of the auxiliary feedwater pumphouse consist of concrete roof slabs that support the applied vertical loads, the walls that support the roof slabs, and the basemat which transmits the loads from the walls to the foundation medium. Representative vertical load carrying elements are identified in figure 5.

The analysis of the building for vertical loads begins at the roof slab and proceeds down through the walls of the building to the basemat. Slabs are analyzed for the vertical loads applied to them. The total vertical load on a wall is computed based on its self weight and the vertical loads from the roof slab tributary areas.

### 4.3 LATERAL LOAD ANALYSIS

The lateral load carrying elements of the auxiliary feedwater pumphouse consist of concrete roof slabs acting as rigid diaphragms, the shear walls which transmit the loads from the roof diaphragm through the walls below to the basemat, and the basemat which transmits the loads from the walls to the foundation medium. Representative lateral load carrying elements are identified in figure 5.

Since the building structure utilizes the slab diaphragms for horizontal shear distribution, the lateral load analysis is

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

performed by a conventional rigidity and mass analysis. In this analysis, the maximum horizontal design forces for earthquake loads are applied statically. The design horizontal earthquake load (story shear load) at the roof level is obtained by multiplying the lumped roof story mass by the maximum roof acceleration. The story shear load is distributed to the shear walls in proportion to their relative rigidities.

To account for the torsion caused by seismic wave propagation effects, the inherent building eccentricity between the center of mass and center of rigidity is increased by 5 percent of the maximum plan dimension in the computation of the torsional moment. The torsional moment is obtained as the product of this augmented eccentricity and the roof story shear. The shear in the walls resulting from this torsional moment is computed based on the relative torsional rigidities of the walls.

For a given shear wall, the shear due to roof story shear (direct shear) and shear due to torsional moment (torsional shear) are combined to obtain the total design shear load. The torsional shear is neglected when it acts in a direction opposite to the direct shear.

#### 4.4 COMBINED EFFECTS OF THREE COMPONENT EARTHQUAKE LOADS

The combination of co-directional responses due to three component earthquake effects is performed using either the Square Root of the Sum of the Squares (SRSS) method, i.e.,  $R = (R_i^2 + R_j^2 + R_k^2)^{1/2}$  or the Component Factor method, i.e.,

$$\begin{aligned} R &= R_i + 0.4 R_j + 0.4 R_k \\ R &= 0.4 R_i + R_j + 0.4 R_k \\ R &= 0.4 R_i + 0.4 R_j + R_k \end{aligned}$$

wherein 100 percent of the design forces from any one of the three components of the earthquake is considered in combination with 40 percent of the design forces from each of the other two components of the earthquake.

## VEGP-AUXILIARY FEEDWATER PUMPHOUSE DESIGN REPORT

### 4.5 ROOF SLABS

#### 4.5.1 Analysis and Design Methodology

A layout of the roof slab panels of the auxiliary feedwater pumphouse is presented in figure 4. Based on the panel configuration, relative stiffness of the supporting members and the type of fixity provided, slab panels are analyzed for one way slab action using appropriate boundary conditions and standard beam formulae.

Equivalent uniformly distributed loads are applied to roof slab panels. The design vertical earthquake loads for roof slab panels are obtained by multiplying the effective mass from the applied loading (including its own mass) by the maximum roof acceleration.

Based on the floor flexibility study, it is concluded that the effects of vertical flexibility on the auxiliary feedwater pumphouse floor accelerations and response spectra are insignificant, as long as the fundamental floor system frequency is equal to or higher than 25 cps. The evaluation of the floor systems in the pumphouse demonstrates that their frequencies are higher than this value. The details of the floor flexibility study are provided in the Seismic Analysis Report.

Slab panels are selected for design on the basis of the controlling combination of design load intensity, span, panel configuration, and support condition. The structural design is primarily based on strength considerations and consists of sizing and detailing the reinforcing steel to meet the ACI 318 Code requirements. Design results are shown in table 3, and design details are presented in figure 8. In general, the reinforcing requirements are determined for the governing face of the slab and conservatively provided on both faces and in both directions. As appropriate, additional reinforcement is provided in the roof adjacent to large openings.

VECP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

#### 4.6 SHEAR WALLS

##### 4.6.1 Analysis and Design Methodology

The locations of shear walls are identified in figure 5.

The details of the analysis methodology used to compute the total in-plane design loads of a shear wall are described under lateral load analysis in sections 4.2 and 4.3.

The in-plane design loads include axial loads resulting from the overturning moment.

The out-of-plane design loads are considered using the inertia loads on the walls due to the structural acceleration caused by the design earthquake. The seismic inertia loads are applied as uniform pressure loads.

Conventional beam analysis is used to compute the bending moment and shear forces resulting from the out-of-plane design loads. At controlling sections, the combined effects of in-plane overturning moment and axial loads, and the out-of-plane loads are evaluated.

The shear wall design is performed in accordance with the ACI 318 Code using the following methodology:

- A. The horizontal and vertical reinforcement required to resist the design shear loads is determined.
- B. The flexural capacity of the shear wall using the reinforcement determined is obtained using the Cardenas equation, (reference 3).
- C. If the flexural capacity computed is less than the design overturning moment, then the reinforcement required is determined in one of the following two ways:
  1. The total vertical reinforcement required for the design moment is computed using the Cardenas equation and is distributed uniformly along the length of the wall.



VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

2. The reinforcement required in the end section of the wall to resist the overturning moment is computed.

D. The reinforcement requirements for the out-of-plane loads are determined and combined with the requirements for the in-plane loads.

Design results are shown in tables 3 and 4, and design details are presented in figure 8.

#### 4.7 BASEMAT

##### 4.7.1 Analysis and Design Methodology

A plan view showing the basemat dimensions is provided in figure 5.

The basemat is first checked for rigidity by investigating beam strips spanning between shear wall support points using standard beam-on-elastic-foundation criteria. Each strip is determined to be rigid. The basemat analysis is, therefore, based on a linear soil reaction profile.

The magnitude and distribution of the soil reaction loads are determined by applying statics to the overall auxiliary feedwater pumphouse structure, and summing equilibrium forces at the bottom of the basemat. The result is a linearly varying soil reaction pressure profile.

The basemat is analyzed by statically applying the soil reaction pressure profile to the basemat. The walls behave as support points. Basemat panels are selected for design on the basis of the controlling combination of design load intensity, span, and configuration. Key spans between the support walls are analyzed as beam strips applying standard beam formulas. The structural design is primarily based on strength considerations and consists of proportioning and detailing the reinforcing steel to meet the ACI 318 Code requirements. Design results are shown in tables 3 and 4, and design details are presented in figure 8. In general,

## VEGP-AUXILIARY FEEDWATER PUMPHOUSE DESIGN REPORT

the reinforcing requirements are determined for the governing face of the slab and conservatively provided on both faces and in both directions. Appropriate consideration is given in the basemat design to the large sump openings.

### 5.0 MISCELLANEOUS ANALYSIS AND DESIGN

As described in section 4.1, the auxiliary feedwater pumphouse is evaluated for the effects of abnormal loads and tornado loads, where applicable on a local area basis. In addition, the overall stability of the auxiliary feedwater pumphouse is evaluated. This section describes these analyses and significant special provisions employed in the auxiliary building design.

#### 5.1 STABILITY ANALYSIS

The overall stability of the auxiliary feedwater pumphouse is evaluated by determining the factor of safety against overturning, and sliding. Since the foundation level (elevation 212'-0") is above the high water table elevation (elevation 165'-0"), the auxiliary feedwater pumphouse is not subjected to flotation effects.

##### 5.1.1 Overturning

The factor of safety against overturning is determined using the equivalent static method.

The factor of safety against overturning using the equivalent static method is defined as the ratio of the resisting moment due to net gravity forces to the overturning moment caused by the maximum lateral forces acting on the structure. The gravity forces are reduced to account for the effects of the vertical component of earthquake.



## VEGP-AUXILIARY FEEDWATER PUMPHOUSE DESIGN REPORT

### 5.1.2 Sliding

The factor of safety against sliding is defined as the ratio of combined frictional and passive sliding resistance of the foundation to the maximum calculated lateral force.

### 5.1.3 Analysis Results

The minimum required factors of safety and the calculated factors of safety for stability are provided in table 5.

## 5.2 TORNADO LOAD EFFECTS

Tornado load effects result from wind pressures, atmospheric pressure differentials, and tornado missile strikes. The magnitude and combinations of tornado load effects considered are described in section 3.2. The load combination involving tornado load effects is specified by equation 8 of Table B.2 in Appendix B.

Controlling roof and exterior wall panels are investigated for tornado load effects, and the localized response is combined with the analysis results of the overall structural response, as applicable, to confirm that design integrity is maintained. Additional reinforcing steel is provided in accordance with the ACI 318 Code, if necessary, to satisfy design requirements. In addition, barriers are provided for the openings in the exterior walls and roofs. Any openings in the exterior walls or slabs and the interior walls or slabs that may be susceptible to missile entry are evaluated to ensure that no safety-related systems or components are located in a potential path of the missile.

The methodology used to analyze and design the structural elements to withstand the tornado load effects is described in reference 2. Specific procedures used for analysis of missile impact effects are described in Appendix C.

Representative results of the tornado missile analysis are provided in table 6.

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

All wall and roof panels providing protection against tornado load effects have a minimum thickness of 24 and 21 inches respectively, to preclude missile perforation and concrete scabbing.

5.3 FOUNDATION BEARING PRESSURE

The maximum calculated bearing pressures under the governing design load conditions are provided in table 7.

6.0 CONCLUSION

The analysis and design of the auxiliary feedwater pumphouse includes all credible loading conditions and complies with all applicable design requirements.

7.0 REFERENCES

1. "Building Code Requirements for Minimum Design Loads in Buildings and Other Structures," ANSI A58.1-1972, American National Standards Institute, New York, N.Y., 1972.
2. BC-TOP-3-A, Revision 3, Tornado and Extreme Wind Design Criteria for Nuclear Power Plants, Bechtel Power Corp., August 1974.
3. Design Provisions for Shear Walls, Portland Cement Association, 1973.
4. BC-TOP-4-A, Revision 3, Seismic Analysis of Structures and Equipment of Nuclear Power Plants, Bechtel Power Corp., November 1974.

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

TABLE 1

AUXILIARY FEEDWATER PUMPHOUSE SEISMIC  
ACCELERATION VALUES

Floor Accelerations (g's) <sup>(1)</sup>						
Elevation (ft)	SSE			OBE		
	E-W	N-S	Vert.	E-W	N-S	Vert.
216	0.24	0.24	0.24	0.14	0.14	0.14
232	0.25	0.25	0.25	0.15	0.15	0.14

(1) The actual acceleration values used in the design of the structure may be higher than the values shown.

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

TABLE 2  
TORNADO MISSILE DATA

Missile	Weight W (lb)	End-On Height Limit (ft)	End-On Horizontal Velocity (ft/sec)	Vertical Velocity (ft/sec)
4" x 12" x 12' Plank	200	216	200	160
3" $\emptyset$ std x 10' Pipe	78.5	212	200	160
1" $\emptyset$ x 3' Steel Rod	8	Unlimited	317	254
6" $\emptyset$ std x 15' Pipe	285	101	160	128
12" $\emptyset$ std x 15' Pipe	744	46	150	120
13-1/2" $\emptyset$ x 35' Utility Pole	1490	30 <sup>(1)</sup>	211	169
Automobile (20-ft <sup>2</sup> Projected Area)	4000	0	75	60

(1) To 30 feet above all grade levels within 1/2 mile of facility structures.

TABLE 3

DESIGN RESULTS (Sheet 1 of 2)

Wall	Governing Load Combination Equation	In-Plane Shear Force (Factored) (k)	Design Forces Out-of-Plane		A <sub>s</sub> Required (Each Face) (in. <sup>2</sup> /ft)	A <sub>s</sub> Provided (Each Face) (in. <sup>2</sup> /ft)
			Moment (ft-k/ft)	Shear <sup>(2)</sup> (k/ft)		
1	3,5	423.8	17.6	5.51	0.36 <sup>(3)</sup>	1.05
2	3,5	233.2	13.8	4.32	0.36 <sup>(3)</sup>	1.05
3	3,5	434.2	17.6	5.51	0.36 <sup>(3)</sup>	1.05
4	3,5	188.6	17.6	5.51	0.36 <sup>(3)</sup>	1.05
5	3,5	213.6	13.8	4.32	0.36 <sup>(3)</sup>	1.05
6	3,5	200.7	13.8	4.32	0.36 <sup>(3)</sup>	1.05
7	3,5,7	149.0 <sup>(1)</sup>	41.4	21.8	0.49	1.05
8	3,5	206.7	13.8	4.32	0.36 <sup>(3)</sup>	1.05
9	3,5	214.9	17.6	5.51	0.36 <sup>(3)</sup>	1.05
10	3,5	119.0	2.45	2.04	0.36 <sup>(3)</sup>	1.05
11	3,5	77.2	1.94	1.62	0.36 <sup>(3)</sup>	1.05
12	3,5	142.1	2.45	2.04	0.36 <sup>(3)</sup>	1.05
13	3,5	119.0	2.45	2.04	0.36 <sup>(3)</sup>	1.05

(1) See table 4 for detailed loading on this key wall

(2) Allowable shear = .126 ksi - sufficient for all cases

(3) Governed by minimum code reinforcing requirements



TABLE 3  
DESIGN RESULTS (Sheet 2 of 2)

Element	Governing Loading Combination Equation	Design Moment (ft-k)	A <sub>s</sub> Required (in. <sup>2</sup> /ft)	A <sub>s</sub> Provided (in. <sup>2</sup> /ft)
Roof	3	162	1.21	1.33
Basemat	3	123	.97	1.05



TABLE 4  
DESIGN RESULTS FOR SHEAR WALL 7

Pier	Governing Load Combination Equation	Shear (Unfactored) (k)	Overturning Moment (Unfactored) (ft-k)	A <sub>s</sub> Required (Each Face) (in. <sup>2</sup> /ft)	A <sub>s</sub> Provided (Each Face) (in. <sup>2</sup> /ft)
1	3	24.6	63.2	1.22	6.8
2	3	14.4	18.5	0.63	3.2
3	3	39.5	56.3	1.22	7.4
4	3	53.9	301.0	10.08	22.1
5	3	46.7	458.4	10.59	22.6
6	3	31.7	215.4	7.42	15.9
A	3	78.4	725.8	5.84	42.0
B	3	78.4	1291.1	19.41	42.0

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

TABLE 5  
FACTORS OF SAFETY FOR STRUCTURAL STABILITY

Load <sup>(1)(2)</sup> Combination	Overturning Factor of Safety		Sliding Factor of Safety	
	Minimum Required	Calculated	Minimum Required	Calculated
D + H + E	1.5	3.43	1.5	2.40
D + H + E'	1.1	2.06	1.1	1.35

- (1) D = Dead weight of structure  
H = Lateral earth pressure  
E = OBE  
E' = SSE

- (2) Lateral loads caused by design wind, tornado, and blast are less in magnitude than lateral loads caused by design OBE and SSE.

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

TABLE 6  
TORNADO MISSILE ANALYSIS RESULTS<sup>(1)</sup>

Panel Description and Location	Panel Size			Computed Ductility	Allowable Ductility
	Length (ft)	Width (ft)	Thickness (ft)		
Roof	38.0	23.0	1.75	See Note (2)	10
Wall	30.0	17.0	2.0	See Note (2)	10
Missile Barrier	40.0	4.0	2.0	6.5	10

(1) Governing combination of tornado load effects is  

$$W_t = W_{tg} + 0.5 W_{tp} + W_{tm}$$

(2) Remains elastic

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

TABLE 7  
MAXIMUM FOUNDATION BEARING PRESSURES<sup>(1)</sup>

Gross Static (ksf)	Net Static (ksf)	Gross Dynamic (ksf)	Net Dynamic (ksf)	Allowable Net <sup>(2)</sup> Bearing Capacity		Computed <sup>(3)</sup> Factor of Safety	
				Static (ksf)	Dynamic (ksf)	Static	Dynamic
1.6	0.6	3.2	2.2	30.8	46.3	154.3	42.0

(1) Maximum foundation bearing pressures are defined as follows:

Gross Static = Total structure dead load plus operating live load divided by total basemat area.


Net Static = The static pressure in excess of the overburden pressure at the base of the structure.

Gross Dynamic = Maximum soil pressure under dynamic loading conditions (i.e., unfactored SSE).

Net Dynamic = The dynamic pressure in excess of the overburden pressure at the base of the structure.

(2) The allowable net static and dynamic bearing capacities are obtained by dividing the ultimate net bearing capacity by factors of 3 and 2, respectively. The ultimate net bearing capacity is the pressure in excess of the overburden pressure at the foundation level at which shear failure may occur in the foundation stratum.

(3) The computed factor of safety is the ultimate net bearing capacity divided by the net static or net dynamic bearing pressure.





N 79+00.00


N 78+00.00

N 77+00.00

N 76+00.00

N 75+00.00


# TI APERTURE CARD




Also Available On  
Aperture Card

Figure 1  
LOCATION OF AUXILIARY FEEDWATER  
PUMPHOUSE - UNIT 1

8411050204-01





Also Available On  
Aperture Card

Figure 2  
LOCATION OF AUXILIARY FEEDWATER  
PUMPHOUSE - UNIT 2

8411050204-02




Figure 3  
AUXILIARY FEEDWATER PUMPHOUSE  
FLOOR PLAN - UNIT 1






Figure 4  
AUXILIARY FEEDWATER PUMPHOUSE  
ROOF PLAN AND ELEVATION





NORTH-SOUTH SHEAR WALLS




EAST-WEST SHEAR WALLS

LEGEND



= SHEAR WALL

Figure 5  
LOCATION OF SHEAR WALLS



H: HEIGHT FROM BASE OF STRUCTURE TO SOIL SURFACE

$P_d$  = DYNAMIC INCREMENTAL SOIL PRESSURE

R: RESULTANT FORCE

$$R = .075 \gamma_m H^2 \text{ (SSE)*}$$


$$= .045 \gamma_m H^2 \text{ (OBE)*}$$

$$P_d = \frac{2R}{H}$$

$\gamma_m$  = SOIL MOIST UNIT WEIGHT, PCF

\*DERIVED USING THE PEAK GROUND ACCELERATIONS OF 0.12g AND 0.20g  
FOR OBE AND SEE RESPECTIVELY.

Figure 6  
DYNAMIC INCREMENTAL  
SOIL PRESSURE PROFILE



$$P = C_s P_{\max} C_p$$

WHERE:

$C_s$  = SIZE COEFFICIENT  
= .92

$P_{\max}$  =  $0.00256 (V_{\max})^2$   
=  $0.00256 (360 \text{ mph})^2$   
= 332 Psf

$C_p$  = EFFECTIVE EXTERNAL PRESSURE  
COEFFICIENT

$$P = (.92) (332 \text{ psf}) C_p$$

$$= 305 C_p (\text{psf})$$

Figure 7  
WIND AND TORNADO EFFECTIVE VELOCITY  
PRESSURE PROFILES




Figure 8  
CONCRETE REINFORCING DETAILS  
(Sheet 1 of 4)




Figure 8  
CONCRETE REINFORCING DETAILS  
(Sheet 2 of 4)






Figure 8  
CONCRETE REINFORCING DETAILS  
(Sheet 3 of 4)




Figure 8  
CONCRETE REINFORCING DETAILS  
(Sheet 4 of 4)

VEOP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

APPENDIX A

DEFINITION OF LOADS

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

APPENDIX A

DEFINITION OF LOADS

The loads considered are normal loads, severe environmental loads, extreme environmental loads, abnormal loads, and potential site proximity loads.

A.1 NORMAL LOADS

Normal loads are those loads to be encountered, as specified, during construction stages, during test conditions, and later, during normal plant operation and shutdown. They include the following:

- D Dead loads or their related internal moments and forces, including hydrostatic loads and any permanent loads except prestressing forces.
- L Live loads or their related internal moments and forces, including any movable equipment loads and other loads which vary with intensity and occurrence, e.g., lateral soil pressures. Live load intensity varies depending upon the load condition and the type of structural element.
- T<sub>O</sub> Thermal effects and loads during normal operating or shutdown conditions, based on the most critical transient or steady-state condition.
- R<sub>O</sub> Pipe reactions during normal operating or shutdown conditions, based on the most critical transient or steady-state conditions.

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

A.2 SEVERE ENVIRONMENTAL LOADS

Severe environmental loads are those loads to be infrequently encountered during plant life. Included in this category are:

- E Loads generated by the operating basis earthquake (OBE). These include the associated hydrodynamic and dynamic incremental soil pressures.
- W Loads generated by the design wind specified for the plant.

A.3 EXTREME ENVIRONMENTAL LOADS

Extreme environmental loads are those loads which are credible but are highly improbable. They include:

- E' Loads generated by the safe shutdown earthquake (SSE). These include the associated hydrodynamic and dynamic incremental soil pressures.
- W<sub>t</sub> Loads generated by the design tornado specified for the plant. They include loads due to wind pressure, differential pressure, and tornado-generated missiles.
- N Loads generated by the probable maximum precipitation.
- B Loads generated by postulated blast along transportation routes.

A.4 ABNORMAL LOADS

Abnormal loads are those loads generated by a postulated high-energy pipe break accident within a building and/or compartment thereof. Included in this category are the following:

- P<sub>a</sub> Pressure load within or across a compartment and/or building, generated by the postulated break.
- T<sub>a</sub> Thermal loads generated by the postulated break and including T<sub>o</sub>.



VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

- $R_a$  Pipe and equipment reactions under thermal conditions generated by the postulated break and including  $R_o$ .
- $Y_r$  Load on a structure generated by the reaction of a ruptured high-energy pipe during the postulated event.
- $Y_j$  Load on a structure generated by the jet impingement from a ruptured high-energy pipe during the postulated break.
- $Y_m$  Load on a structure or pipe restraint resulting from the impact of a ruptured high-energy pipe during the postulated event.

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

APPENDIX B

LOAD COMBINATIONS

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

APPENDIX B

LOAD COMBINATIONS

B.1 STEEL STRUCTURES

The steel structures and components are designed in accordance with elastic working stress design methods of Part 1 of the American Institute of Steel Construction (AISC) specification, using the load combinations specified in table B.1.

B.2 CONCRETE STRUCTURES

The concrete structures and components are designed in accordance with the strength design methods of the American Concrete Institute (ACI) Code, ACI 318, using the load combinations specified in table B.2.

TABLE B.1<sup>(a)</sup>STEEL DESIGN LOAD COMBINATIONS  
ELASTIC METHOD

	<u>EQ</u>	<u>D</u>	<u>L</u>	<u>P<sub>a</sub></u>	<u>T<sub>o</sub></u>	<u>T<sub>a</sub></u>	<u>E</u>	<u>E'</u>	<u>W</u>	<u>W<sub>t</sub></u>	<u>R<sub>o</sub></u>	<u>R<sub>a</sub></u>	<u>Y<sub>j</sub></u>	<u>Y<sub>r</sub></u>	<u>Y<sub>m</sub></u>	<u>N</u>	<u>B</u>	<u>Strength Limit(f<sub>s</sub>)</u>
<u>Service Load Conditions</u>																		
	1	1.0	1.0															1.0
	2	1.0	1.0				1.0											1.0
	3	1.0	1.0						1.0									1.0
	4	1.0	1.0		1.0						1.0							1.5
	5	1.0	1.0		1.0		1.0				1.0							1.5
	6	1.0	1.0		1.0				1.0		1.0							1.5
<u>Factored Load</u>																		
	7	1.0	1.0		1.0			1.0			1.0							1.6
(See note b.)	8	1.0	1.0		1.0					1.0	1.0							1.6
	9	1.0	1.0	1.0		1.0						1.0						1.6
(See notes c and d.)	10	1.0	1.0	1.0		1.0	1.0					1.0	1.0	1.0	1.0			1.6
(See notes c and d.)	11	1.0	1.0	1.0		1.0		1.0				1.0	1.0	1.0	1.0			1.7
	12	1.0	1.0		1.0						1.0						1.0	1.6
	13	1.0	1.0		1.0						1.0					1.0		1.6

- a. See Appendix A for definition of load symbols.  $f_s$  is the allowable stress for the elastic design method defined in Part 1 of the AISC, "Specification for the Design, Fabrication, and Erection of Structural Steel for Buildings." The one-third increase in allowable stresses permitted for seismic or wind loadings is not considered.
- b. When considering tornado missile load, local section strength may be exceeded provided there will be no loss of function of any safety-related system. In such cases, this load combination without the tornado missile load is also to be considered.
- c. When considering  $Y_j$ ,  $Y_r$ , and  $Y_m$  loads, local section strength may be exceeded provided there will be no loss of function of any safety-related system. In such cases, this load combination without  $Y_j$ ,  $Y_r$ , and  $Y_m$  is also to be considered.
- d. For this load combination, in computing the required section strength, the plastic section modulus of steel shapes, except for those which do not meet the AISC criteria for compact sections, may be used.

TABLE B.2<sup>(a)(f)</sup>

CONCRETE DESIGN LOAD COMBINATIONS  
STRENGTH METHOD

	<u>EQN</u>	<u>D</u>	<u>L</u>	<u>P<sub>a</sub></u>	<u>T<sub>o</sub></u>	<u>T<sub>a</sub></u>	<u>E</u>	<u>E'</u>	<u>W</u>	<u>W<sub>t</sub></u>	<u>R<sub>o</sub></u>	<u>R<sub>a</sub></u>	<u>Y<sub>j</sub></u>	<u>Y<sub>r</sub></u>	<u>Y<sub>m</sub></u>	<u>N</u>	<u>B</u>	<u>Strength Limit</u>
<u>Service Load Conditions</u>																		
	1	1.4	1.7															U
(See note b.)	2	1.4	1.7						1.7									U
(See note c.)	3	1.4	1.7				1.9											U
	4	1.05	1.275		1.275						1.275							U
	5	1.05	1.275		1.275				1.275		1.275							U
	6	1.05	1.275		275		1.425				1.275							U
<u>Factored Load Conditions</u>																		
	7	1.0	1.0		1.0			1.0			1.0							U
(See note d.)	8	1.0	1.0		1.0					1.0	1.0							U
	9	1.0	1.0	1.5		1.0						1.0						U
(See note e.)	10	1.0	1.0	1.25		1.0	1.25					1.0	1.0	1.0	1.0			U
(See note e.)	11	1.0	1.0	1.0		1.0		1.0				1.0	1.0	1.0	1.0			U
	12	1.0	1.0		1.0						1.0					1.0		U
	13	1.0	1.0		1.0						1.0					1.0		U

- a. See Appendix A for definition of load symbols. U is the required strength based on strength method per ACI 318-71.  
b. Unless this equation is more severe, the load combination 1.2D+1.7W is also to be considered.  
c. Unless this equation is more severe, the load combination 1.2D+1.9E is also to be considered.  
d. When considering tornado missile load, local section strength may be exceeded provided there will be no loss of function of any safety-related system. In such cases, this load combination without the tornado missile load is also to be considered.  
e. When considering Y<sub>j</sub>, Y<sub>r</sub>, and Y<sub>m</sub> loads, local section strength may be exceeded provided there will be no loss of function of any safety-related system. In such cases, this load combination without Y<sub>j</sub>, Y<sub>r</sub>, and Y<sub>m</sub> is also to be considered.  
f. Actual load factors used in design may have exceeded those shown in this table.



VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

APPENDIX C

DESIGN OF STRUCTURES FOR TORNADO MISSILE IMPACT

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

APPENDIX C

DESIGN OF STRUCTURES FOR TORNADO MISSILE IMPACT

C.1 INTRODUCTION

This appendix contains methods and procedures for analysis and design of steel and reinforced concrete structures and structural elements subject to tornado-generated missile impact effects. Postulated missiles, and other concurrent loading conditions are identified in Section 3.2 of the Design Report.

Missile impact effects are assessed in terms of local damage and structural response. Local damage (damage that occurs in the immediate vicinity of the impact area) is assessed in terms of perforation and scabbing.

Evaluation of local effects is essential to ensure that protected items would not be damaged directly by a missile perforating a protective barrier or by scab particles. Empirical formulas are used to assess local damage.

Evaluation of structural response is essential to ensure that protected items are not damaged or functionally impaired by deformation or collapse of the impacted structure.

Structural response is assessed in terms of deformation limits, strain energy capacity, structural integrity, and structural stability. Structural dynamics principles are used to predict structural response.

C.1.1 Procedures

The general procedures for analysis and design of structures or structural elements for missile impact effects include:

- a. Defining the missile properties (such as type, material, deformation characteristics, geometry, mass, trajectory, strike orientation, and velocity).

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

- b. Determining impact location, material strength, and thickness required to preclude local failure (such as perforation for steel targets and scabbing for reinforced concrete targets).
- c. Defining the structure and its properties (such as geometry, section strength, deformation limits, strain energy absorption capacity, stability characteristics, and dynamic response characteristics).
- d. Determining structural response considering other concurrent loading conditions.
- e. Checking adequacy of structural design (stability, integrity, deformation limits, etc.) to verify that local damage and structural response (maximum deformation) will not impair the function of safety-related items.

## C.2 LOCAL EFFECTS

Evaluation of local effects consists of estimating the extent of local damage and characterization of the interface force-time function used to predict structural response. Local damage is confined to the immediate vicinity of the impact location on the struck element and consists of missile deformation, penetration of the missile into the element, possible perforation of the element, and, in the case of reinforced concrete, dislodging of concrete particles from the back face of the element (scabbing).

Because of the complex physical processes associated with missile impact, local effects are evaluated primarily by application of empirical relationships based on missile impact test results. Unless otherwise noted, these formulas are applied considering a normal incidence of strike with the long axis of the missile parallel to the line of flight.

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

C.2.1 Reinforced Concrete Elements

The parts of the building structure that offer protection for safety-related equipment against tornado-generated missiles are provided with  $f'_c = 4000$  psi minimum concrete strength, have 24-inch-minimum-thick walls, and have 21-inch-minimum-thick roofs. Therefore, the walls and roofs of these structures are resistant to perforation and scabbing by the postulated missiles discussed in Section 3.2 of the Design Report under tornado loads.

C.2.2 Steel Elements

Steel barriers subjected to missile impact are designed to preclude perforation. An estimate of the steel element thickness for threshold of perforation for nondeformable missiles is provided by equation 2-1, which is a more convenient form of the Ballistic Research Laboratory (BRL) equation for perforation of steel plates with material constant taken as unity (reference 1).

$$T_p = \frac{(E_k)^{2/3}}{672D} \quad E_k = \frac{M_m V_s^2}{2} \quad (2-1)$$

where:

- $T_p$  = steel plate thickness for threshold of perforation (in.).
- $E_k$  = missile kinetic energy (ft-lb).
- $M_m$  = mass of the missile (lb-s<sup>2</sup>/ft).
- $V_s$  = missile striking velocity (ft/s).
- $D$  = missile diameter (in.).<sup>(a)</sup>

---

a. For irregularly shaped missiles, an equivalent diameter is used. The equivalent diameter is taken as the diameter of a circle with an area equal to the circumscribed contact, or projected frontal area, of the noncylindrical missile. For pipe missiles, D is the outside diameter of the pipe.



VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

The design thickness to prevent perforation,  $t_p$ , must be greater than the predicted threshold value. The threshold value is increased by 25 percent to obtain the design thickness.

$$t_p = 1.25 T_p \quad (2-2)$$

where:

$$t_p = \text{design thickness to preclude perforation (in.).}$$

### C.3 STRUCTURAL RESPONSE DUE TO MISSILE IMPACT LOADING

When a missile strikes a structure, large forces develop at the missile-structure interface, which decelerate the missile and accelerate the structure. The response of the structure depends on the dynamic properties of the structure and the time-dependent nature of the applied loading (interface force-time function). The force-time function is, in turn, dependent on the type of impact (elastic or plastic) and the nature and extent of local damage.

#### C.3.1 General

In an elastic impact, the missile and the structure deform elastically, remain in contact for a short period of time (duration of impact), and subsequently disengage due to the action of elastic interface restoring forces.

In a plastic impact, the missile or the structure or both may deform plastically or sustain permanent deformation or damage (local damage). Elastic restoring forces are small, and the missile and the structure tend to remain in contact after impact. Plastic impact is much more common in nuclear plant design than elastic impact, which is rarely encountered. For example, test data indicate that the impact from all postulated tornado-generated missiles can be characterized as a plastic collision.



VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

If the interface forcing function can be defined or conservatively idealized (from empirical relationships or from theoretical considerations), the structure can be modeled mathematically, and conventional analytical or numerical techniques can be used to predict structural response. If the interface forcing function cannot be defined, the same mathematical model of the structure can be used to determine structural response by application of conservation of momentum and energy balance techniques with due consideration for type of impact (elastic or plastic).

In either case, in lieu of a more rigorous analysis, a conservative estimate of structural response can be obtained by first determining the response of the impacted structural element and then applying its reaction forces to the supporting structure. The predicted structural response enables assessment of structural design adequacy in terms of strain energy capacity, deformation limits, stability, and structural integrity.

Three different procedures are given for determining structural response: the force-time solution, the response chart solution, and the energy balance solution. The force-time solution involves numerical integration of the equation(s) of motion and is the most general method applicable for any pulse shape and resistance function. The response chart solution can be used with comparable results, provided the idealized pulse shape (interface forcing function) and the resistance function are compatible with the response chart. The energy balance solution is used in cases where the interface forcing function cannot be defined or where an upper limit check on structural response is desired. This method will consistently overestimate structural response, since the resisting spring forces during impact are neglected.

In defining the mass-spring model, consideration is given to local damage that could affect the response of the element. For concrete slab elements, the beneficial effect of formation of a fracture plane which propagates from the impact zone to the back of the slab (back face fracture plane) just prior to scabbing

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

(reference 2) is neglected. The formation of this fracture plane limits the forces transferred to the surrounding slab and significantly reduces overall structural response. Since scabbing is to be precluded in the design, the structural response check is made assuming the fracture plane is not formed. It is recognized, however, that should the missile velocity exceed that for threshold of scabbing, structural response would be limited by this mechanism.

Therefore, the structural response is conservatively evaluated ignoring formation of the fracture plane and any reduction in response.

#### C.3.2 Structural Assessment

The predicted structural response enables assessment of design adequacy in terms of strain energy capacity, deformation limits, stability, and structural integrity.

For structures allowed to displace beyond yield (elasto-plastic response), a check is made to ensure that deformation limits would not be exceeded, by comparing calculated displacements or required ductility ratios with allowable values (such as those contained in table C-1).

#### C.4 REFERENCES

1. Gwaltney, R. C., "Missile Generation and Protection in Light-Water-Cooled Power Reactor Plants," ORNL NSIC-22, Oak Ridge National Laboratory, Oak Ridge, Tennessee, for the USAEC, September 1968.
2. Rotz, J. V., "Results of Missile Impact Tests on Reinforced Concrete Panels," Vol 1A, pp 720-738, Second Specialty Conference on Structural Design of Nuclear Power Plant Facilities, New Orleans, Louisiana, December 1975.

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

TABLE C-1  
DUCTILITY RATIOS (Sheet 1 of 2)

<u>Member Type and Load Condition</u>	<u>Maximum Allowable Value of Ductility Ratio (<math>\mu</math>)</u>
<u>Reinforced Concrete</u>	
Flexure <sup>(1)</sup> :	
Beams and one-way slabs <sup>(2)</sup>	$\frac{0.10}{p-p'} \leq 10$
Slabs with two-way reinforcing <sup>(2)</sup>	$\frac{0.10}{p-p'} \leq 10$ or 30 (See 3 and 4)
Axial compression <sup>(1)</sup> :	
Walls and columns	1.3
Shear, concrete beams and slabs in region controlled by shear:	
Shear carried by concrete only	1.3
Shear carried by concrete and stirrups	1.6
Shear carried completely by stirrups	2.0
Shear carried by bent-up bars	3.0
<u>Structural Steel</u>	
Columns <sup>(5)</sup>	
$l/r \leq 20$	1.3
$l/r > 20$	1.0
Tension due to flexure	10
Shear	10
Axial tension and steel plates in membrane tension <sup>(6)</sup>	$0.5 \frac{e_u}{e_y}$
Compression members not required for stability of building structures	10

VEGP-AUXILIARY FEEDWATER PUMPHOUSE  
DESIGN REPORT

TABLE C-1

DUCTILITY RATIOS (Sheet 2 of 2)


Notes:

- (1) The interaction diagram used to determine the allowable ductility ratio for elements subject to combined flexure and axial compression is provided in figure C-1.
- (2)  $p$  and  $p'$  are the positive and negative reinforcing steel ratios, respectively.
- (3) Ductility ratio up to 10 can be used without an angular rotation check.
- (4) Ductility ratio up to 30 can be used provided an angular rotation check is made.
- (5)  $\ell/r$  is the member slenderness ratio. The value specified is for axial compression. For columns and beams with uniform moment the following value is used:

$$\frac{14 \times 10^4}{F_y \left( \frac{k\ell}{r} \right)^2} + \frac{1}{2} \leq 10$$

- (6)  $e_u$  and  $e_y$  are the ultimate and yield strains.  
 $e_u$  shall be taken as the ASTM-specified minimum.





(A) REINFORCED CONCRETE INTERACTION  
DIAGRAM (P VS M)

(B) ALLOWABLE DUCTILITY RATIO  $\mu$  VS P

Figure C-1  
MAXIMUM ALLOWABLE DUCTILITY RATIO  
FOR REINFORCED CONCRETE SECTION  
WITH BEAM-COLUMN ACTION