



ENV 43

VIRGINIA ELECTRIC AND POWER COMPANY, RICHMOND, VIRGINIA 23261

February 13, 1985

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

U. S. Environmental Protection Agency
Region III
Superfund Branch (3HW22)
Curtis Building
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

Oil Spill Questionnaire VA-85-039 - 11/2/84 - North Anna Power Station

Gentlemen:

Attached is the completed form submitted to this office on February 11, 1985 by Mr. Thomas Voltaggio on the above referenced oil spill.

If you have any questions or desire additional information, please contact us.

Very truly yours,

John A. Taylor, Ph.D.
Manager
Water Quality

cc: Mr. W. L. Kregloe, SWCB (With Enclosure)
Mr. James P. O'Reilly, USNRC, Docket No. 50-338/50-339 (Enclosure)
Mr. Harold R. Denton, USNRC, Docket No. 50-338/50-339 (Enclosure) ✓
Mr. M. W. Branch, USNRC, Docket No. 50-338 (With Enclosure)

8502260132 850213
PDR ADDCK 05000338
S PDR

0591020GRK934

1623
41



NOTED FEB 11 1985 M.F.K.

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION III

6TH AND WALNUT STREETS
PHILADELPHIA, PENNSYLVANIA 19106

February 9, 1985

VEPCO
P.O. Box 26666
Richmond, VA 23261

Re: VA-85-039, 11/2/84, Louisa Co., VA

Gentlemen:

This office has received notification that your facility discharged oil or hazardous materials in harmful quantities in violation of Section 311 (b) (3) of the Federal Water Pollution Control Act Amendments of 1972, 33 U.S.C. 1321 (b) (3) as referenced above. You are hereby requested to submit to EPA the following information:

(a) Time and date of discharge:

1055 hours, November 2, 1984

(b) Material(s) discharged:

lubrication oil

(c) Description of the vehicle or facility from which the material was discharged (i.e., pipeline, tank, well, etc.):

riprap

(d) Name and address of the owner/operator of the vehicle or facility described above in (c):

Virginia Electric and Power Company

Attention: Dr. John A. Taylor, Water Quality Department

P. O. Box 26666, Richmond, Virginia 23261

(e) Name and address of the operator of the vehicle or facility described above in (c) and, if different from (d) above, describe the relationship between the owner and operator (i.e., employee, subcontractor, lessee, etc.):

See (d) above

- (f) Location of the discharge, including county and state:

The discharge canal from North Anna Power Station,

Louisa County, Virginia

- (g) Quantity of material discharged from the facility or vehicle:

Approximately 1 quart

- (h) Did the material reach any water (YES or NO): Yes

Did the material reach any sewer (YES or NO): No

- (1) If YES, describe the first water reached and the location of this water:

The discharge canal leading to Lake Anna

- (2) State the quantity of material reaching the water described above in (h) (1):

Approximately 1 quart

- (3) State the quantity of material reaching the shoreline of the water described above in (1) which did not reach the water:

Unknown

- (4) Was the water described above in (h) (1), at the time of the spill, a tributary of, or physically connected to, any part or tributary of a riverine, hydrological or creek system? (YES or NO) Yes

- (5) If the answer to (4) is YES, describe or name the waterways to which the waters in (h) (1) connect or flow:

Lake Anna and the North Anna River

- (6) If the answer to (4) is NO, does the water described above in (h) (1) periodically connect with or flow into any tributary or part of any riverine, hydrological or creek system? If YES, describe the flow and connection:

N/A

- (i) Did the material cause any film, sheen, discoloration or iridescent appearance on the adjoining shorelines of, or surface of, any water described above in (3), (4), (5), or (6)? If YES, describe:

A slight sheen of oil was observed trapped in an eddy near a

permanently deployed boom around Outfall 004

- (j) Did the material cause any sludge or emulsion to be deposited on the adjoining shorelines of, or beneath the surface of, the waters described above in (3), (4), (5), or (6)? If YES, describe:

No

- (k) Does the facility have a NPDES Permit? (YES or NO) Yes

- (l) If you answered YES to (k) please supply NPDES Permit number:

VA 0052451

- (m) Did the discharge violate any applicable water quality standards, e.g., NPDES/ If YES, describe:

To the best of our knowledge no water quality standards were violated.

No analytical data was obtained.

- (n) Date and time of discovery that the discharge was reaching the waterway:

November 2, 1984 at 1055 hours

- (o) Describe in detail what actually caused the discharge:

The source of the oil is believed to be seepage from riprap on the

banks near Outfall 004 contaminated from a previous oil spill on

October 13, 1984. High winds caused an absorbent boom to lift and disperse a small amount of oil originally trapped behind the boom.

- (p) Describe any observed damage to animal life or vegetation:

None was observed

- (q) Describe steps taken to contain and clean up the spilled material and mitigate environmental damage:

A second boom was deployed to contain the oil and cleanup was effected with absorbent pads and Fiber Pearl.

- (r) List the federal and state agencies, if any, to which the owner or operator reported the discharge. Show the agency, its location, the date and time of notification the official contacted:

1) National Response Center, Washington, D. C. November 2, 1984 at 1531 (Paul Mackay)

2) State Water Control Board (SWCB), Valley Regional Office, November 29, 1984 at 1530 (Michelle Tilman)

- (s) List the state and local officials who were on-scene at the spill during or after clean up:

None

- (t) List the names and addresses of persons believed to have knowledge of the facts surrounding this incident:

E. W. Harrell, Station Manager, North Anna Power Station

P. O. Box 702

Mineral, Virginia 23117

- (u) List the type of oil and total storage capacities at the facility for any oil related products. Describe the storage tanks at the facility, e.g., above ground, underground, etc.:

See attached sheet

- (u) Describe action taken or proposed to prevent a recurrence of this type of spill:

Due to the nature of the spill, no specific action was taken.

- (v) Does the facility have a Spill Prevention Control and Countermeasures (SPCC) Plan certified and implemented in accordance with 40 CFR 112? YES or NO: Yes

- (w) List any other information you wish to bring to the attention of the federal government:


None


The above information should be mailed to :

US ENVIRONMENTAL PROTECTION AGENCY
REGION III
ENVIRONMENTAL EMERGENCY BRANCH (3HW22)
CURTIS BUILDING
6th & WALNUT STREETS
PHILADELPHIA, PA 19106

If you cannot answer this letter by February 25, 1985 or if there are any questions on this matter, you may call Carol Oleksiak at (215) 597-9898.

Sincerely yours,


Thomas Voltaggio, Chief
Superfund Branch

 for JOHN A. TAYLOR - MGR.
I hereby certify the above to be true and accurate to the best of my knowledge.

WATER QUAL

Location of Oils - North Anna Power Station OperationsFuel Oil - No. 2

1	5,000 bbl storage tank (210,000 gal)	Above ground
2	50,000 gallon storage tank	Below ground
4	1,000 gallon day tanks	Diesel Generator Room
	Maximum Storage Capacity	314,000 gallons
	Average Daily Usage	6,000 gallons
	Average Daily Received	6,000 gallons
1	250 gallon fire pump-tank	Within Service water pump house
1	270 gallon fire pump-tank	Within Warehouse No. 5 pump house

Lubricating Oil

2	16,000 gallon storage tank	Within Turbine Building
2	14,000 gallon storage tank	Within Turbine Building
2	2,000 gallon storage tank	Within Turbine Building
2	200 gallon storage tank	Within Turbine Building
	Maximum Storage Capacity	64,000 gallons

Gasoline (Outside security fence - Adjacent to Warehouse No. 2)

1	3,000 gallon tank (regular)	Below ground
1	1,000 gallon tank (unleaded)	Below ground

Transformers

4	18 MVA Station transformers	Cooling water intake structure
3	330 MVA Main station transformers	North side of Turbine Building
6	15 MVA Station service transformers	North side of Turbine Building

Location of Oils - North Anna Unit 3 ConstructionFuel Oil - Diesel

1	7,500 gallon tank (fuel depot)	Below ground
1	7,500 gallon tank (Warehouse No. 1)	Below ground

Gasoline

1	10,000 gallon tank (fuel depot)	Below ground
---	---------------------------------	--------------