

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)
Browns Ferry - Unit 3

DOCKET NUMBER (2)

0 5 0 0 0

PAGE (3)

1 OF 0 2

TITLE (4)

Late Performance of Surveillance Test

EVENT DATE (6)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)														
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)													
0	1	2	2	8	5	8	5	0	0	4	0	0	0	2	2	1	8	5	0	5	0	0	0

OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)																	
POWER LEVEL (10)	1	0	0	20.402(b)				20.406(e)				50.73(a)(2)(iv)				73.71(b)			
				20.406(a)(1)(i)				50.36(a)(1)				50.73(a)(2)(v)				73.71(c)			
				20.406(a)(1)(ii)				50.36(a)(2)				50.73(a)(2)(vi)				OTHER (Specify in Abstract below and in Text, NRC Form 368A)			
				20.406(a)(1)(iii)				50.73(a)(2)(i)				50.73(a)(2)(viii)(A)							
				20.406(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(B)							
				20.406(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(x)							

LICENSEE CONTACT FOR THIS LER (12)
NAME
D. L. Smith

TELEPHONE NUMBER

AREA CODE

2 0 5 7 2 9 - 3 8 6 5

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE)		NO		EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR
		X					

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

During normal operation, a surveillance instruction was not performed within its required frequency band. It was performed one day late with no problems during performance. This was a random event with minor procedural revisions initiated to preclude recurrence.

8502260421 850221
PDR ADOCK 05000296
S PDR

IE22

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Browns Ferry - Unit 3	DOCKET NUMBER (2) 0 5 0 0 0 2 9 6 8 5 - 0 1 0 4 - 0 0 0 2 OF 0 2	LER NUMBER (8)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			

TEXT (If more space is required, use additional NRC Form 368A's) (17)

Unit 1 was in a short outage, unit 2 was in a refueling outage, and unit 3 was operating at 100 percent.

Surveillance Instruction 4.3.A.2, Control Rod Drive (AA) exercise, was performed one day beyond the allowable Technical Specification extension times. The senior reactor operator, without the benefit of recent Surveillance Instruction performance dates, determined that the proposed performance date was within the Technical Specification frequency allowances.

The Surveillance Instruction was performed with no problems. The affected senior reactor operator was cautioned to more carefully apply frequency requirements in the future. In the future, all performance dates for the three previous Surveillance Instruction performances will be obtained prior to assessing an extension.

No further corrective action is required.

Responsible Plant Section - N/A

Previous Events - None

TENNESSEE VALLEY AUTHORITY

Browns Ferry Nuclear Plant

P. O. Box 2000

Decatur, Alabama 35602

February 21, 1985

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555


Dear Sir:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT (BFN) UNIT 3 -
DOCKET NO. 50-296 - FACILITY OPERATING LICENSE DPR-68 - REPORTABLE
OCCURRENCE REPORT BFRO-50-296/85004

The enclosed report provides details concerning the late performance of
Surveillance Test. This report is submitted in accordance with
10 CFR 50.73 (a)(2)(i).

Very truly yours,

TENNESSEE VALLEY AUTHORITY



G. T. Jones
Plant Manager
Browns Ferry Nuclear Plant

Enclosures

cc (Enclosures):

Regional Administrator
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 2900
Atlanta, Georgia 30303

INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

NRC Resident Inspector, BFN

IE22
1/1