

Duke Power Company
Catawba Nuclear Generation Department
4800 Concord Road
York, SC 29745

WILLIAM R. McCOLLUM, JR.
Vice President
(803) 831-3200 Office
(803) 831-3426 Fax



DUKE POWER

April 16, 1996

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Catawba Nuclear Station, Units 1
Request For Additional Information - Response
Request For Relief 94-05 Second
Ten Year Interval Inservice Inspection Program
Plan
Docket Nos. 50-413

Re: Request For Additional Information Letter from U.S.
NRC, dated 19 March 1996, to W. R. McCollum, Catawba
Site Vice President

Gentlemen:

Per your Request For Additional Information, the following
is Catawba's response:

The reactor pressure vessel outlet nozzles were examined during the first period (EOC2) of the first inspection interval in **October, 1987**. This examination met the first ten year inspection requirements of ASME Section XI, 1980 Edition, W81 Addenda. The outlet nozzles were again examined during the third (last) period (EOC7) of the first interval in **November 1993**. This Examination was done in conjunction with the 10 Year Reactor Vessel Examination. We will be taking credit for these outlet nozzle examinations in the first period of the second ten year interval.

The outlet nozzles are scheduled for examination during the third period (EOC14) of the second inspection interval, in conjunction with the second interval 10 Year Reactor Vessel Examination. This is scheduled for **June, 2003**.
Document Control Desk

9604250116 960416
PDR ADOCK 05000413
G PDR

3024

40471/0

Page 2
April 16, 1996


The 10 year time interval will not be exceeded as shown below:

Outlet Nozzle Exam (completed)	EOC2	October, 1987
Outlet Nozzle Exam (completed)	EOC7	November, 1993
Outlet Nozzle Exam (scheduled)	EOC14	June, 2003

As requested by the referenced letter, a copy of this response is being sent to Mr. Michael T. Anderson, INEL Research Center.

Should there be any questions concerning this response, please call D. Tower at (803) 831-3419.

Very truly yours,



William R. McCollum, Jr.
Vice President
Catawba Nuclear Station

xc:

S.D. Ebnetter, Regional Administrator
Region II

R.J. Freudenberger, Senior Resident Inspector
Catawba Nuclear Station

R.E. Martin, Senior Project Manager
ONRR

M. T. Anderson
INEL Reasearch Center
2151 North Boulevard
P.O. Box 1625
Idaho Falls, Idaho
83415-2209

Document Control Desk
Page 3
April 3, 1996

bxc:

G. R. Peterson	CN01SM
D.X Tower	CN01RC
G.A. Copp	EC050
J.E. Snyder	MG01RC
J.S. Forbes	CN01EG
M.S. Kitlan	CN01RC
P.R. Newton	PB05A
ELL	EC050
NCMPA-1	
NCEMC	
PMPA	
SREC	
Document Control File	CN-801.01
Group File	CN-801.01