



Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004

THOMAS P. NOONAN
Division Vice President
Nuclear Operations

(412) 393-7622
Fax (412) 393-4905

April 23, 1996
NPD1VPO:0465

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, Licensee No. DPR-66
LER-96-004-00

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Duquesne Light Co. (DLC), Beaver Valley Power Station, has developed a review plan in response to Generic Letter (GL) 96-01, "Testing of Safety-Related Logic Circuits". The completion dates for the reviews are included in the DLC response to the Commission dated April 4, 1996.

As a result of these reviews, certain findings may fall under the reportability criteria established by 10 CFR 50.73 (Licensee Event Reports). Upon discovery of the first reportable condition resulting from the GL 96-01 reviews, DLC intends to prepare one Licensee Event Report (LER) for each unit, as necessary, and subsequently submit a monthly update covering the reportable findings discovered for each respective unit since the previous report. Upon completion of the GL 96-01 reviews, the single LER (with monthly updates) process will be stopped and the Commission will be notified of the LER closure. At this point, the normal LER reporting practices will continue. DLC Management remains aware of the reporting requirements beyond 10 CFR 50.73 and will continue to comply with these requirements.

In accordance with Appendix A, Beaver Valley Technical Specifications, the following Licensee Event Report is submitted:

LER 96-004-00, Unit 1, Incorrect Test Frequency of Safety Related Logic (GL 96-01), reportable in accordance with 10 CFR 50.73 a.2.i.B, (Condition Prohibited by Technical Specifications". An update will be submitted by May 24, 1996.

T. P. Noonan
Division Vice President
Nuclear Operations/Plant Manager

DAW/nlc

Attachment

9604290058 960423
PDR ADOCK 05000334
S PDR



April 23, 1996
NPD1VPO:0465
Page 2

cc: Mr. T. T. Martin, Regional Administrator
United States Nuclear Regulatory Commission
Region 1
475 Allendale Road
King of Prussia, PA 19406

Mr. D. S. Brinkman
BVPS Licensing Project Manager
United States Nuclear Regulatory Commission
Washington, DC 20555

Mr. Larry Rossbach
BVPS Senior Resident Inspector
United States Nuclear Regulatory Commission

Mr. J. A. Hultz
Ohio Edison Company
76 S. Main Street
Akron, OH 44308

Mr. Mark Burns
Centerior Energy Corporation
6200 Oak Tree Boulevard
Independence, OH 44101-4661

INPO Records Center
700 Galleria Parkway
Atlanta, GA 30339-5957

Mr. Robert Maiers
Department of Environmental Resources
P.O. Box 8469
State Office Building, 13th Floor
Harrisburg, PA 17105-8469

Director, Safety Evaluation & Control
Virginia Electric & Power Company
P.O. Box 26666
One James River Plaza
Richmond, VA 23261