

3.1 REACTIVITY CONTROL SYSTEMS

3.1.7 Standby Liquid Control (SLC) System

LCO 3.1.7 Two SLC subsystems shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One SLC subsystem inoperable.	A.1 Restore SLC subsystem to OPERABLE status.	7 days
B. Two SLC subsystems inoperable.	B.1 Restore one SLC subsystem to OPERABLE status.	8 hours
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 3.	12 hours

Table 3.3.2.1-1 (page 1 of 1)
Control Rod Block Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	SURVEILLANCE REQUIREMENTS
1. Rod Pattern Control System			
a. Rod withdrawal limiter	(a)	2	SR 3.3.2.1.1 SR 3.3.2.1.6 SR 3.3.2.1.9
	(b)	2	SR 3.3.2.1.2 SR 3.3.2.1.5 SR 3.3.2.1.7 SR 3.3.2.1.9
b. Rod pattern controller	(c)	2	SR 3.3.2.1.3 SR 3.3.2.1.4 SR 3.3.2.1.5 SR 3.3.2.1.7 SR 3.3.2.1.9
2. Reactor Mode Switch - Shutdown Position	(d)	2	SR 3.3.2.1.8

(a) THERMAL POWER > 70% RTP.

(b) THERMAL POWER > 35% RTP and \leq 70% RTP.

(c) With THERMAL POWER \leq 20% RTP.


(d) Reactor mode switch in the shutdown position.

Table 3.3.3.1-1 (page 1 of 1)
Post Accident Monitoring Instrumentation

FUNCTION	REQUIRED CHANNELS	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1
1. Reactor Steam Dome Pressure	2	E
2. Reactor Vessel Water Level—Wide Range	2	E
3. Reactor Vessel Water Level—Fuel Zone	2	E
4. Suppression Pool Water Level	2	E
5. Suppression Pool Sector Water Temperature	2(c)	E
6. Drywell Pressure	2	E
7. Drywell Air Temperature	2	E
8. Primary Containment/Drywell Area Gross Gamma Radiation Monitors	2	F
9. Penetration Flow Path, PCIV Position	2 per penetration flow path (a)(b)	E
10. Primary Containment and Drywell H ₂ Concentration Analyzer and Monitor	2	E
11. Primary Containment Pressure	2	E
12. Primary Containment Air Temperature	2	E

- (a) Not required for isolation valves whose associated penetration flow path is isolated.
- (b) Only one position indication channel is required for penetration flow paths with only one installed control room indication channel.
- (c) Monitoring each of eight sectors.

Table 3.3.5.1-1 (page 3 of 5)
Emergency Core Cooling System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER FUNCTION	CONDITIONS REFERENCED FROM REQUIRED ACTION A.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. LPCI B and LPCI C Subsystems (continued)					
e. LPCI Pump B and LPCI Pump C Discharge Flow - Low (Bypass)	1,2,3, 4(a),5(a)	1 per pump	E	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.3 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 1450 gpm
f. Manual Initiation	1,2,3, 4(a),5(a)	1	C	SR 3.3.5.1.6	NA
3. High Pressure Core Spray (HPCS) System					
a. Reactor Vessel Water Level - Low Low, Level 2	1,2,3, 4(a),5(a)		B	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.3 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 127.6 inches
b. Drywell Pressure - High	1,2,3		B	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.3 SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 1.88 psig
c. Reactor Vessel Water Level - High, Level 2	1,2,3, 4(a),5(a)	4	B	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.3 SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 221.7 inches
d. Condensate Storage Tank Level - Low	1,2,3, 4(c),5(c)	2	D	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.3 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 59,700 gallons
e. Suppression Pool Water Level - High	1,2,3	2	D	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.3 SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 18 ft 6 inches

(continued)

(a) When associated subsystem(s) are required to be OPERABLE.

(b) Also required to initiate the associated diesel generator, and AECG subsystem.

(c) When HPCS is OPERABLE for compliance with LCO 3.5.2, "ECCS - Shutdown," and aligned to the condensate storage tank while tank water level is not within the limits of SR 3.5.2.2.

Primary Containment and Drywell Isolation Instrumentation

3.3.6.1

Table 3.3.6.1-1 (page 1 of 6)
 Primary Containment and Drywell Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Main Steam Line Isolation					
a. Reactor Vessel Water Level - Low Low Low, Level 1	1,2,3	2	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.6	≥ 14.3 inches
b. Main Steam Line Pressure - Low	1	2	E	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.6	≥ 795.0 psig
c. Main Steam Line Flow - High	1,2,3	2 per MSL	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 191 psid
d. Condenser Vacuum - Low	1,2 ^(b) , 3 ^(a)	2	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≥ 7.6 inches Hg vacuum
e. Main Steam Line Pipe Tunnel Temperature - High	1,2,3	2	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 158.9°F
f. Main Steam Line Turbine Building Temperature - High	1,2,3	2	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5	≤ 138.9°F
g. Manual Initiation	1,2,3	2	G	SR 3.3.6.1.5	NA
2. Primary Containment and Drywell Isolation					
a. Reactor Vessel Water Level - Low Low, Level 2	1,2,3	2 ^(b)	H	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≥ 127.6 inches

Increase font size of superscript

(continued)

(a) With any turbine stop valve not closed.

(b) Required to initiate the associated drywell isolation function.

Primary Containment and Drywell Isolation Instrumentation

3.3.6.1

Table 3.3.6.1-1 (page 2 of 6)
Primary Containment and Drywell Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. Primary Containment and Drywell Isolation					
a. Reactor Vessel Water Level—Low Low, Level 2 (continued)	(c)	(10)	L	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≥ 127.6 inches
b. Drywell Pressure—High	1,2,3	(10)	H	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≤ 1.88 psig
c. Reactor Vessel Water Level—Low Low Low, Level 1 (ECCS Divisions 1 and 2)	1,2,3	(10)	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≥ 14.3 inches
d. Drywell Pressure—High (ECCS Divisions 1 and 2)	(c)	(10)	L	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≥ 14.3 inches
	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≤ 1.88 psig
e. Reactor Vessel Water Level—Low Low, Level 2 (HPCS)	1,2,3	4	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≥ 127.6 inches
f. Drywell Pressure—High (HPCS)	(c)	4	L	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≥ 127.6 inches
	1,2,3	4	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≤ 1.88 psig
g. Containment and Drywell Purge Exhaust Plenum Radiation—High	1,2,3	(10)	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5	≤ 4.0 mR/hr above background

Increase Font size of Superscripts

(b) Required to initiate the drywell isolation function.

(c) During CORE ALTERATIONS, and operations with a potential for draining the reactor vessel.

Primary Containment and Drywell Isolation Instrumentation

3.3.6.1

Table 3.3.6.1-1 (page 3 of 3)
Primary Containment and Drywell Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. Primary Containment and Drywell Isolation					
g. Containment and Drywell Purge Exhaust Plenum Radiation - High (continued)	(d)	2	K	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5	≤ 4.0 mR/hr above background
h. Manual Initiation	1,2,3 (d)	2	G K	SR 3.3.6.1.5 SR 3.3.6.1.5	NA NA
3. Reactor Core Isolation Cooling (RCIC) System Isolation					
a. RCIC Steam Line Flow - High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≤ 298.5 inches water
b. RCIC Steam Line Flow Time Delay	1,2,3	1	F	SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5	≥ 3 seconds and ≤ 13 seconds
c. RCIC Steam Supply Line Pressure - Low	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≥ 55 psig
d. RCIC Turbine Exhaust Diaphragm Pressure - High	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≤ 20 psig
e. RCIC Equipment Area Ambient Temperature - High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	$\leq 145.9^{\circ}\text{F}$
f. Main Steam Line Pipe Tunnel Temperature - High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	$\leq 158.9^{\circ}\text{F}$

(continued)

(b) Required to initiate the drywell isolation function.

(d) During CORE ALTERATIONS, operations with a potential for draining the reactor vessel, and movement of irradiated fuel assemblies in primary containment.

Primary Containment and Drywell Isolation Instrumentation

3.3.6.1

Table 3.3.6.1-1 (page 6 of 6)
Primary Containment and Drywell Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
5. RHR System Isolation					
a. RHR Equipment Area Ambient Temperature - High	2 ^(a) , 3 ^(e)	1 per area	F	SR 3.3.6.1.1 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 159.9°F
b. Reactor Vessel Water Level-Low, Level 3	1, 2 ^(g) , 3 ^(g)	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≥ 177.1 inches
	2 ^(e) , 3 ^(e) , 4, 5	2 ^(f)	J	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≥ 177.1 inches
c. Reactor Vessel Steam Dome Pressure - High	1, 2, 3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.6.1.1.3 SR 3.6.1.1.4 SR 3.6.1.1.5	≤ 150 psig
d. Drywell Pressure - High	1, 2, 3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.4 SR 3.3.6.1.5	≤ 1.88 psig
e. Manual Initiation	1, 2, 3	2	G	SR 3.3.6.1.5	NA

- (e) With reactor vessel steam dome pressure less than the RHR cut in permissive pressure.
(f) Only one trip system required in MODES 4 and 5 with RHR Shutdown Cooling System integrity maintained.
(g) With reactor steam dome pressure greater than or equal to the RHR cut in permissive

vessel

pressure.

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.1 Recirculation Loops Operating

LCO 3.4.1

a. Either:

Two recirculation loops shall be in operation with:

1. Matched flows; and
2. Total core flow and THERMAL POWER within limits.

OR

b. One recirculation loop shall be in operation with:

1. Thermal power \leq 2500 MWt;
2. Total core flow and THERMAL POWER within limits;
3. Required limits modified for single recirculation loop operation as specified in the COLR; and
4. LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation," Function 2.b (Average Power Range Monitors Flow Biased Simulated Thermal Power—High) Allowable Value of Table 3.3.1.1-1 reset for single loop operation.

-----NOTE-----
Required limit and setpoint modifications for single recirculation loop operation may be delayed for up to 12 hours after transition from two recirculation loop operation to single recirculation loop operation.

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Recirculation loop jet pump flow mismatch not within limits.	A.1 Shut down one of the recirculation loops.	2 hours

(continued)

RHR Shutdown Cooling System—Cold Shutdown
3.4.10

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. No RHR shutdown cooling subsystem in operation. <u>AND</u> No recirculation pump in operation.	B.1 Verify reactor coolant circulating ^{circulation} by an alternate method.	1 hour from discovery of no reactor coolant circulation <u>AND</u> Once per 12 hours thereafter
	<u>AND</u> B.2 Monitor reactor coolant temperature and pressure.	Once per hour

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.10.1 Verify one RHR shutdown cooling subsystem or recirculation pump is operating.	12 hours

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.4.11.8 -----NOTE----- Only required to be met in single loop operation during increases in THERMAL POWER or recirculation loop flow with the operating recirculation loop jet pump flow $\leq 50\%$ of rated core flow or THERMAL POWER $\leq 30\%$ of RTP, and with reactor vessel steam dome pressure ≥ 25 psig.</p> <p>Verify the difference between the bottom head coolant temperature and the RPV temperature is $\leq 100^{\circ}\text{F}$.</p> <p style="text-align: center;">coolant</p>	<p>Once within 15 minutes prior to an increase in THERMAL POWER or an increase in loop flow</p>
<p>SR 3.4.11.9 -----NOTE----- Only required to be met in single loop operation during increases in THERMAL POWER or recirculation loop flow with the operating recirculation loop jet pump flow $\leq 50\%$ of rated core flow, or THERMAL POWER $\leq 30\%$ of RTP, and the idle recirculation loop not isolated from the RPV.</p> <p>Verify the difference between the reactor coolant temperature in the recirculation loop not in operation and the RPV coolant temperature is $\leq 50^{\circ}\text{F}$.</p>	<p>Once within 15 minutes prior to an increase in THERMAL POWER or an increase in loop flow</p>
<p>SR 3.4.11.10 The reactor vessel material surveillance specimens shall be removed and examined to determine changes in reactor pressure vessel material properties.</p>	<p>In accordance with the schedule required by 10 CFR 50, Appendix H</p>

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	C.3 Restore air lock to OPERABLE status.	24 hours
D. Required Action and associated Completion Time of Condition A, B, or C not met in MODE 1, 2, or 3.	D.1 Be in MODE 3.	12 hours
	<u>AND</u> D.2 Be in MODE 4.	36 hours
E. Required Action and associated Completion Time of Condition A, B, or C not met during movement of recently irradiated fuel assemblies in the primary containment, or OPDRVs. <u>during</u>	E.1 Suspend movement of recently irradiated fuel assemblies in the primary containment.	Immediately
	<u>AND</u> E.2 Initiate action to suspend OPDRVs.	Immediately

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.3.11 -----NOTE----- Only required to be met in MODES 1, 2, and 3.</p> <p>Verify combined leakage rate of 1 gpm times the total number of PCIVs through hydrostatically tested lines that penetrate the primary containment is not exceeded when these isolation valves are tested at $\geq 1.1 P_a$.</p>	<p>-----NOTE----- SR 3.0.2 is not applicable</p> <p>In accordance with 10 CFR 50, Appendix J, as modified by approved exemptions</p>
<p>SR 3.6.1.3.12 -----NOTE----- Only required to be met in MODES 1, 2, and 3.</p> <p>Verify each outboard 42 inch primary containment purge valve is blocked to restrict the valve from opening $> 50^\circ$.</p>	<p>18 months</p>
<p>SR 3.6.1.3.13 -----NOTE----- Not required to be met when the Backup Hydrogen Purge System isolation valves are open for pressure control, ALARA or air quality considerations for personnel entry, or Surveillances or special testing of the Backup Hydrogen Purge System that require the valves to be open.</p> <p>Verify each 2 inch Backup Hydrogen Purge System isolation valve is closed.</p>	<p>31 days</p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Required Action and associated Completion Time of Condition A not met or in MODE 1, 2, or 3.	B.1 Be in MODE 3. <u>AND</u>	12 hours
	B.2 Be in MODE 4.	36 hours
C. Required Action and associated Completion Time of Condition A not met during movement of irradiated fuel assemblies in the primary containment, CORE ALTERATIONS, <u>and</u> OPDRVs. <i>during</i> <i>or during</i>	C.1 Suspend movement of irradiated fuel assemblies in the primary containment. <u>AND</u>	Immediately
	C.2 Suspend CORE ALTERATIONS. <u>AND</u>	Immediately
	C.3 Initiate action to suspend OPDRVs.	Immediately

SURVEILLANCE REQUIREMENT

SURVEILLANCE	FREQUENCY
SR 3.6.1.12.1 Verify containment average temperature-to-relative humidity to be within limits.	24 hours

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
SR 3.6.3.2.4 Verify each required igniter in in accessible areas develops a surface temperature of $\geq 1700^{\circ}\text{F}$.	18 months

No changes proposed to this page.
Submitted for reference only.

PY-CEI/NRR-1999L
Attachment 2
Page 16 of 34

SCIVs
3.6.4.2

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition A or B not met during movement of irradiated fuel assemblies in the primary containment, during CORE ALTERATIONS, or during OPDRVs.	D.1 Suspend movement of irradiated fuel assemblies in the primary containment.	Immediately
	<u>AND</u>	
	D.2 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	D.3 Initiate action to suspend OPDRVs.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.6.4.2.1</p> <p>-----NOTES-----</p> <ol style="list-style-type: none"> Valves and blind flanges in high radiation areas may be verified by use of administrative means. Not required to be met for SCIVs that are open under administrative controls. <p>-----</p> <p>Verify each secondary containment isolation manual valve and blind flange that is required to be closed during accident conditions is closed.</p>	31 days

3.6 CONTAINMENT SYSTEMS

3.6.5.3 Drywell Isolation Valves

LCO 3.6.5.3 Each drywell isolation valve, except for Drywell Vacuum Relief System valves, shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

- NOTES-----
1. Penetration flow paths, except for the 24 inch and 36 inch purge supply and exhaust valve penetration flow path, may be unisolated intermittently under administrative controls.
 2. Separate Condition entry is allowed for each penetration flow path.
 3. Enter applicable Conditions and Required Actions for systems made inoperable by drywell isolation valves.
 4. Enter applicable Conditions and Required Actions of LCO 3.6.5.1, "Drywell," when drywell isolation valve leakage results in exceeding overall drywell bypass leakage rate acceptance criteria.
-

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more penetration flow paths with one drywell isolation valve inoperable.	<p>A.1 Isolate the affected penetration flow path by use of at least one close ^{closed} and de-activated automatic valve, closed manual valve, blind flange, or check valve with flow through the valve secured.</p> <p><u>AND</u></p>	<p>8 hours</p> <p>(continued)</p>

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	<p>A.2 -----NOTE----- Isolation devices in high radiation areas may be verified by use of administrative means. -----</p> <p>Verify the affected penetration flow path is isolated.</p>	Prior to entering MODE 2 or 3 from MODE 4, if not performed within the previous 92 days
<p>B. One or more penetration flow paths with two drywell isolation valves inoperable.</p> <p>Closed manual valve, <u>Check</u> valve</p>	<p>B.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, blind flange, or <u>check</u> valve with flow through the <u>valve</u> secured.</p>	4 hours
C. Required Action and associated Completion Time not met.	<p>C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 4.</p>	<p>12 hours 36 hours</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.5.3.1 Verify each 24 inch and 36 inch drywell purge supply and exhaust isolation valve is sealed closed.	31 days
<div data-bbox="190 685 365 765" data-label="Text"> <p>Deleted.</p> </div> <div data-bbox="474 620 1166 1082" data-label="Text"> <p>-----NOTE----- Not required to be met when the Backup Hydrogen Purge System isolation valves are open for pressure control, ALARA or air quality considerations for personnel entry, or Surveillances or special testing of the Backup Hydrogen Purge System that require the valves to be open. Verify each 2 inch Backup Hydrogen Purge System isolation valve is closed. </p> </div>	<div data-bbox="1198 987 1356 1045" data-label="Text"> <p>31 days</p> </div>
SR 3.6.5.3.3 -----NOTES----- 1. Valves and blind flanges in high radiation areas may be verified by use of administrative means. 2. Not required to be met for drywell isolation valves that are open under administrative controls. Verify each drywell isolation manual valve and blind flange that is required to be closed during accident conditions is closed.	Prior to entering MODE 2 or 3 from MODE 4, if not performed in the previous 92 days

(continued)

3.7 PLANT SYSTEM

3.7.3 Control Room Emergency Recirculation (CRER) System

LCO 3.7.3 Two CRER subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of irradiated fuel assemblies in the primary
containment or fuel handling building,
During CORE ALTERATIONS,
During operations with a potential for draining the reactor
vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One CRER subsystem inoperable.	A.1 Restore CRER subsystem to OPERABLE status.	7 days
B. Required Action and Associated Completion Time of Condition A not met in MODE 1, 2, or 3.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

(continued)

3.7 PLANT SYSTEMS

3.7.4 Control Room Heating, Ventilating, and Air Conditioning (HVAC) System

LCO 3.7.4 Two control room HVAC subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of irradiated fuel assemblies in the primary
containment or fuel handling building,
During CORE ALTERATIONS,
During operations with a potential for draining the reactor
vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One control room HVAC subsystem inoperable.	A.1 Restore control room HVAC subsystem to OPERABLE status.	30 days
B. Two control room HVAC subsystems inoperable.	B.1 Verify control room air temperature is $\leq 90^{\circ}\text{F}$.	Once per 4 hours
	<u>AND</u> B.2 Restore one control room HVAC subsystem to OPERABLE status.	7 days
C. Required Action and Associated Completion Time of Condition A or B not met in MODE 1, 2, or 3.	C.1 Be in MODE 3.	12 hours
	<u>AND</u> C.2 Be in MODE 4.	36 hours

(continued)

Fuel Handling Building Ventilation Exhaust System
3.7.9

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.9.1	Operate each FHB ventilation exhaust subsystem for ≥ 10 continuous hours with heaters operating.	31 days
SR 3.7.9.2	Perform FHB ventilation exhaust filter testing in accordance with the Ventilation Filter Testing <u>program</u> (VFTP).	In accordance with the VFTP
SR 3.7.9.3	Perform a system functional test.	18 months
SR 3.7.9.4	Perform a CHANNEL FUNCTIONAL TEST of the FHB ventilation exhaust radiation monitor (noble gas)	92 days

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.3</p> <p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. DG loadings may include gradual loading as recommended by the manufacturer. 2. Momentary transients outside the load range do not invalidate this test. 3. This Surveillance shall be conducted on only one DG at a time. 4. This SR shall be preceded by, and immediately follow, without shutdown, a successful performance of SR 3.8.1.2 or SR 3.8.1.7. <p>-----</p> <p>Verify each DG operates for ≥ 60 minutes at a load ≥ 5600 kW and ≤ 7000 kW for Division 1 and 2 DGs, and ≥ 2600 kW for Division 3 DG.</p>	<p>As specified in Table 3.8.1-1</p>
<p>SR 3.8.1.4</p> <p>Verify each day tank contains $\geq \textcircled{316}$ gal of fuel oil for Divisions 1 and 2 and $\geq \textcircled{260}$ gal for Division 3.</p> <p>$\textcircled{279}$</p>	<p>31 days</p>
<p>SR 3.8.1.5</p> <p>Check for and remove accumulated water from each day tank.</p>	<p>31 days</p>
<p>SR 3.8.1.6</p> <p>Verify the fuel oil transfer system operates to automatically transfer fuel oil from the storage tank to the day tank.</p>	<p>31 days</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.9</p> <p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. This Surveillance shall not be performed in MODE 1 or 2. However, credit may be taken for unplanned events that satisfy this SR. 2. If performed with DG synchronized with offsite power, it shall be performed at a power factor ≤ 0.9. <p>a load</p> <p>Verify each DG rejects greater than or equal to its associated single largest post-accident load. Following load rejection, engine speed is maintained less than nominal plus 75% of the difference between nominal speed and the overspeed trip setpoint, or 15% above nominal, whichever is less.</p>	<p>18 months</p>
<p>SR 3.8.1.10</p> <p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Momentary transients outside the load and power factor ranges do not invalidate this test. 2. This Surveillance shall not be performed in MODE 1 or 2. However, credit may be taken for unplanned events that satisfy this SR. <p>Verify each DG operating at a power factor ≤ 0.9 does not trip and voltage is maintained ≤ 4784 V for Division 1 and 2 DGs and ≤ 5000 V for Division 3 DG during and following a load rejection of a load ≥ 5600 kW for Division 1 and 2 DGs and ≥ 2600 kW for Division 3 DG.</p>	<p>18 months</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.12 -----NOTES-----</p> <ol style="list-style-type: none"> 1. All DG starts may be preceded by an engine prelube period. 2. This Surveillance shall not be performed in MODE 1 or 2. However, credit may be taken for unplanned events that satisfy this SR. <p>-----</p> <p>Verify on an actual or simulated Emergency Core Cooling System (ECCS) initiation signal each DG auto-starts from standby condition and:</p> <ol style="list-style-type: none"> a. In ≤ 10 seconds for Divisions 1 and 2, and ≤ 13 seconds for Division 3 after auto-start and during tests, achieves voltage ≥ 3900 V and ≤ 4400 V; b. In ≤ 10 seconds for Divisions 1 and 2, and ≤ 13 seconds for Division 3 after auto-start and during tests, achieves frequency ≥ 58.8 Hz and ≤ 61.2 Hz; <u>and</u> c. Operates for ≥ 5 minutes <u>cc</u> 	<p>18 months</p>
<p>SR 3.8.1.13 -----NOTE-----</p> <p>This Surveillance shall not be performed in MODE 1, 2, or 3. However, credit may be taken for unplanned events that satisfy this SR.</p> <p>-----</p> <p>Verify each DG's automatic trips are bypassed on an actual or simulated ECCS initiation signal except:</p> <ol style="list-style-type: none"> a. Engine overspeed; and b. Generator differential current. 	<p>18 months</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.20</p> <p>-----NOTE----- All DG starts may be preceded by an engine prelube period.</p> <p>Verify, when started simultaneously from standby condition, the Division 1 and 2 DGs achieve voltage ≥ 3900 V and ≤ 4400 V and frequency ≥ 58.8 Hz and ≤ 61.2 Hz in ≤ 10 seconds, and the Division 3 DG achieves a frequency ≥ 58.8 Hz in ≤ 10 seconds, and a voltage ≥ 3900 V and ≤ 4400 V and frequency ≥ 58.8 Hz and ≤ 61.2 Hz in ≤ 13 seconds .</p>	<p>10 years</p>

3.8 ELECTRICAL POWER SYSTEMS

3.8.5 DC Sources—Shutdown

LCO 3.8.5

The following DC electrical power subsystems shall be OPERABLE:

- a. One Class 1E DC electrical power subsystem capable of supplying one division of the Division 1 or 2 onsite Class 1E electrical power distribution subsystem(s) required by LCO 3.8.8, "Distribution Systems - Shutdown";
- b. One Class 1E battery or battery charger, other than the DC electrical power subsystem in LCO 3.8.5.a, capable of supplying the remaining Division 1 or Division 2 onsite Class 1E DC electrical power distribution subsystem when required by LCO 3.8.8; and
- c. ^{power} The Division 3 DC electrical power subsystem capable of supplying the Division 3 onsite Class 1E DC electrical distribution subsystem when the Division 3 onsite Class 1E DC electrical power distribution subsystem is required by LCO 3.8.8.

APPLICABILITY: MODES 4 and 5,
During movement of irradiated fuel assemblies in the primary containment or fuel handling building.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.2.2 Suspend movement of irradiated fuel assemblies in the primary containment and fuel handling building.	Immediately
	AND	
	A.2.2 Suspend movement of irradiated fuel assemblies in the primary containment and fuel handling building.	Immediately
	AND	
	A.2.3 Initiate action to suspend operations with a potential for draining the reactor vessel.	Immediately
	AND	
	A.2.4 Initiate action to restore required DC electrical power subsystems to OPERABLE status.	Immediately

4.0 DESIGN FEATURES (continued)

4.3 Fuel Storage

4.3.1 Criticality

4.3.1.1 The spent fuel storage racks are designed and shall be maintained with:

- a. $k_{eff} \leq 0.95$ if fully flooded with unborated water, which includes an allowance for uncertainties as described in Section 9.1.2 of the USAR;
- b. A nominal fuel assembly center to center storage spacing of 7 inches within rows and 12 inches between rows in the storage racks in the upper containment pool; and

with c. A nominal fuel assembly center to center storage spacing of 6.625 inches, within a neutron poison material between storage spaces, in the high density storage racks in the fuel handling building.

4.3.1.2 The new fuel storage racks are designed and shall be maintained with:

- a. $k_{eff} \leq 0.95$ if fully flooded with unborated water, which includes an allowance for uncertainties as described in Section 9.1.1 of the USAR;

and

- b. A nominal 7 inch center to center distance between fuel assemblies placed in storage racks.

4.3.2 Drainage

The spent fuel storage pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 594 ft 6 inches.

4.3.3 Capacity

4.3.3.1 The spent fuel storage pool is designed and shall be maintained with a storage capacity limited to no more than 4020 fuel assemblies.

4.3.3.2 No more than 190 fuel assemblies may be stored in the upper containment pool.

5.0 ADMINISTRATIVE CONTROLS

5.1 Responsibility

5.1.1 The plant manager shall be responsible for overall unit operation and shall delegate in writing the succession to this responsibility during his absence.

The plant manager, or his designee, shall approve, prior to implementation, each proposed test, experiment, or modification to systems or equipment that affect nuclear safety, and all administrative procedures. (

5.1.2 The shift supervisor (SS) shall be responsible for the control room command function. During any absence of the SS from the control room while the unit is in MODE 1, 2, or 3, an individual with an active Senior Reactor Operator (SRO) license shall be designated to assume the control room command function. During any absence of the SS from the control room while the unit is in MODE 4 or 5, an individual with an active SRO license or Reactor Operator license shall be designated to assume the control room command function.

5.0 ADMINISTRATIVE CONTROLS

5.3 Unit Staff Qualifications

- 5.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions as modified by Specification 5.2.2.f, except for the radiation protection manager, who shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975. ² The licensed Reactor Operators and Senior Reactor Operators shall also meet or exceed ~~the minimum qualifications of the supplemental requirements specified in Sections A and C of Enclosure 1 of the March 28, 1980 NRC letter to all licensees.~~

and
, who
comply with the requirements of 10 CFR 55.

5.5 Programs and Manuals

5.5.4 Radioactive Effluent Controls Program (continued)

- f. Limitations on the functional capability and use of the liquid and gaseous effluent treatment systems to ensure that appropriate portions of these systems are used to reduce releases of radioactivity when the projected doses in a period of 31 days would exceed 2% of the guidelines for the annual dose or dose commitment, conforming to 10 CFR 50, Appendix I;
- g. Limitations on the dose rate resulting from radioactive material released in gaseous effluents to areas beyond the site boundary as follows:
 - 1. for noble gases: ≤ 500 mrem/yr to the total body and ≤ 3000 mrem/yr to the skin, and
 - 2. for iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half-lives > 8 days: ≤ 1500 mrem/yr to any organ;
- h. Limitations on the annual and quarterly air doses resulting from noble gases released in gaseous effluents from the unit to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I;
- i. Limitations on the annual and quarterly doses to a member of the public from iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half lives > 8 days in gaseous effluents released from the unit to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I; and
- j. Limitations on the annual dose or dose commitment to any member of the public due to releases of radioactivity and to radiation from uranium fuel cycle sources, conforming to 40 CFR 190.

5.5.5 Component Cyclic or Transient Limit

This program provides controls to track the USAR, Section 3.9.1.1, cyclic and transient occurrences to ensure that reactor vessel is maintained within the design limits.

the

(continued)

5.5 Programs and Manuals

5.5.7 Ventilation Filter Testing Program (VFTP) (continued)

- d. Demonstrate for each of the ESF systems that the pressure drop across the combined HEPA filters and the charcoal adsorbers is less than the value specified below when tested in accordance with Regulatory Guide 1.52, Revision 2, and ANSI N510-1980 at the system flowrate specified below $\pm 10\%$:

ESF Ventilation System	Delta P	Flowrate
a) Control Room Emergency Recirculation	4.9" H ₂ O	30,000 <u>scfm</u>
b) Fuel Handling Building	4.9" H ₂ O	15,000 <u>scfm</u>
c) Annulus Exhaust Gas Treatment	6.0" H ₂ O	2,000 <u>scfm</u>

- e. Demonstrate that the heaters for each of the ESF systems dissipate the value specified below $\pm 10\%$ when corrected to nominal input voltage when tested in accordance with ANSI N510-1980:

ESF Ventilation System	Wattage
a) Control Room Emergency Recirculation	100 kW
b) Fuel Handling Building	50 kW
c) Annulus Exhaust Gas Treatment	20 kW

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the VFTP test frequencies.

5.5.8 Explosive Gas and Storage Tank Radioactivity Monitoring Program

This program provides controls for potentially explosive gas mixtures contained in the main condenser offgas treatment system, and the quantity of radioactivity contained in unprotected outdoor liquid storage tanks.

The program shall include:

- a. The limits for concentrations of hydrogen in the main condenser offgas treatment system and a surveillance program to ensure the limits are maintained. Such limits shall be appropriate to the system's design criteria (i.e., whether or not the system is designed to withstand a hydrogen explosion); and

(continued)

5.7 High Radiation Area

5.7.2 (continued)

Individuals qualified in radiation protection procedures (e.g., health physics technicians) or personnel continuously escorted by such individuals may be exempt from the RWP issuance requirement during the performance of their assigned duties in high radiation areas with exposure rates ≤ 3000 mrem/hr, provided they are otherwise following plant radiation protection procedures for entry into such high radiation areas.

5.7.3

In addition to the requirements of Specification 5.7.1, for individual high radiation areas accessible to personnel with radiation levels such that a major portion of the body could receive in 1 hour a dose ≥ 1000 mrem that are located within large areas such as reactor containment, where no enclosure exists for purposes of locking, or that ~~cannot be~~ continuously guarded, and where no enclosure can be reasonably constructed around the individual area, that individual area shall be barricaded and conspicuously posted, and a flashing light shall be activated as a warning device.

5.7.4

In addition to the requirements and exemptions of Specifications 5.7.1 and 5.7.2 for individual areas accessible to personnel such that a major portion of the body could receive in 1 hour a dose > 3000 mrem, entry shall require an approved RWP which will specify dose rate levels in the immediate work area and the maximum allowable stay time for individuals in that area. In lieu of the stay time specification of the RWP, continuous surveillance, direct or remote, such as use of closed circuit TV cameras, may be made by personnel qualified in radiation protection procedures to provide positive exposure control over activities within the areas.

SIGNIFICANT HAZARDS CONSIDERATION

The standards used to arrive at a determination that a request for amendment involves no significant hazards consideration are included in the Commission's regulations, 10CFR50.92. This regulation states that a proposed amendment involves no significant hazards consideration if operation of the facility in accordance with the proposed amendment would not: (1) involve a significant increase in the probability or consequences of an accident previously evaluated; (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety.

The proposed changes have been reviewed with respect to these three factors and it has been determined that the proposed changes do not involve a significant hazard because:

1. The proposed changes do not involve a significant increase in the probability or consequences of an accident previously evaluated.

Eight of the proposed changes are administrative in nature and either correct errors or incorporate into the improved Technical Specifications a change which was approved by the NRC under Amendment 70 for the current Technical Specifications. Changing the classification of the Backup Hydrogen Purge System isolation valves from drywell isolation valves to primary containment isolation valves results in the same actions being taken in the event one of these valves is declared inoperable. However, the Completion Times are more restrictive for inoperable primary containment isolation valves than for inoperable drywell isolation valves. The proposed changes to the diesel generator fuel oil day tank minimum volumes provide more stringent requirements for operation of the facility to increase the reliability of the diesel generator fuel oil transfer pump operation. The more stringent requirements continue to ensure that the safety analysis and licensing basis are maintained. The proposed change to Specification 5.7.3 clarifies continuously guarding a high radiation area is an option, not a requirement. The proposed changes have been reviewed and determined to have no effect on accident conditions or assumptions.

Based on the above, the proposed changes do not significantly increase the probability or consequences of any accident previously evaluated.

2. The proposed changes do not create the possibility of a new or different kind of accident from any accident previously evaluated.

As stated above eight of the proposed changes are administrative in nature and do not increase the possibility of any new or different kind of accident. Changing the classification of the Backup Hydrogen Purge System isolation valves from drywell isolation valves to primary containment isolation valves results in the same actions being taken in the event one of these valves is declared inoperable. However, the Completion Times are more restrictive for inoperable primary containment isolation valves than for inoperable drywell isolation valves. The proposed changes to the diesel generator fuel oil day tank minimum volumes do not involve installation of new or different equipment nor do they change the methods governing normal plant operations. These changes are also consistent with assumptions made in the safety analysis and licensing basis. Clarifying the controls of high radiation areas will not impact existing or introduce any new accident precursors. The proposed changes do not create the possibility of a new or different kind of accident since they do not affect the reactor coolant pressure boundary or reactivity controls. Consequently, no new failure modes are introduced as a result of the proposed changes.

Therefore, the proposed changes do not create the possibility of a new or different kind of accident from any previously evaluated.

3. The proposed changes do not involve a significant reduction in a margin of safety.

The margin of safety is unchanged because the proposed administrative changes do not affect any design basis or accident assumptions. Changing the classification of the Backup Hydrogen Purge System isolation valves from drywell isolation valves to primary containment isolation valves results in the same actions being taken in the event one of these valves is declared inoperable. However, the Completion Times are more restrictive for inoperable primary containment isolation valves than for inoperable drywell isolation valves. The imposition of more restrictive requirements for the diesel generator fuel oil day tank minimum volumes results from the implementation of the Bases for the Technical Specification Surveillance Requirement. Clarifying the controls of high radiation areas is consistent with ALARA practices.

Therefore, the proposed changes do not involve a significant reduction in a margin of safety.

TABLE OF CONTENTS

FY-CEI/NRR-1999L
Attachment 4
Page 1 of 7

1.0	USE AND APPLICATION	
1.1	Definitions	1.0-1
1.2	Logical Connectors	1.0-8
1.3	Completion Times	1.0-11
1.4	Frequency	1.0-24
2.0	SAFETY LIMITS (SLs)	
2.1	SLs	2.0-1
2.2	SL Violations	2.0-1
B 2.0	SAFETY LIMITS (SLs)	
B 2.1.1	Reactor Core SLs	B 2.0-1
B 2.1.2	Reactor Coolant System (RCS) Pressure SL	B 2.0-6
3.0	LIMITING CONDITION FOR OPERATION (LCO) APPLICABILITY	3.0-1
3.0	SURVEILLANCE REQUIREMENT (SR) APPLICABILITY	3.0-4
B 3.0	LIMITING CONDITION FOR OPERATION (LCO) APPLICABILITY	B 3.0-1
B 3.0	SURVEILLANCE REQUIREMENT (SR) APPLICABILITY	B 3.0-10
3.1	REACTIVITY CONTROL SYSTEMS	
3.1.1	SHUTDOWN MARGIN (SDM)	3.1-1
3.1.2	Reactivity Anomalies	3.1-5
3.1.3	Control Rod OPERABILITY	3.1-7
3.1.4	Control Rod Scram Times	3.1-12
3.1.5	Control Rod Scram Accumulators	3.1-15
3.1.6	Control Rod Pattern	3.1-18
3.1.7	Standby Liquid Control (SLC) System	3.1-20
3.1.8	Scram Discharge Volume (SDV) Vent and Drain Valves	3.1-24
B 3.1	REACTIVITY CONTROL SYSTEMS	
B 3.1.1	SHUTDOWN MARGIN (SDM)	B 3.1-1
B 3.1.2	Reactivity Anomalies	B 3.1-8
B 3.1.3	Control Rod OPERABILITY	B 3.1-13
B 3.1.4	Control Rod Scram Times	B 3.1-22
B 3.1.5	Control Rod Scram Accumulators	B 3.1-28
B 3.1.6	Control Rod Pattern	B 3.1-33
B 3.1.7	Standby Liquid Control (SLC) System	B 3.1-38
B 3.1.8	Scram Discharge Volume (SDV) Vent and Drain Valves	B 3.1-44
3.2	POWER DISTRIBUTION LIMITS	
3.2.1	AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)	3.2-1
3.2.2	MINIMUM CRITICAL POWER RATIO (MCPR)	3.2-2
3.2.3	LINEAR HEAT GENERATION RATE (LHGR)	3.2-3
B 3.2	POWER DISTRIBUTION LIMITS	
B 3.2.1	AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)	B 3.2-1
B 3.2.2	MINIMUM CRITICAL POWER RATIO (MCPR)	B 3.2-6
B 3.2.3	LINEAR HEAT GENERATION RATE (LHGR)	B 3.2-10

(continued)

TABLE OF CONTENTS

3.3	INSTRUMENTATION	
3.3.1.1	Reactor Protection System (RPS) Instrumentation	3.3-1
3.3.1.2	Source Range Monitor (SRM) Instrumentation	3.3-10
3.3.2.1	Control Rod Block Instrumentation	3.3-15
3.3.3.1	Post Accident Monitoring (PAM) Instrumentation	3.3-20
3.3.3.2	Remote Shutdown System	3.3-24
3.3.4.1	End of Cycle Recirculation Pump Trip (EOC-RPT) Instrumentation	3.3-26
3.3.4.2	Anticipated Transient Without Scram Recirculation Pump Trip (ATWS-RPT) Instrumentation	3.3-29
3.3.5.1	Emergency Core Cooling System (ECCS) Instrumentation	3.3-32
3.3.5.2	Reactor Core Isolation Cooling (RCIC) System Instrumentation	3.3-44
3.3.6.1	Primary Containment and Drywell Isolation Instrumentation	3.3-48
3.3.6.2	Residual Heat Removal (RHR) Containment Spray System Instrumentation	3.3-60
3.3.6.3	Suppression Pool Makeup (SPMU) System Instrumentation	3.3-64
3.3.6.4	Relief and Low-Low Set (LLS) Instrumentation	3.3-68
3.3.7.1	Control Room Emergency Recirculation (CRER) System Instrumentation	3.3-70
3.3.8.1	Loss of Power (LOP) Instrumentation	3.3-74
3.3.8.2	Reactor Protection System (RPS) Electric Power Monitoring	3.3-77
B 3.3	INSTRUMENTATION	
B 3.3.1.1	Reactor Protection System (RPS) Instrumentation	B 3.3-1
B 3.3.1.2	Source Range Monitor (SRM) Instrumentation	B 3.3-33
B 3.3.2.1	Control Rod Block Instrumentation	B 3.3-42
B 3.3.3.1	Post Accident Monitoring (PAM) Instrumentation	B 3.3-51
B 3.3.3.2	Remote Shutdown System	B 3.3-63
B 3.3.4.1	End of Cycle Recirculation Pump Trip (EOC-RPT) Instrumentation	B 3.3-68
B 3.3.4.2	Anticipated Transient Without Scram Recirculation Pump Trip (ATWS-RPT) Instrumentation	B 3.3-79
B 3.3.5.1	Emergency Core Cooling System (ECCS) Instrumentation	B 3.3-88
B 3.3.5.2	Reactor Core Isolation Cooling (RCIC) System Instrumentation	B 3.3-124
B 3.3.6.1	Primary Containment and Drywell Isolation Instrumentation	B 3.3-136
B 3.3.6.2	Residual Heat Removal (RHR) Containment Spray System Instrumentation	B 3.3-173
B 3.3.6.3	Suppression Pool Makeup (SPMU) System Instrumentation	B 3.3-184

(continued)

TABLE OF CONTENTS

B 3.3	INSTRUMENTATION (continued)	
B 3.3.6.4	Relief and Low-Low Set (LLS) Instrumentation	B 3.3-195
B 3.3.7.1	Control Room Emergency Recirculation (CRER) System Instrumentation	B 3.3-201
B 3.3.8.1	Loss of Power (LOP) Instrumentation	B 3.3-211
B 3.3.8.2	Reactor Protection System (RPS) Electric Power Monitoring	B 3.3-218
3.4	REACTOR COOLANT SYSTEM (RCS)	
3.4.1	Recirculation Loops Operating	3.4-1
3.4.2	Flow Control Valves (FCVs)	3.4-6
3.4.3	Jet Pumps	3.4-8
3.4.4	Safety/Relief Valves (S/RVs)	3.4-10
3.4.5	RCS Operational LEAKAGE	3.4-12
3.4.6	RCS Pressure Isolation Valve (PIV) Leakage	3.4-14
3.4.7	RCS Leakage Detection Instrumentation	3.4-16
3.4.8	RCS Specific Activity	3.4-19
3.4.9	Residual Heat Removal (RHR) Shutdown Cooling System-Hot Shutdown	3.4-21
3.4.10	Residual Heat Removal (RHR) Shutdown Cooling System-Cold Shutdown	3.4-24
3.4.11	RCS Pressure and Temperature (P/T) Limits	3.4-26
3.4.12	Reactor Steam Dome Pressure	3.4-32
B 3.4	REACTOR COOLANT SYSTEM (RCS)	
B 3.4.1	Recirculation Loops Operating	B 3.4-1
B 3.4.2	Flow Control Valves (FCVs)	B 3.4-9
B 3.4.3	Jet Pumps	B 3.4-13
B 3.4.4	Safety/Relief Valves (S/RVs)	B 3.4-17
B 3.4.5	RCS Operational LEAKAGE	B 3.4-22
B 3.4.6	RCS Pressure Isolation Valve (PIV) Leakage	B 3.4-27
B 3.4.7	RCS Leakage Detection Instrumentation	B 3.4-32
B 3.4.8	RCS Specific Activity	B 3.4-39
B 3.4.9	Residual Heat Removal (RHR) Shutdown Cooling System-Hot Shutdown	B 3.4-43
B 3.4.10	Residual Heat Removal (RHR) Shutdown Cooling System-Cold Shutdown	B 3.4-48
B 3.4.11	RCS Pressure and Temperature (P/T) Limits	B 3.4-53
B 3.4.12	Reactor Steam Dome Pressure	B 3.4-63
3.5	EMERGENCY CORE COOLING SYSTEMS (ECCS) AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM	
3.5.1	ECCS-Operating	3.5-1
3.5.2	ECCS-Shutdown	3.5-6
3.5.3	RCIC System	3.5-10

(continued)

TABLE OF CONTENTS

B 3.5	EMERGENCY CORE COOLING SYSTEMS (ECCS) AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM	
B 3.5.1	ECCS—Operating	B 3.5-1
B 3.5.2	ECCS—Shutdown	B 3.5-15
B 3.5.3	RCIC System	B 3.5-20
3.6	CONTAINMENT SYSTEMS	
3.6.1.1	Primary Containment—Operating	3.6-1
3.6.1.2	Primary Containment Air Locks	3.6-3
3.6.1.3	Primary Containment Isolation Valves (PCIVs)	3.6-9
3.6.1.4	Primary Containment Pressure	3.6-20
3.6.1.5	Primary Containment Air Temperature	3.6-21
3.6.1.6	Low-Low Set (LLS) Valves	3.6-22
3.6.1.7	Residual Heat Removal (RHR) Containment Spray System	3.6-24
3.6.1.8	Feedwater Leakage Control System (FWLCS)	3.6-26
3.6.1.9	Main Steam Isolation Valve (MSIV) Leakage Control System (LCS)	3.6-27
3.6.1.10	Primary Containment—Shutdown	3.6-29
3.6.1.11	Containment Vacuum Breakers	3.6-31
3.6.1.12	Containment Humidity Control	3.6-34
3.6.2.1	Suppression Pool Average Temperature	3.6-36
3.6.2.2	Suppression Pool Water Level	3.6-39
3.6.2.3	Residual Heat Removal (RHR) Suppression Pool Cooling	3.6-40
3.6.2.4	Suppression Pool Makeup (SPMU) System	3.6-42
3.6.3.1	Primary Containment Hydrogen Recombiners	3.6-44
3.6.3.2	Primary Containment and Drywell Hydrogen Igniters	3.6-46
3.6.3.3	Combustible Gas Mixing System	3.6-49
3.6.4.1	Secondary Containment	3.6-51
3.6.4.2	Secondary Containment Isolation Valves (SCIVs)	3.6-53
3.6.4.3	Annulus Exhaust Gas Treatment (AEGT) System	3.6-56
3.6.5.1	Drywell	3.6-59
3.6.5.2	Drywell Air Lock	3.6-61
3.6.5.3	Drywell Isolation Valves	3.6-65
3.6.5.4	Drywell Pressure	3.6-69
3.6.5.5	Drywell Air Temperature	3.6-70
3.6.5.6	Drywell Vacuum Relief System	3.6-71
B 3.6	CONTAINMENT SYSTEMS	
B 3.6.1.1	Primary Containment—Operating	B 3.6-1
B 3.6.1.2	Primary Containment Air Locks	B 3.6-5
B 3.6.1.3	Primary Containment Isolation Valves (PCIVs)	B 3.6-15
B 3.6.1.4	Primary Containment Pressure	B 3.6-31
B 3.6.1.5	Primary Containment Air Temperature	B 3.6-34
B 3.6.1.6	Low-Low Set (LLS) Valves	B 3.6-37

(continued)

TABLE OF CONTENTS

B 3.6	CONTAINMENT SYSTEMS (continued)	
B 3.6.1.7	Residual Heat Removal (RHR) Containment Spray System	B 3.6-41
B 3.6.1.8	Feedwater Leakage Control System (FWLCS)	B 3.6-46
B 3.6.1.9	Main Steam Isolation Valve (MSIV) Leakage Control System (LCS)	B 3.6-49
B 3.6.1.10	Primary Containment-Shutdown	B 3.6-53
B 3.6.1.11	Containment Vacuum Breakers	B 3.6-57
B 3.6.1.12	Containment Humidity Control	B 3.6-63
B 3.6.2.1	Suppression Pool Average Temperature	B 3.6-68
B 3.6.2.2	Suppression Pool Water Level	B 3.6-73
B 3.6.2.3	Residual Heat Removal (RHR) Suppression Pool Cooling	B 3.6-77
B 3.6.2.4	Suppression Pool Makeup (SPMU) System	B 3.6-81
B 3.6.3.1	Primary Containment Hydrogen Recombiners	B 3.6-88
B 3.6.3.2	Primary Containment and Drywell Hydrogen Igniters	B 3.6-93
B 3.6.3.3	Combustible Gas Mixing System	B 3.6-99
B 3.6.4.1	Secondary Containment	B 3.6-104
B 3.6.4.2	Secondary Containment Isolation Valves (SCIVs)	B 3.6-109
B 3.6.4.3	Annulus Exhaust Gas Treatment (AEGT) System	B 3.6-115
B 3.6.5.1	Drywell	B 3.6-120
B 3.6.5.2	Drywell Air Lock	B 3.6-124
B 3.6.5.3	Drywell Isolation Valves	B 3.6-132
B 3.6.5.4	Drywell Pressure	B 3.6-140
B 3.6.5.5	Drywell Air Temperature	B 3.6-143
B 3.6.5.6	Drywell Vacuum Relief System	B 3.6-146
3.7	PLANT SYSTEMS	
3.7.1	Emergency Service Water (ESW) System—Divisions 1 and 2	3.7-1
3.7.2	Emergency Service Water (ESW) System—Division 3	3.7-3
3.7.3	Control Room Emergency Recirculation (CRER) System	3.7-4
3.7.4	Control Room Heating, Ventilation, and Air Conditioning (HVAC) System	3.7-8
3.7.5	Main Condenser Offgas	3.7-11
3.7.6	Main Turbine Bypass System	3.7-13
3.7.7	Fuel Pool Water Level	3.7-14
3.7.8	Fuel Handling Building	3.7-15
3.7.9	Fuel Handling Building Ventilation Exhaust System	3.7-16
3.7.10	Emergency Closed Cooling Water (ECCW) System	3.7-19
B 3.7	PLANT SYSTEMS	
B 3.7.1	Emergency Service Water (ESW) System—Divisions 1 and 2	B 3.7-1
B 3.7.2	Emergency Service Water (ESW) System—Division 3	B 3.7-7
B 3.7.3	Control Room Emergency Recirculation (CRER) System	B 3.7-10

(continued)

TABLE OF CONTENTS

B 3.7	PLANT SYSTEMS (continued)	
B 3.7.4	Control Room Heating, Ventilation and Air Conditioning (HVAC) System	B 3.7-16
B 3.7.5	Main Condenser Offgas	B 3.7-21
B 3.7.6	Main Turbine Bypass System	B 3.7-24
B 3.7.7	Fuel Pool Water Level	B 3.7-28
B 3.7.8	Fuel Handling Building (FHB)	B 3.7-31
B 3.7.9	Fuel Handling Building (FHB) Ventilation Exhaust System	B 3.7-34
B 3.7.10	Emergency Closed Cooling Water (ECCW) System	B 3.7-40
3.8	ELECTRICAL POWER SYSTEMS	
3.8.1	AC Sources—Operating	3.8-1
3.8.2	AC Sources—Shutdown	3.8-17
3.8.3	Diesel Fuel Oil, Lube Oil, and Starting Air	3.8-21
3.8.4	DC Sources—Operating	3.8-24
3.8.5	DC Sources—Shutdown	3.8-28
3.8.6	Battery Cell Parameters	3.8-32
3.8.7	Distribution Systems—Operating	3.8-36
3.8.8	Distribution Systems—Shutdown	3.8-38
B 3.8	ELECTRICAL POWER SYSTEMS	
B 3.8.1	AC Sources—Operating	B 3.8-1
B 3.8.2	AC Sources—Shutdown	B 3.8-35
B 3.8.3	Diesel Fuel Oil, Lube Oil, and Starting Air	B 3.8-42
B 3.8.4	DC Sources—Operating	B 3.8-52
B 3.8.5	DC Sources—Shutdown	B 3.8-61
B 3.8.6	Battery Cell Parameters	B 3.8-65
B 3.8.7	Distribution Systems—Operating	B 3.8-72
B 3.8.8	Distribution Systems—Shutdown	B 3.8-82
3.9	REFUELING OPERATIONS	
3.9.1	Refueling Equipment Interlocks	3.9-1
3.9.2	Refuel Position One-Rod-Out Interlock	3.9-2
3.9.3	Control Rod Position	3.9-4
3.9.4	Control Rod Position Indication	3.9-5
3.9.5	Control Rod OPERABILITY—Refueling	3.9-7
3.9.6	Reactor Pressure Vessel (RPV) Water Level— Irradiated Fuel	3.9-8
3.9.7	Reactor Pressure Vessel (RPV) Water Level— New Fuel or Control Rods	3.9-9
3.9.8	Residual Heat Removal (RHR)—High Water Level	3.9-10
3.9.9	Residual Heat Removal (RHR)—Low Water Level	3.9-13
B 3.9	REFUELING OPERATIONS	
B 3.9.1	Refueling Equipment Interlocks	B 3.9-1

(continued)

TABLE OF CONTENTS

B 3.9	REFUELING OPERATIONS (continued)	
B 3.9.2	Refuel Position One-Rod-Out Interlock	B 3.9-5
B 3.9.3	Control Rod Position	B 3.9-9
B 3.9.4	Control Rod Position Indication	B 3.9-12
B 3.9.5	Control Rod OPERABILITY-Refueling	B 3.9-16
B 3.9.6	Reactor Pressure Vessel (RPV) Water Level - Irradiated Fuel	B 3.9-19
B 3.9.7	Reactor Pressure Vessel (RPV) Water Level - New Fuel or Control Rods	B 3.9-22
B 3.9.8	Residual Heat Removal (RHR) -High Water Level	B 3.9-25
B 3.9.9	Residual Heat Removal (RHR) -Low Water Level	B 3.9-30
3.10	SPECIAL OPERATIONS	
3.10.1	Inservice Leak and Hydrostatic Testing Operation	3.10-1
3.10.2	Reactor Mode Switch Interlock Testing	3.10-4
3.10.3	Single Control Rod Withdrawal-Hot Shutdown	3.10-6
3.10.4	Single Control Rod Withdrawal-Cold Shutdown	3.10-9
3.10.5	Single Control Rod Drive (CRD) Removal - Refueling	3.10-13
3.10.6	Multiple Control Rod Withdrawal-Refueling	3.10-16
3.10.7	Control Rod Testing-Operating	3.10-18
3.10.8	SHUTDOWN MARGIN (SDM) Test-Refueling	3.10-19
B 3.10	SPECIAL OPERATIONS	
B 3.10.1	Inservice Leak and Hydrostatic Testing Operation	B 3.10-1
B 3.10.2	Reactor Mode Switch Interlock Testing	B 3.10-6
B 3.10.3	Single Control Rod Withdrawal-Hot Shutdown	B 3.10-11
B 3.10.4	Single Control Rod Withdrawal-Cold Shutdown	B 3.10-16
B 3.10.5	Single Control Rod Drive (CRD) Removal - Refueling	B 3.10-21
B 3.10.6	Multiple Control Rod Withdrawal-Refueling	B 3.10-26
B 3.10.7	Control Rod Testing-Operating	B 3.10-29
B 3.10.8	SHUTDOWN MARGIN (SDM) Test-Refueling	B 3.10-33
4.0	DESIGN FEATURES	
4.1	Site Location	4.0-1
4.2	Reactor Core	4.0-1
4.3	Fuel Storage	4.0-2
5.0	ADMINISTRATIVE CONTROLS	
5.1	Responsibility	5.0-1
5.2	Organization	5.0-2
5.3	Unit Staff Qualifications	5.0-4
5.4	Procedures	5.0-5
5.5	Programs and Manuals	5.0-6
5.6	Reporting Requirements	5.0-16
5.7	High Radiation Area	5.0-19