

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

April 22, 1996

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Serial No. 96-185  
NL/RPC  
Docket Nos. 50-338  
50-339  
License Nos. NPF-4  
NPF-7


Gentlemen:

**VIRGINIA ELECTRIC AND POWER COMPANY**  
**NORTH ANNA POWER STATION UNITS 1 AND 2**  
**ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT**

Pursuant to Technical Specification 6.9.1.8, enclosed is the Annual Radiological Environmental Operating Report for North Anna Power Station Units 1 and 2 for 1995.

If you have any questions or require additional information, please contact us.

Very truly yours,



M. L. Bowling, Manager  
Nuclear Licensing and Operations Support

Attachment

cc: U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, N. W.  
Suite 2900  
Atlanta, Georgia 30323

Mr. R. D. McWhorter  
NRC Senior Resident Inspector  
North Anna Power Station

060098

9605070010 951231  
PDR ADDCK 05000338  
R PDR

JE 25/1


***VIRGINIA ELECTRIC AND POWER COMPANY***  
***NORTH ANNA POWER STATION***  
***Radiological Environmental Monitoring Program***  
***January 1, 1995 to December 31, 1995***

*Prepared by*  
***VIRGINIA ELECTRIC AND POWER COMPANY***  
***and***  
***TELEDYNE BROWN ENGINEERING***

**Annual Radiological Environmental Operating Report**  
**North Anna Power Station**


**January 1, 1995 to December 31, 1995**

**Prepared by:**




James B. Breeden,  
Supervisor Radiological Analysis

**Reviewed by:**



Erich W. Dreyer  
Supervisor Health Physics Technical Services

**Approved by:**



Alan H. Stafford  
Superintendent Radiological Protection

## Table Of Contents

<u>Section</u>	<u>Title</u>	<u>Page</u>
	Preface.....	7
	Executive Summary.....	8
I.	Introduction.....	10
II.	Nuclear Power And The Environment: In Perspective.....	12
III.	Sampling And Analysis Program.....	25
IV.	Program Exceptions.....	41
V.	Summary And Discussion Of 1995 Analytical Results.....	42
	A. Airborne Exposure Pathway.....	42
	1. Air Iodine/Particulates.....	42
	2. Precipitation.....	44
	3. Soil.....	45
	B. Waterborne Exposure Pathway.....	45
	1. Ground/Well Water.....	45
	2. River Water.....	46
	3. Surface Water.....	46
	C. Aquatic Exposure Pathway.....	48
	1. Sediment/Silt.....	48
	2. Shoreline Soil.....	51
	D. Ingestion Exposure Pathway.....	51
	1. Milk.....	51
	2. Fish.....	52
	3. Food/Vegetation.....	52
	E. Direct Radiation Exposure Pathway.....	54
	1. TLD Dosimeters.....	54
VI.	Conclusion.....	55



## Table Of Contents (Continued)

<u>Section</u>	<u>Title</u>	<u>Page</u>
VII.	References.....	58
VIII.	Appendices.....	59
	Appendix A - Radiological Environmental Monitoring Program Annual Summary Tables - 1995 .....	59
	Appendix B - Data Tables .....	66
	Appendix C - Land Use Census - 1995 .....	89
	Appendix D - Synopsis of Analytical Procedures .....	92
	Appendix E - EPA Interlaboratory Comparison Program .....	103

### List of Trending Graphs

1.	Gross Beta in Air Particulates.....	43
2.	Tritium in River Water .....	43
3.	Tritium in Surface Water.....	47
4.	Cobalt-58 in Sediment Silt.....	47
5.	Cobalt-60 in Sediment Silt.....	49
6.	Cesium-134 in Sediment Silt.....	49
7.	Cesium-137 in Sediment Silt.....	50
8.	Cesium-134 in Fish .....	50
9.	Cesium-137 in Fish .....	53
10.	Environmental Radiation - TLDs .....	53

### List of Figures

<u>Figure</u>	<u>Title</u>	<u>Page</u>
1.	Atomic Structure .....	12
2.	Alpha Particle .....	14
3.	Beta Particle .....	14
4.	Gamma Ray .....	14
5.	The Penetrating Ability of Various Types of Radiation .....	15
6.	Unit Comparison .....	15
7.	The Curie, a Measurement of Activity .....	16
8.	Average Annual Dose Equivalent to Persons in the U.S. from Various Radiation Sources .....	17
9.	Estimated Average Days of Life Expectancy Lost Due to Various Health Risks.....	19
10.	Reactor Vessel with Fuel Assemblies, Rods, and Fuel Pellets.....	20
11.	Fission: a Chain Reaction.....	21
12.	PWR System Diagram .....	22
13.	Containment Schematic .....	23
14.	North Anna Radiological Monitoring Locations .....	32

## *List of Tables*

Table	Page
1. Uranium Isotopes .....	13
2. Radiological Sampling Station Distance and Direction from Unit 1.....	26
3. North Anna Power Station Sample Analysis Program.....	38
4. REMP Exceptions for Scheduled Sampling and Analysis During 1995.....	41
 <b>Appendix B Tables</b>	
B-1 Iodine-131 Concentration in Filtered Air .....	66
B-2 Concentrations of Gross Beta in Air Particulates.....	68
B-3 Gamma Emitter, Strontium 89, and Strontium 90 Concentrations in Air Particulates .....	72
B-4 Gamma Emitter and Tritium Concentration in River Water .....	75
B-5 Gamma Emitter Concentration in Soil.....	76
B-6 Gamma Emitter, Strontium, and Tritium Concentrations in Ground and Well Water .....	77
B-7 Gamma Emitter, Strontium, and Tritium Concentrations in River Water .....	77
B-8 Gamma Emitter, Strontium, and Tritium Concentrations in Surface Water.....	78
B-9 Gamma Emitter, Strontium, and Tritium Concentrations in Surface Water State-Split Samples .....	79
B-10 Gamma Emitter Concentrations in Sediment Silt .....	80
B-11 Gamma Emitter Concentrations in Shoreline Soil .....	80
B-12 Gamma Emitter Concentrations in Milk .....	81
B-13 Gamma Emitter Concentrations in Fish.....	83
B-14 Gamma Emitter Concentrations in Food/Vegetation .....	84
B-15 Direct Radiation Measurements Quarterly Annual TLD Results.....	86
B-16 Direct Radiation Measurements Sector Quarterly TLD Results.....	87

## *Preface*

This report is submitted as required by Technical Specification 6.9.1.8, Annual Radiological Environmental Operating Report for North Anna Power Stations, Units 1 and 2, Virginia Electric and Power Company Docket Nos. 50-338 and 50-339.

## *Executive Summary*

This document is a detailed report on the 1995 North Anna Nuclear Power Station Radiological Environmental Monitoring Program (REMP). Radioactivity levels from January 1 through December 31, 1995 in water, silt, shoreline sediment, milk, aquatic biota, food products, vegetation, and direct exposure pathways have been analyzed, evaluated, and summarized. The REMP is designed to ensure that radiological effluent releases are As Low As is Reasonably Achievable (ALARA), no undue environmental effects occur, and the health and safety of the public is protected. The program also detects any unexpected environmental processes which could allow radiation accumulations in the environment or food pathway chains.

Radiation and radioactivity in the environment is constantly monitored within a 25 mile radius of the station. Virginia Power also collects samples within this area. A number of sampling locations for each medium were selected using available meteorological, land use, and water use data. Two types of samples are obtained. The first type, control samples, are collected from areas that are beyond the measurable influence of North Anna Nuclear Power Station or any other nuclear facility. These samples are used as reference data. Normal background radiation levels, or radiation present due to causes other than North Anna Power Station, can thus be compared to the environment surrounding the nuclear power station. Indicator samples are the second sample type obtained. These samples show how much radiation is contributed to the environment by the plant. Indicator samples are taken from areas close to the station where any plant contribution will be at the highest concentration.



Prior to station operation, samples were collected and analyzed to determine the amount of radioactivity present in the area. The resulting values are used as a "pre-operational baseline." Analysis results from the indicator samples are compared to both current control sample values and the pre-operational baseline to determine if changes in radioactivity levels are attributable to station operations, other causes such as the Chernobyl accident, or natural variation.

Teledyne Brown Engineering provides sample analyses for various radioisotopes as appropriate for each sample media. Participation in the Environmental Protection Agency's (EPA) Interlaboratory Comparison Program provides an independent check of sample measurement precision and accuracy. Typically, radioactivity levels in the environment are so low that analysis values frequently fall below the minimum detection limits of state-of-the-art measurement methods. Because of this, the Nuclear Regulatory Commission (NRC) requires that equipment used for radiological environmental monitoring must be able to detect specified minimum Lower Limits of Detection (LLD). This ensures that analyses are as accurate as possible. Samples with extremely low levels of radiation which cannot be detected are therefore reported as being below the LLD. The NRC also mandates a "reporting level." Licensed nuclear facilities must report any releases

equal to or greater than this reporting level. Environmental radiation levels are sometimes referred to as a percent of the reporting level.

Analytical results are divided into five categories based on exposure pathways: Airborne, waterborne, aquatic, ingestion, and direct radiation. Each of these pathways is described below:

- The airborne exposure pathway includes airborne iodine, airborne particulate, precipitation, and soil samples. The overall 1995 airborne results were very similar to previous years and to preoperational levels. No increase was noted and there were no detections of fission products or other man-made isotopes in the airborne particulate media during 1995.
- The waterborne exposure pathway includes ground/well water, river water, and surface water samples. No man-made or natural isotopes were detected in Lake Anna surface water except for tritium. The average tritium activity in 1995 was 14% of the NRC reporting level. This has essentially remained unchanged from 1994 levels.
- The aquatic exposure pathway includes sediment/silt and shoreline samples. North Anna sediment contained some cesium-137. During the preoperational period, cesium-137 was detected. Sediment contamination, however, does not provide a direct dose pathway to man. In shoreline soil, which may provide a direct dose pathway, only cesium-137 was detected. Cesium-137 levels were 341 pCi/kg in 1995.
- The ingestion exposure pathway includes milk, fish, and food/vegetation samples. Iodine-131 was not detected in any 1995 milk samples. Although cesium-137 has been detected in the past, it was not detected in 1995 milk samples. Strontium-90 was detected at levels comparable to 1989, and lower than preoperational years. Both strontium-90 and cesium-137 are attributable to atmospheric nuclear weapons testing in the past. Naturally occurring potassium-40 was detected at normal environmental levels.

Fish samples during 1995 contained cesium-137 at a slightly higher activity than preoperational levels. Steam generator repairs and better liquid waste processing, however, have reduced these activity levels from previous years. Vegetation samples were statistically similar to both control and preoperational levels.

- The direct radiation exposure pathway measures environmental radiation doses by use of thermoluminescent dosimeters (TLDs). TLD results have remained essentially the same since the preoperational period in 1977.

During 1995, as in previous years, operation of the North Anna Nuclear Power Station created no adverse environmental affects or health hazards. The maximum radiation dose calculated for a hypothetical individual at the North Anna Power Station site boundary due to liquid and gaseous effluents released from the site during 1995 was 0.30 millirem. For reference this dose may be compared to the 360 millirem average annual exposure to every person in the United States from natural and man-made sources. Natural sources in the environment provide approximately 82% of radiation exposure to man while Nuclear Power contributes less than 0.1%. These results demonstrate not only compliance with federal and state regulations, but also demonstrate the adequacy of radioactive effluent control at the North Anna Nuclear Power Station.



**Virginia Electric And Power Company**  
**North Anna Power Station**  
**Radiological Environmental Operating Program**

**I. Introduction**

The operational Radiological Environmental Monitoring Program (REMP) conducted for the year 1995 for North Anna Power Station is provided in this report. The results of measurements and analyses of data obtained from samples collected from January 1, 1995 through December 31, 1995 are summarized.

- A. The North Anna Power Station of Virginia Electric and Power Company is located on Lake Anna in Mineral, Virginia, approximately 35 miles southwest of Fredericksburg, Virginia. The site consists of two units, each with pressurized water reactor (PWR) nuclear steam supply systems and turbine generators furnished by Westinghouse Electric Corporation. Each unit is designed with a gross electrical output of 970 megawatts electric (MWe). Unit 1 achieved commercial operation on June 6, 1978, and Unit 2 on December 14, 1980.
- B. The United States Nuclear Regulatory Commission (USNRC) regulations (10 CFR 50.34a) require that nuclear power plants be designed, constructed, and operated to keep levels of radioactive material in effluents to unrestricted areas As Low As is Reasonably Achievable (ALARA). To ensure these criteria are met, the operating license for North Anna Power Station includes Technical Specifications which address the release of radioactive effluents. Inplant monitoring is used to ensure release limits are not exceeded. As a precaution against unexpected or undefined environmental processes which might allow undue accumulation of radioactivity in the environment, a program for monitoring the plant environs is also included in Virginia Power's Station Administrative Procedure VPAP-2103, Offsite Dose Calculation Manual (ODCM).
- C. Virginia Electric and Power Company is responsible for collecting the various indicator and control environmental samples. Teledyne Isotopes is responsible for sample analysis and submitting reports of radioanalyses. The results are used to determine if changes in radioactivity levels could be attributable to station operations. Measured values are compared to control levels, which vary with time due to such external events as cosmic ray bombardment, weapons test fallout, and seasonal variations of naturally occurring isotopes. Data collected prior to the plant operation is used to indicate the degree of natural variation to be expected. This preoperational data is compared to data collected during the operational phase to assist in evaluating any radiological impact of plant operations.
- D. Occasionally samples of environmental media show the presence of man-made isotopes. As a method of referencing the measured radionuclide concentrations in the sample media to a dose consequence to man, the data is compared to the reporting

level concentrations listed in the USNRC Regulatory Guide 4.8 and North Anna Power Station's ODCM. These concentrations are based upon the annual dose commitment recommended by 10 CFR 50, Appendix I, to meet the criterion of "As Low As Is Reasonably Achievable."

- E. This report documents the results of the Radiological Environmental Monitoring Program for 1991 and satisfies the following objectives of the program:
1. Provides measurements of radiation and of radioactive materials in those exposure pathways and for those radionuclides that lead to the highest potential radiation exposure of the maximum exposed members of the public resulting from the station operation.
  2. Supplements the radiological effluent monitoring program by verifying that radioactive effluents are within allowable limits.
  3. Identifies radioactivity changes in the environment.
  4. Verifies that the plant operations have no detrimental effect on the health and safety of the public.



## ***II. Nuclear Power And The Environment: In Perspective***

Coal, oil, natural gas, nuclear power, and hydropower have all been used to run the nation's electric generating stations. Each method, however, has its drawbacks. Coal-fired power can damage the environment during the mining process, or by airborne discharges such as fly-ash and chemicals which contribute to acid rain. Oil and natural gas are costly because of their limited supply. Few suitable sites for hydropower exist, and building the large dams necessary to produce Hydropower has a significant impact on the environment.


Nuclear energy provides an alternate source of energy which is readily available. The operation of nuclear power stations has a very small impact on the environment. In fact, hundreds of acres adjoining Surry Power Station are a state waterfowl refuge, and Lake Anna, next to North Anna Power Station, is a well-known fishing site with a state park on its shore.

In order to more fully understand this unique energy source, background information about basic radiation characteristics, risk assessment, reactor operation, effluent control, environmental monitoring, and radioactive waste is provided in this section.

### ***Fundamentals***

#### ***The Atom***

Everything we encounter is made of atoms. Atoms are the smallest parts of an element that still have all the chemical properties of that element. At the center of an atom is a nucleus. The nucleus consists of neutrons and protons. Electrons move in an orbit around the nucleus and are negatively charged. Protons and neutrons are nearly identical in size and weight, and each is about 2000 times heavier than an electron. The proton, however, has a positive charge, while the neutron has no charge, it is electrically neutral. Figure 1 presents a simple diagram of an atom.



#### ***Isotopes***

The number of protons in the atom of any specific element is always the same. For example, all hydrogen atoms have one proton whereas all oxygen atoms have eight protons. Unlike protons,

the number of neutrons in the nucleus of an element may vary. Atoms with the same number of protons, but a different number of neutrons, are called isotopes. Table 1 lists the isotopes of uranium.

Isotopes	Symbols	Number of Protons	Number of Neutrons
Uranium-235	$^{235}\text{U}$	92	143
Uranium-236	$^{236}\text{U}$	92	144
Uranium-237	$^{237}\text{U}$	92	145
Uranium-238	$^{238}\text{U}$	92	146
Uranium-239	$^{239}\text{U}$	92	147
Uranium-240	$^{240}\text{U}$	92	148

**Table 1. Uranium Isotopes**

## ***Radiation and Radioactivity***

### ***Radionuclides***

Normally, the parts of an atom are in a balanced or stable state. A small percentage of atoms naturally contain excess energy and therefore are not stable atoms. If the nucleus of an atom contains excess energy, it may be called a radioactive atom, a radioisotope, or radionuclide. The excess energy is usually due to an imbalance in the number of electrons, protons, and/or neutrons which make up the atom.

Radionuclides can be naturally occurring, such as uranium-238, thorium-232 and potassium-40, or man-made, such as iodine-131, cesium-137, and cobalt-60.

### ***Radioactive Decay***

Radioactive atoms attempt to reach a stable (non-radioactive) state through a process known as radioactive decay. Radioactive decay is the release of energy from the atom through the emission of particulate and/or electromagnetic radiation. Particulate radiation may be in the form of electrically charged particles such as alpha (2 protons plus 2 neutrons) or beta particles (1 electron), or may be electrically neutral, such as neutrons. Part of the electromagnetic spectrum consists of gamma rays and X-rays which are similar to light and microwaves, but have a much higher energy.

### ***Half-Life***

A radioactive half-life is the amount of time required for a radioactive substance to lose half of its activity through the process of radioactive decay. Cobalt-60 has a half-life of about 5 years.

After 5 years, 50% of its radioactivity is gone, and after 10 years, 75% has decayed away. Radioactive half-lives vary from millionths of a second to millions of years.

Radioactive atoms may decay directly to a stable state or may undergo a series of decay stages. During the decay process, several daughter products may be formed which eventually transform into stable atoms. Naturally occurring radium-226, for example, has 10 successive daughter products (including radon) resulting finally with lead-206 as a stable form.

## Types Of Radiation




Two types of radiation are considered in the nuclear industry, particulate and electromagnetic. Particulate radiation may come from the nucleus of an atom in the form of an ejected alpha particle. As shown in Figure 2, alpha particles consist of two protons together with two neutrons.


Alpha particles have a very limited ability to penetrate matter. A piece of paper will stop all alpha radiation. For this reason, alpha radiation from sources outside the body are not considered to be a radiation hazard.

Figure 3 shows how the beta particle is like an electron that has been ejected from the nucleus of an atom. Skin or a thin piece of aluminum will stop beta radiation. Exposure to beta radiation can be a hazard to the skin or lens of the eye. Because of their limited ability to penetrate the body, beta and alpha radiation are a health concern primarily if alpha or beta emitters are swallowed or inhaled where they might cause internal radiation exposure.

Gamma rays are like X-rays, except that they come from the nucleus of an atom while X-rays come from the electron rings (Figure 4).

Gamma rays can penetrate deep into the body and thus give a "whole-body" radiation dose. Several inches of concrete or lead will stop both gamma and X-rays. Figure 5 shows the approximate penetrating ability of various types of radiation.







## Quantities And Units Of Radioactive Measurement

Several quantities and units are used to describe radioactivity and its effects. In the following sections two terms, rem and activity, will be used to describe amounts of radiation.

Rem measures the potential effect of radiation exposure on human cells. Small doses are counted in millirem. Each millirem is equal to one thousandth of a rem (Figure 6). Federal standards limit exposure for an individual member of the public to 100 millirem annually, compared with the average 300 millirem received from natural sources and approximately 60 millirem from medical applications.






**Figure 5. The Penetrating Ability of Various Types of Radiation**

## Quantities And Units Of Radioactive Measurement


Several quantities and units are used to describe radioactivity and its effects. In the following sections two terms, rem and activity, will be used to describe amounts of radiation.

Rem measures the potential effect of radiation exposure on human\* cells. Small doses are counted in millirem. Each millirem is equal to one thousandth of a rem (Figure 6). Federal standards limit exposure for an individual member of the public to 100 millirem annually, compared with the average 300 millirem received from natural sources and approximately 60 millirem from medical applications.



**Figure 6. Unit Comparison**

Activity is the number of nuclei in a sample that disintegrate (decay) every second. Each time a nucleus disintegrates, radiation is emitted. As depicted in Figure 7, the unit of activity is the curie. A Curie (Ci) is the amount of radioactive material which decays at a rate of 37 billion atoms per second. Smaller units of the Curie are often used. Two common units are the microCurie ( $\mu\text{Ci}$ ), one millionth of a Curie, and the picoCurie ( $\text{pCi}$ ), one trillionth of a Curie. A Curie is a measurement of radioactivity, not a quantity of material. The amount of material necessary to make one Curie varies. For example, one gram of radium-226 is one Curie of radioactivity, but it would take 9,170,000 grams (about 10 tons) of thorium-232 to obtain one Curie.



## Sources Of Radiation

The average annual dose equivalent to persons in the United States from background and man-made sources is shown in Figure 8.

### Background Radiation

Radiation is not a new creation of the nuclear power industry; it is a natural occurrence on the earth. Mankind has always lived with radiation and always will. Every second of our lives, over 7,000 atoms undergo radioactive decay in the body of the average adult. Radioactivity exists naturally in the soil, water, air and space. All of these common sources of radiation contribute to the natural background radiation that we are exposed to each day.

The earth is constantly showered by a steady stream of high energy gamma rays. These rays come from space and are known as cosmic radiation. Our atmosphere shields out most of this radiation, but everyone still receives about 20 to 50 millirem each year from this source. At high altitudes, the air is thinner and provides less protection from cosmic radiation. Because of this, people living at higher altitudes or even flying in an airplane are exposed to more radiation. Radioactive atoms commonly found in the atmosphere as a result of cosmic ray interactions include beryllium-7, carbon-14, tritium, and sodium-22.


Other natural sources of radiation include radionuclides naturally found in soil, water, food, building materials and even people. People have always been radioactive, in part because the carbon found in our bodies is a mixture of all carbon isotopes, both non-radioactive and radioactive. Approximately two-thirds of the whole body dose from natural sources is contributed by Radon gas. About one-third of the naturally occurring external terrestrial and internal whole body radiation dose is attributable to a naturally radioactive isotope of potassium, potassium-40.




## Man-Made

In addition to naturally occurring radiation, people are also exposed to man-made radiation. The largest sources of these exposures are from medical X-rays, fluoroscopic examinations, radioactive drugs, and tobacco. Small doses are received from consumer products such as television, smoke alarms, and fertilizers. Very small doses result from the production of nuclear power. Fallout from nuclear weapons tests is another source of man-made exposure. Fallout radionuclides include strontium-90, cesium-137, carbon-14, and tritium.

### Man-Made Sources



### Natural And Man-Made Sources



#### Man-Made

Medical	
Diagnostic X-Rays	39.00
Other Medical	14.00
Consumer Products	5.00 to 13.00
Occupational	0.90
Miscellaneous	
Environmental	0.06
Nuclear Power	0.05

#### Natural Background

Radon and Radon Daughters	200.00
Cosmic Rays	27.00
Cosmogenic Radiation	1.00
Terrestrial Radiation	28.00
Internal Radiation	40.00

**Total 360.00 MREM Per Year**

NCRP Report No. 93, "Ionizing Radiation Exposure of the Population of the United States," 30 Dec 1987, Bethesda, MD 20814

KC563

**Figure 8. Average Annual Dose Equivalent To Persons In The U.S. From Various Radiation Sources**

# ***Effects Of Radiation***

## ***Studies***

The effects of ionizing radiation on human health have been under study for more than eighty years. Scientists have obtained valuable knowledge through the study of laboratory animals that were exposed to radiation under controlled conditions. It has proven difficult, however, to relate the biological effects of irradiated laboratory animals to the potential health effects on humans. Because of this, human populations irradiated under various circumstances have been studied in great depth. These groups include:

- Survivors of the atomic bomb.
- Persons undergoing medical radiation treatment.
- Radium dial painters during World War I who ingested large amounts of radioactivity by "tipping" the paint brushes with their lips.
- Uranium miners, who inhaled large amounts of radioactive dust while mining pitchblende (uranium ore).
- Early radiologists, who accumulated large doses of radiation from early X-ray equipment while being unaware of the potential hazards.

Analysis of these groups has increased our knowledge of health effects resulting from large radiation doses. Less is known about the effects of low doses of radiation. To be on the conservative side, we assume that health effects occur proportionally to those observed following a large dose of radiation. That is, if one dose of radiation causes an effect, then half the dose will cause half the effect. Radiation scientists agree that this assumption overestimates the risks associated with low level radiation exposure. The effects predicted in this manner have not been actually observed in individuals exposed to low level radiation.

## ***Health Risks***

Since the actual effects of exposure to low level radiation are difficult to measure, scientists often refer to the possible risk involved. The problem is one of evaluating alternatives, of comparing risks and weighing them against benefits. People make decisions involving risks every day, such as deciding whether to wear seat belts or smoke cigarettes. Risks are a part of everyday life. The question is to determine how great the risks are.


We accept the inevitability of automobile accidents. Building safer cars or wearing seat belts will reduce the risk of injury. You could choose to not drive to be even safer, but pedestrians and bicyclists are also injured by cars. Reducing the risk of injury from automobiles to zero requires moving to a place where there are no automobiles.



While accepting the many daily risks of living, some people feel that their demands for energy should be met on an essentially risk-free basis. Attention is focused on safeguarding the public, developing a realistic assessment of the risks, and placing them in perspective.

Because you cannot see, feel, taste, hear, or smell radiation, it is often a source of concern. We have the same lack of sensory perception for things such as radio waves, carbon monoxide, and small concentrations of numerous cancer causing substances. Although these risks are just as real as the risks associated with radiation, they have not generated the same degree of concern as radiation.

Most risks are with us throughout our lives, and their effects can be added up over a lifetime to obtain a total effect on our life span. The typical life span for an American woman is now 76 years, whereas men average 71 years of age. Figure 9 shows a number of different factors that decreased our average life expectancy.



The American Cancer Society estimates that about 30 percent of all Americans will develop cancer at some time in their lives from all possible causes. So, in a group of 10,000 people it is expected that 3,000 of them will develop cancer. If each person were to receive a radiation exposure of one rem in addition to natural background radiation, then it is expected that three more may develop cancer during their lifetime. This increases the risk from 30 percent to 30.03 percent. Hence, the risks of radiation exposure are small when compared to the risks of everyday life.

These comparisons should give you some idea of the risk involved in activities that you are familiar with. They give a basis for judging what smoking, eating, or driving a car could mean to your health and safety. Everyone knows that life is full of risks. If you have the basis for judgment, you can decide what to do or what not to do.

## ***Nuclear Reactor Operation***


Electricity in the United States is being produced using fossil fuel, uranium, or falling water. A fossil-fueled power station burns coal, oil or natural gas in a boiler to produce energy. Nuclear power stations use uranium fuel and the heat produced from the fission process to make energy. In both cases, they heat and boil water to produce steam. The steam is used to drive a turbine which turns a generator and produces electricity.

### ***Nuclear Fuel***

Uranium (U) is the basic ingredient in nuclear fuel, consisting of U-235 and U-238 atoms. Natural uranium contains less than one percent U-235 when it is mined. Commercial nuclear power plants use fuel with a U-235 content of approximately three percent. The process used to increase the U-235 concentration is known as enrichment.

### ***Reactor Operation***

After enrichment, the uranium fuel is chemically changed to uranium dioxide, a dry black powder. This powder is compressed into small ceramic pellets. Each fuel pellet is about 3/4 inches long and 3/8 inches in diameter. The pellets are placed into 12 foot long metal tubes made of zirconium alloy to make a fuel rod. About five pounds of pellets are used to fill each rod. A total of 204 fuel rods make a single fuel assembly. Virginia Power nuclear reactors contains 157 fuel assemblies (Figure 10).




**Figure 10. Reactor Vessel With Fuel Assemblies, Rods, and Fuel Pellets**

## Fission

Nuclear energy is produced by a process called fission. Fission occurs in a reactor when uranium is split into fragments producing heat and releasing neutrons. These neutrons strike other uranium atoms, causing them to split (fission) and release more heat and neutrons. This is called a chain reaction (Figure 11) and is controlled by the use of reactor control rods.

Control rods are an essential part of the nuclear reactor. Control rods contain cadmium, indium, and silver metals which absorb and control the amount of neutrons produced in the reactor. The control rods act to slow down or stop the chain reaction. A chain reaction cannot occur when the control rods are inserted completely into the core. When the control rods are withdrawn, the chain reaction begins and heat is generated.



**Figure 11. Fission: A Chain Reaction**


## Design & Operation

Surry Power Station and North Anna Power Station use a Pressurized Water Reactor (PWR) system to generate electricity. There are two complete and independent PWR systems on-site at both Surry and North Anna Power Stations. These are referred to as Unit-1 and Unit-2.

The reactor core is inside a large steel container called the Reactor Pressure Vessel. The reactor core is always surrounded by water. The fissioning of the uranium fuel makes the fuel rods get hot. The hot fuel rods heat the water, which serves as a coolant that carries away heat.

In a pressurized water reactor, heat is moved from place to place by moving water, the reactor's coolant. The water flows in closed loops. As (primary) water moves through the core it gets very hot (605°F), but because it is under such high pressure, 2235 pounds per square inch (psi), it doesn't boil. The hot water then flows to the steam generator. The steam generator is a heat exchanger. Reactor coolant passes through it but doesn't mix with the steam generator (secondary) water. Instead, heat from the primary water is transferred through thousands of tubes to the cooler secondary water. The water in the steam generator is under much less pressure, and the heat boils the secondary water to steam. At Virginia Electric and Power stations, each unit has 3 steam generators.

The steam is piped to a steam turbine that turns an electric generator. The exhausted steam from the turbine is cooled and converted back to water in a condenser. The condenser is also a heat exchanger; in it heat passes from the steam to a third loop of water. In Surry's case the James River provides the third loop water. At North Anna Power Station third loop water is from Lake Anna. The steam turns back to liquid and is pumped back to the steam generator. Figure 12 is a diagram of typical nuclear reactor systems.




## Containment

Nuclear power plants are designed to prevent the escape of large quantities of radiation and radioactive substances. Two principles are used. First, thick, heavy walls are used as shielding to absorb radiation and prevent its escape. Second, strong, airtight walls called containment, are used to prevent the escape of radioactive materials.

The reactor pressure vessel and the containment building that houses it are enormously strong (Figure 13). Strong enough, in fact, to withstand a direct hit from a jet airliner. The reactor core lies within a sealed pressure vessel. Like all boilers its walls must be very strong because the water inside must be kept under high pressure. The reactor pressure vessel in a nuclear power plant is even heavier than an ordinary steam boiler because of the need to minimize the chance of rupture and release of any radioactive materials. The reactor pressure vessel is made from a stainless steel alloy 6 to 8 inches thick.

Around the reactor pressure vessel is a thick concrete wall. This wall acts as shielding, protecting workers by absorbing radiation resulting from the nuclear chain reaction. Next an airtight 1/2 inch steel liner surrounds the entire interior of the containment. If the reactor pressure vessel or any of the primary piping should break, the escaping steam would be trapped inside the liner.



Finally, the building's reinforced concrete outer wall is 4 1/2 feet thick tapering to 2 1/2 feet at the top of the dome. It is designed to act as shielding and is also intended to withstand natural and man-made events like earthquakes and even the direct impact from a large commercial jet aircraft.

## *Operating the Reactor Safely*

### *Accidents*

The most serious accident that could happen in a nuclear power plant involves overheating in the nuclear reactor core. Such an accident would result from a loss-of-coolant accident or LOCA. During a LOCA, primary coolant would no longer circulate through the reactor core to remove heat. Circulation could be lost if a combination of pipes burst, for example. Conceivably, a dry, overheated reactor core could melt through the pressure vessel.



The reactor itself is designed to respond automatically to such an emergency. Operators are also trained to make corrections for any system failure. The automatic and operator responses have two goals: to prevent damage to the reactor, and prevent the release of radiation. Shutting the reactor down is relatively easy. Control rods are inserted in the core and chemicals are injected into the coolant to stop the nuclear reaction. Losing the coolant itself tends to stop the chain reaction because the coolant is needed to keep the nuclear chain reaction going. Within 10 seconds of shutdown, the amount of heat is less than 5 percent of the amount produced at full power and within 15 minutes, less than 1 percent.

To carry heat away during an accident, all reactors have Emergency Core Cooling Systems (ECCS). The ECCS consists of primary and back-up pumps and reservoirs of coolant that operate separately from those that normally circulate through the system. A nuclear reactor has many different back-up safety systems designed so that if one fails another is always available.

### ***Workers***

There are many different jobs at a nuclear power plant and they are filled by people with diverse backgrounds. All employees are initially trained and then retrained annually by the company. Virginia Power's Training centers are fully accredited by the National Academy for Nuclear Training and the Institute for Nuclear Power Operations. The operators are tested and certified by the United States Nuclear Regulatory Commission (NRC).

### ***Safety Statistics***

Job safety is another measure of assurance that the station is being properly operated. Surry Power Station attained 6,000,000 man hours without a lost time accident and is continuing that record into 1996. North Anna Power Station has attained over 4,000,000 man hours without a lost time accident.

## ***Summary***

- Nuclear energy provides an alternate source of energy which is readily available. The operation of a nuclear power station has a very small impact on the environment.
- Radiation is not a new creation of the nuclear power industry; it is a natural occurrence on the earth. Mankind has always lived with radiation and always will. Radioactivity exists naturally in the soil, water, air and space. All these common sources of radiation contribute to the natural background radiation to which we are exposed.
- In addition to naturally occurring radiation and radioactivity, people are also exposed to man-made radiation. Very small doses result from the production of nuclear power.
- Nuclear power plants are designed to prevent the escape of radiation and radioactive substances.
- A nuclear reactor has many different back-up safety systems designed so that if one fails another is available.

### *III. SAMPLING AND ANALYSIS PROGRAM*

#### *A. Sampling Program*

1. Table 2 summarizes the sampling program for North Anna Power Station during 1995. Figure 1 indicates the locations of the environmental monitoring stations.
2. For routine TLD measurements, two dosimeters made of  $\text{CaSO}_4\text{:Dy}$  in a teflon card are deployed at each sampling location. Several TLDs are co-located with NRC and Commonwealth of Virginia direct radiation recording devices. These are indicated as "co-location" samples.
3. In addition to the Radiological Environmental Monitoring Program required by North Anna Technical Specifications, Virginia Electric and Power Company (VEPCO) splits samples with the Commonwealth of Virginia. All samples listed in Table 1 are collected by VEPCO personnel except for those labeled state split. All samples are shipped to Teledyne Brown Engineering located in Westwood, New Jersey.
4. All samples listed in Table 2 are taken at indicator locations except those labeled "control".

TABLE 2  
(Page 1 of 5)

North Anna Power Station - 1995  
RADIOLOGICAL SAMPLING STATIONS  
DISTANCE AND DIRECTION FROM UNIT NO. 1

Sample Media	Location	Station	Distance Miles	Compass Direction	Degrees	Collection Frequency	Remarks
Environmental Thermoluminescent Dosimetry (TLD)	NAPS Sewage Treatment Plant	01	0.20	NE	42°	Quarterly & Annually	On-site, State Split
	Fredericks Hall	02	5.30	SSW	225°	Quarterly & Annually	State Split
	Mineral, Va	03	7.10	WSW	243°	Quarterly & Annually	
	Wares Crossroads	04	5.10	WNW	287°	Quarterly & Annually	State Split
	Route 752	05	4.20	NNE	20°	Quarterly & Annually	
	Sturgeon's Creek Marina	05A	3.20	N	11°	Quarterly & Annually	
	Levy, VA	06	4.70	ESE	115°	Quarterly & Annually	State Split, Co-Location
	Bumpass, VA	07	7.30	SSE	167°	Quarterly & Annually	State Split
	End of Route 685	21	1.00	WNW	301°	Quarterly & Annually	Exclusion Boundary State Split, Co-Location
	Route 700	22	1.00	WSW	242°	Quarterly & Annually	Exclusion Boundary State Split
	"Aspen Hills"	23	0.93	SSE	158°	Quarterly & Annually	Exclusion Boundary State Split, Co-Location
	Orange, VA	24	22.00	NW	325°	Quarterly & Annually	Control
	Bearing Cooling Tower	N-1/33	0.06	N	10°	Quarterly	On-Site
	Sturgeon's Creek Marina	N-2/34	3.20	N	11°	Quarterly	
	Parking Lot "C" (on-site)	NNE-3/35	0.25	NNE	32°	Quarterly	On-Site
	Good Hope Church	NNE-4/36	4.96	NNE	25°	Quarterly	State Split
	Parking Lot "B"	NE-5/37	0.20	NE	42°	Quarterly	On-Site
	Lake Anna Marina	NE-6/38	1.49	NE	34°	Quarterly	
	Weather Tower Fence	ENE-7/39	0.36	ENE	74°	Quarterly	On-Site
	Route 689	ENE-8/40	2.43	ENE	65°	Quarterly	
	Near Training Facility	E-9/41	0.30	E	91°	Quarterly	On-Site



TABLE 2

(Page 2 of 5)

North Anna Power Station - 1995  
RADIOLOGICAL SAMPLING STATIONS  
DISTANCE AND DIRECTION FROM UNIT NO. 1

Sample Media	Location	Station	Distance Miles	Compass Direction	Degrees	Collection Frequency	Remarks
Environmental	"Morning Glory Hill"	E-10/42	2.85	E	93°	Quarterly	
Thermoluminescent	Island Dike	ESE-11/43	0.12	ESE	103°	Quarterly	On-Site
Dosimetry (TLD)	Route 622	ESE-12/44	4.70	ESE	115°	Quarterly	
	VEPCO Biology Lab	SE-13/45	0.75	SE	138°	Quarterly	On-Site
	Route 701 (Dam Entrance)	SE-14/46	5.88	SE	137°	Quarterly	
	"Aspen Hills"	SSE-15/47	0.93	SSE	158°	Quarterly	Exclusion Boundary
	Elk Creek	SSE-16/48	2.33	SSE	165°	Quarterly	
	Warehouse Compound	S-17/49	0.22	S	173°	Quarterly	On-Site
	Elk Creek Church	S-18/50	1.55	S	178°	Quarterly	
	500 Kv Tower	SSW-19/51	0.36	SSW	197°	Quarterly	On-Site
	Route 618	SSW-20/52	5.30	SSW	205°	Quarterly	
	NAPS Access Road	SW-21/53	0.30	SW	218°	Quarterly	On-Site
	Route 700	SW-22/54	4.36	SW	232°	Quarterly	
	NAPS Radio Tower	WSW-23/55	0.31	WSW	237°	Quarterly	On-Site
	Route 700	WSW-24/56	1.00	WSW	242°	Quarterly	Exclusion Boundary
	(Exclusion Boundary)						
	South Gate Construction Switchyard	W-25/57	0.25	W	279°	Quarterly	On-Site
	Route 685	W-26/58	1.55	W	274°	Quarterly	
	End of Route 685	WNW-27/59	1.00	WNW	301°	Quarterly	Exclusion Boundary
	H. Purcell's Private Rd.	WNW-28/60	1.52	WNW	303°	Quarterly	Co-Location
	North Gate Construction Side Laydown Area	NW-29/61	0.44	NW	321°	Quarterly	On-Site
	Lake Anna Campground	NW-30/62	2.54	NW	319°	Quarterly	
	#1/#2 Intake	NNW-31/63	0.07	NNW	349°	Quarterly	On-Site
	Route 208	NNW-32/64	3.43	NNW	344°	Quarterly	
	Bumpass Post Office	C-1/2	7.30	SSE	167°	Quarterly	Control
	Orange, VA	C-3/4	22.00	NW	325°	Quarterly	Control
	Mineral, VA	C-5/6	7.10	WSW	243°	Quarterly	Control
	Louisa, VA	C-7/8	11.54	WSW	257°	Quarterly	Control

TABLE 2

(Page 3 of 5)

North Anna Power Station - 1995

RADIOLOGICAL SAMPLING STATIONS  
DISTANCE AND DIRECTION FROM UNIT NO. 1

Sample Media	Location	Station	Distance Miles	Compass Direction	Degrees	Collection Frequency	Remarks
Airborne Particulate and Radiiodine	NAPS Sewage Treatment Plant	01	0.20	NE	42°	Weekly	On-Site, State Split
	Fredericks Hall	02	5.30	SSW	205°	Weekly	
	Mineral, VA	03	7.10	WSW	243°	Weekly	
	Wares Crossroads	04	5.10	WNW	287°	Weekly	
	Route 752	05	4.20	NNE	20°	Weekly	
	Sturgeon's Creek Marina	05A	3.20	N	11°	Weekly	
	Levy, VA	06	4.70	ESE	115°	Weekly	
	Bumpass, VA	07	7.30	SSE	167°	Weekly	
	End of Route 685	21	1.00	WNW	301°	Weekly	Exclusion Boundary
	Route 700	22	1.00	WSW	242°	Weekly	Exclusion Boundary
	"Aspen Hills"	23	0.93	SSE	158°	Weekly	State Split
	Orange, VA	24	22.00	NW	325°	Weekly	Exclusion Boundary Control
Surface Water	Waste Heat Treatment Facility (Second Cooling Lagoon)	08	1.10	SSE	148°	Monthly	State Split
	*Lake Anna (upstream) (Route 208 Bridge)	09	2.20	NW	320°	Monthly	Control, State Split
	*Lake Anna (upstream) (Route 669 Bridge)	09A	12.90	WNW	295°	Monthly	Control
River Water	North Anna River (downstream)	11	5.80	SE	128°	Monthly	
Ground Water (Well Water)	Biology Lab	01A	0.75	SE	138°	Quarterly	State Split
Precipitation	Biology Lab	01A	0.75	SE	138°	Monthly	
Aquatic Sediment	Waste Heat Treatment Facility (Second Cooling Lagoon)	08	1.10	SSE	148°	Semi-Annually	State Split
	Lake Anna (upstream)	09	2.20	NW	320°	Semi-Annually	Control, State Split
	North Anna River	11	5.80	SSE	128°	Semi-Annually	
	(Downstream)						

\* In October 1991 the Surface Water Sample location at station 09 was moved to 09A.

TABLE 2

(Page 4 of 5)

North Anna Power Station - 1995

## RADIOLOGICAL SAMPLING STATIONS

DISTANCE AND DIRECTION FROM UNIT NO. 1

Sample Media	Location	Station	Distance Miles	Compass Direction	Degrees	Collection Frequency	Remarks
Shoreline Soil	Lake Anna (upstream) (Route 208 Bridge)	09	2.20	NW	320°	Semi-Annually	State Split
Soil	NAPS Sewage Treatment Plant	01	0.20	NE	42°	Once/3 years	On-Site
	Fredericks Hall	02	5.30	SSW	205°	Once/3 years	
	Mineral, VA	03	7.10	WSW	243°	Once/3 years	
	Wares Crossroads	04	5.10	WNW	287°	Once/3 years	
	Route 752	05	4.20	NNE	20°	Once/3 years	
	Sturgeon's Creek Marina	05A	3.20	N	11°	Once/3 years	
	Levy, VA	06	4.70	ESE	115°	Once/3 years	
	Bumpass, VA	07	7.30	SSE	167°	Once/3 years	
	End of Route 685	21	1.00	WNW	301°	Once/3 years	Exclusion Boundary
	Route 700 (Exclusion Boundary)	22	1.00	WSW	242°	Once/3 years	Exclusion Boundary
	"Aspen Hills"	23	0.93	SSE	158°	Once/3 years	Exclusion Boundary
	Orange, VA	24	22.00	NW	325°	Once/3 years	Control
Milk	Holladay Dairy (R.C. Goodwin)	12	8.30	NW	310°	Monthly	State Split
	Terrell's Dairy (Fredericks Hall)	13	5.60	SSW	205°	Monthly	State Split
Fish***	Waste Heat Treatment Facility (Second Cooling Lagoon)	08	1.10	SSE	148°	Semi-Annually	State Split
	Lake Anna (upstream) (Route 208 Bridge)	09	2.20	NW	320°	Semi-Annually	State Split
	Lake Orange *	25	16.5	NW	312°	Semi-Annually	Control
Food Products (Broadleaf Vegetation)	Route 713	14	1.20	NE	43°	Monthly if available or at harvest	
	Route 614	15**	1.70(1.37)	SE	133°	Monthly if available or at harvest	

\* Added as result of 1990 Quality Assurance Audit.

\*\* Location changed as a result of 1991 Land Use Census to garden at 1.37 miles October 1991.

\*\*\* Fish sample no longer obtained at station #09.

TABLE 2

(Page 5 of 5)

North Anna Power Station - 1995

## RADIOLOGICAL SAMPLING STATIONS


DISTANCE AND DIRECTION FROM UNIT NO. 1


Sample Media	Location	Station	Distance Miles	Compass Direction	Degrees	Collection Frequency	Remarks
Food Products (Broadleaf Vegetation)	Route 629/522	16	12.60	NW	314°	Monthly if available or at harvest	
	End of Route 685	21	1.00	WNW	301°	Monthly if available or at harvest	
	Aspen Hills	23	0.93	SSE	158°	Monthly if available or at harvest	

*Legend For The North Anna Power Station  
Environmental Monitoring Stations Overview Maps*


Map Designation	Environmental Sta Identification	Map Designation	Environmental Sta Identification
1 (a)	01,NE-5/37	7/8	C-7&8
1A	01A,SE-13/45	1/33	N-1/33
2 (a)	02,SSW-20/52	31/63	NNW-31/63
3 (a)	03,C-5/16	29/61	NW-29/61
4 (a)	04	3/35	NNE-3/35
5 (a)	5	7/39	ENE-7/39
5A (a)	05A,N-2/34	9/41	E-9/41
6 (a)	6,ESE-12/44	11/93	ESE-11/43
7 (a)	07,C-1&2	17/49	S-17/49
8	8-Water, Fish Sediment	19/51	SSW-19/51
9	09-Shoreline Soil Stations NW-30/62	21/53	SW-21/53
9A	09A-Water sample, sediment	23/55	WSW-23/55
11	11-River Water, Sediment	25/57	W-25/57
12	12-Milk	16/48	SSE-16/48
13	13-Milk	18/50	S-18/50
14	14-Vegetation, NE-6/38	14/46	SE-14/46
15	Vegetation	22/54	SW-22/54
16	Vegetation	26/58	W-26/58
21 (a)	21,WNN-27/39	28/60	WNW-28/60
22 (a)	22,WSW-24/56	32/64	NNW-32/64
23 (a)	23-SSE-15/47	8/40	ENE-8/40
24 (a)(b)	24,C-3&4	4/36	NNE-40/36
25 (c)	25-Fish	10/42	E-10/42

- (a) Indicates air sample station, annual and quarterly TLD, Triennial soil  
 (b) In Orange  
 (c) In Lake Orange
















Original © 1991 by ADC of Alexandria, Inc. 6440 General Green Way, Alexandria, VA 22312. USED WITH PERMISSION. No other reproduction may be made without the written permission of ADC.

CB3281B

## ***B. Analysis Program***

1. Table 3 summarizes the analysis program conducted by Teledyne Brown Engineering for North Anna Power Station during 1995.

TABLE 3

(Page 1 of 3)

NORTH ANNA POWER STATION  
SAMPLE ANALYSIS PROGRAM

SAMPLE MEDIA	FREQUENCY	ANALYSIS	LLD*	REPORT UNITS
<b>Thermoluminescent Dosimetry (TLD)</b> (84 Routine Station TLD's)	Quarterly	Gamma Dose	2mR±2mR	mR/std. month
12 Station TLD's	Annually	Gamma Dose	2mR±2mR	mR/std. month
<b>Airborne Radioiodine</b>	Weekly	I-131	0.07	pCi/m <sup>3</sup>
<b>Airborne Particulate</b>	Weekly	Gross Beta	0.01	pCi/m <sup>3</sup>
	Quarterly (a)	Gamma Isotopic		pCi/m <sup>3</sup>
		Cs-134	0.05	
		Cs-137	0.06	
	Annually (2nd Quarter Composite)	Sr-89	(c)	pCi/m <sup>3</sup>
		Sr-90	(c)	
<b>Surface Water</b>	Monthly	I-131	1(b)	pCi/l
		Gamma Isotopic		pCi/l
		Mn-54	15	
		Fe-59	30	
		Co-58	15	
		Co-60	15	
		Zn-65	30	
		Zr-95	30	
		Nb-95	15	
		Cs-134	15	
		Cs-137	18	
		Ba-140	60	
		La-140	15	
	Quarterly (a)	Tritium (H-3)	2000	pCi/l
	2nd Quarterly	Sr-89	(c)	pCi/l
	Composite	Sr-90	(c)	

\* LLD's indicate those levels that the environmental samples should be analyzed to, in accordance with the North Anna Radiological Environmental Program. Actual analysis of the samples by Teledyne Brown Engineering may be lower than those listed.

(a) Quarterly Composites of each location's samples are used for the required analysis.

(b) LLD for non-drinking water is 10 pCi/liter.

(c) There are no required LLD's for strontium-89/90. LLD's are those achieved by Teledyne Brown Engineering.

TABLE 3

(Page 2 of 3)

NORTH ANNA POWER STATION  
SAMPLE ANALYSIS PROGRAM

SAMPLE MEDIA	FREQUENCY	ANALYSIS	LLD*	REPORT UNITS
River Water	Monthly	I-131	1(b)	pCi/l
		Gamma Isotopic		pCi/l
		Mn-54	15	
		Fe-59	30	
		Co-58/Co-60	15	
		Zn-65	30	
		Zr-95	30	
		Nb-95	15	
		Cs-134	15	
		Cs-137	18	
		Ba-140	60	
		La-140	15	
	Quarterly (a) 2nd Quarter Sample	Tritium (H-3)	2000	pCi/l
		Sr-89	(c)	pCi/l
		Sr-90	(c)	
Ground Water (Well Water)	Quarterly (a) 2nd Quarter Composite	Gamma Isotopic		pCi/l
		Mn-54	15	
		Fe-59	30	
		Co-58/Co-60	15	
		Zn-65	30	
		Zr-95	30	
		Nb-95	15	
		I-131	1(b)	
		Cs-134	15	
		Cs-137	18	
		Ba-140	60	
		La-140	15	
	Quarterly (a) 2nd Quarter Composite	Tritium (H-3)	2000	pCi/l
		Sr-89	(c)	
		Sr-90	(c)	
Aquatic Sediment	Semi-Annually	Gamma Isotopic		pCi/kg (dry)
		Cs-134	150	
		Cs-137	180	
	Annually	Sr-89	(c)	pCi/kg (dry)
		Sr-90	(c)	
Precipitation	Monthly	Gross Beta		pCi/l
	Semi-Annual	Gamma Isotopic		pCi/l
	Composite			

\* LLD's indicate those levels that the environmental samples should be analyzed to, in accordance with the North Anna Radiological Environmental Program. Actual analysis of the samples by Teledyne Brown Engineering may be lower than those listed.

(a) Quarterly Composites of each location's samples are used for the required analysis.

(b) LLD for non-drinking water is 10 pCi/liter.

(c) There are no required LLD's for strontium-89/90. LLD's are those achieved by Teledyne Brown Engineering.

**TABLE 3**  
(Page 3 of 3)  
**NORTH ANNA POWER STATION**  
**SAMPLE ANALYSIS PROGRAM**

<b>SAMPLE MEDIA</b>	<b>FREQUENCY</b>	<b>ANALYSIS</b>	<b>LLD*</b>	<b>REPORT UNITS</b>
<b>Shoreline Soil</b>	Semi-Annual	Gamma Isotopic		pCi/kg (dry)
		Cs-134	150	
		Cs-137	180	
	Annually	Sr-89	(a)	
		Sr-90	(a)	
<b>Soil</b>	Once per 3 yrs.	Gamma Isotopic		pCi/kg (dry)
		Cs-134	150	
		Cs-137	180	
	Once per 3 yrs.	Sr-89	(a)	pCi/kg (dry)
		Sr-90	(a)	
<b>Milk</b>	Monthly	I-131	1	pCi/l
	Monthly	Gamma Isotopic		pCi/l
		Cs-134	15	
		Cs-137	18	
		Ba-140	60	
		La-140	15	
	Quarterly	Sr-89	(a)	pCi/l
		Sr-90	(a)	
<b>Fish</b>	Semi-Annual	Gamma Isotopic		pCi/kg (wet)
		Mn-54	130	
		Fe-59	260	
		Co-58	130	
		Co-60	130	
		Zn-65	260	
		Cs-134	130	
		Cs-137	150	
<b>Food Products (Broadleaf Vegetation)</b>	Monthly if available or at harvest	Gamma Isotopic		pCi/kg (wet)
		Cs-134	60	
		Cs-137	80	
		I-131	60	pCi/kg (wet)

**Note:**

This table is not a complete listing of nuclides which can be detected and reported. Other peaks that are measurable and identifiable, together with the above nuclides, shall also be identified and reported.

\* LLD's indicate those levels that the environmental samples should be analyzed to, in accordance with the North Anna Radiological Environmental Program. Actual analysis of the samples by Teledyne Brown Engineering may be lower than those listed.

(a) There are no required LLD's for strontium-89/90. LLD's are those achieved by Teledyne Brown Engineering.

*Appendix B*  
*REMP Exceptions For Scheduled*  
*Sampling And Analysis During 1995 - North Anna*

<b>Location</b>	<b>Description</b>	<b>Date of Sampling</b>	<b>Reason(s) for Loss/Exception</b>
ENE-8	Direct Radiation/ TLD	03/29/95	TLD was missing from sampling location.
ENE-40	"	"	TLD was missing from sampling location.
W-27	Surface Water	11/30/95	LLD for I-131 not met due to late receipt of sample at laboratory.



## ***V. Summary And Discussion of 1995 Analytical Results***

Data from the radiological analyses of environmental media collected during 1995 are tabulated and discussed below. The procedures and specifications followed in the laboratory for these analyses are as required in the Teledyne Brown Engineering Quality Assurance Manual and are explained in the Teledyne Brown Engineering Analytical Procedures. A synopsis of analytical procedures used for the environmental samples is provided in Appendix D. In addition to internal quality control measures performed by Teledyne, the laboratory also participates in the Environmental Protection Agency's Interlaboratory Comparison Program. Participation in this program ensures that independent checks on the precision and accuracy of the measurements of radioactive material in environmental samples are performed. The results of the EPA Interlaboratory Comparison are provided in Appendix E.

Radiological analyses of environmental media characteristically approach and frequently fall below the detection limits of state-of-the-art measurement methods. The "less than" values in the data tables were calculated for each specific analysis and are dependent on sample size, detector efficiency, length of counting time, chemical yield, when appropriate, and the radioactive decay factor from time of counting to time of collection. Teledyne Brown Engineering's analytical methods meet the Lower Limit of Detection (LLD) requirements given in Table 2 of the USNRC Branch Technical Position, Radiological Monitoring Exceptable Program (November 1979, Revision 1) and the ODCM.


The following is a discussion and summary of the results of the environmental measurements taken during the 1995 reporting period.

### ***A. Airborne Exposure Pathway***


#### ***1. Air Iodine/Particulates***

Charcoal cartridges used to collect airborne iodine were collected weekly and analyzed by gamma spectrometry for iodine-131. The results are presented in Table B-1. All results were below the required lower limit of detection. For air particulates, gross beta activity was observed in all fifty-three control samples with an average concentration of 0.020 pCi/m<sup>3</sup> and a range of 0.009 to 0.033 pCi/m<sup>3</sup>. The average measurement for the indicator locations was 0.019 pCi/m<sup>3</sup> with a range of 0.004 to 0.031 pCi/m<sup>3</sup>. The results of the gross beta activities are presented in Table B-2. The gross beta activities for 1995 were comparable to levels measured in the 1982-1994 period. Prior to that period the gross beta activities were higher due to atmospheric nuclear weapons testing performed in other

TRENDING GRAPH-1: GROSS BETA IN AIR PARTICULATES



TRENDING GRAPH 2: TRITIUM IN RIVER WATER-STATION 11



During the preoperational period, tritium was not detected in the samples analyzed.

countries. During the preoperational period of July 1, 1974 through March 31, 1978 gross beta activities ranged from a low of 0.005 pCi/m<sup>3</sup> to a high of 0.75 pCi/m<sup>3</sup>.

Air particulate filters were composited by locations on a quarterly basis and were analyzed by gamma ray spectroscopy. The results are listed in Table B-3. Beryllium-7, which is produced continuously in the upper atmosphere by cosmic radiation, was measured in all 48 composite samples. The average measurement for the control location was 0.071 pCi/m<sup>3</sup> with a range of 0.050 to 0.079 pCi/m<sup>3</sup>. The indicator locations had an average concentration of 0.070 pCi/m<sup>3</sup> and a range of 0.048 to 0.088 pCi/m<sup>3</sup>. During the preoperational period, beryllium-7 was measured at comparable levels, as would be expected. Naturally occurring potassium-40 was detected in two control samples with an average concentration of 0.005 pCi/m<sup>3</sup> and a range of 0.004 to 0.006 pCi/m<sup>3</sup>. Potassium-40 was detected in eleven indicator samples with an average concentration of 0.011 pCi/m<sup>3</sup> and a range of 0.003 to 0.030 pCi/m<sup>3</sup>. All other gamma emitters were below the detection limits. During the preoperational period gamma ray spectroscopy measured several fission products in numerous air particulate filters. All isotopes were attributed to atmospheric nuclear weapons testing conducted before the preoperational period. Among the isotopes measured were zirconium-95, ruthenium-103, ruthenium-106, cesium-137, cerium-141 and cerium-144.

The second quarter composites of air particulate filters from all twelve stations were analyzed for strontium-89 and 90. There was no detection of these fission products at any of the eleven indicator stations nor at the control station.

## 2. Precipitation

A sample of rain water was collected monthly at station 01A, on site, 0.75 miles, 138 degrees SE and analyzed for gross beta activity. The results are presented in Table B-4. The average gross beta activity for 1995 in the twelve samples was 4.34 pCi/liter with a range from 0.86 to 13 pCi/liter. Semi-annual composites were prepared and analyzed for gamma emitting isotopes and tritium. Beryllium-7 was measured in one sample with a concentration of 61.5 pCi/liter. All other gamma emitters were below their detection limits. Tritium was not detected in the semi-annual composite samples. These results were comparable to or lower than those measured in 1986 thru 1994. During the preoperational period gross beta activity in rain water was expressed in nCi per square meter of the collector surface, thus a direct comparison can not be made to the 1995 period. During the

preoperational period, tritium was measured in over half of the few quarterly composites made. The tritium activity ranged from 100 to 330 pCi/liter.

### 3. Soil

Soil samples which are collected every three years from twelve stations, were collected in July and analyzed by gamma ray spectroscopy. The results are presented in Table B-5. Naturally occurring potassium-40 was detected in all twelve samples with an average activity of 11588 pCi/kg (dry weight) and a range of 3820 to 23100 pCi/kg (dry weight). Beryllium-7 was measured in one sample with an activity of 1090 pCi/kg (dry weight). The terrestrial nuclide radium-226 was monitored in ten samples with an average activity of 2083 pCi/kg (dry weight) and a range of 798 to 2900 pCi/kg (dry weight). Thorium-228 also naturally occurring was detected in all samples with an average activity of 1233 pCi/kg (dry weight) and a range of 335 to 2020 pCi/kg (dry weight). The fission product cesium-137 was detected in nine of the twelve samples at an average activity of 342 pCi/kg (dry weight) and a range of 58.5 to 767 pCi/kg (dry weight). The cesium-137 is attributed to past atmospheric nuclear weapons testing. Cesium-137 was not detected in the sample from station 24, the control station.

The twelve soil samples were analyzed for strontium-89 and strontium-90. There were no detections of strontium-89. Strontium-90 was detected in five of the twelve samples with an average activity of 105 pCi/kg (dry weight) and a range of 68 to 170 pCi/kg (dry weight). These fission products occurred in previous years and are believed to be from atmospheric nuclear weapons testing in previous years.

## **B. *Waterborne Exposure Pathway***

### 1. Ground/Well Water

Water was sampled quarterly from the on site well at the metrology laboratory. These samples were analyzed for gamma radiation and for tritium. The results are presented in Table B-6. No gamma emitting isotopes or tritium were detected during 1995. The second quarter sample was analyzed for strontium-89 and strontium-90. There were no detections of these isotopes above the detection level. No gamma emitting isotopes were detected during the preoperational period. Tritium was measured in most of the samples during that period with concentrations between 80 and 370 pCi/liter.

## 2. River Water

A sample of water from the North Anna River was collected monthly at station 11, 5.8 miles downstream from the discharge lagoon, 128 degrees SSE. The results are presented in Table B-7. The samples were analyzed by gamma spectroscopy monthly. The samples were analyzed for tritium quarterly on a composite sample. The second quarter samples were analyzed in addition for strontium-89 and strontium-90.

Potassium-40 was not measured during 1995 and all other gamma emitters were below the detection level. No detections of strontium-89 or strontium-90 occurred. Tritium was measured in all four samples with an average level of 2825 pCi/liter and a range of 2100 to 3600 pCi/liter. This is slightly higher than the average level measured in 1994 of 2400 pCi/liter and a range of 1800 to 3100 pCi/liter. No river water samples were collected during the preoperational period.


## 3. Surface Water

Samples of surface water were collected monthly from two stations. Station 08 is at the discharge lagoon, 1.1 miles, 148 degrees SSE on Lake Anna. Station 09A is located 12.9 miles WNW. The samples were analyzed for iodine-131 by radiochemical separation. No iodine was detected in the 24 samples analyzed. The results are presented in Table B-8. The samples were also analyzed by gamma ray spectrometry. No gamma emitters were below their detection levels at both station.


A quarterly composite from each station was prepared and analyzed for tritium. The tritium activity at station 08 for the quarterly composites was at an average level of 2775 pCi/liter with a range of 2100 to 3300 pCi/liter. The tritium level had been increasing since the middle of 1978 when the average level was below 300 pCi/liter. However, during 1995 the results were within the same range as those measured in 1986 thru 1994. During the preoperational period tritium was measured in several samples with concentrations between 90 and 250 pCi/liter. Tritium was not detected at station 09A.

Samples of surface water were collected by the Commonwealth of Virginia from two stations. Station W-33 is located at the discharge lagoon while station W-27 is located on the North Anna River at the RT. 208 Bridge, which is upstream of the site. Twenty-four samples were collected and analyzed by gamma ray spectroscopy. The results are presented in Table B-9. All gamma emitters were below their detection levels.

TRENDING GRAPH - 3: TRITIUM IN SURFACE WATER - STA 08



TRENDING GRAPH - 4: COBALT-58 IN SEDIMENT SILT





Four samples from each station were analyzed for tritium during 1995. The average activity at station W-33 in all samples was 3075 pCi/liter with a range of 2200 to 4200 pCi/liter. This is slightly higher than the 2600 pCi/liter measured during 1994 at this station. Tritium was measured in three samples at station W-27 with an average activity of 1033 pCi/liter and a range of 300 to 1500 pCi/liter. This is lower than the average of 1510 pCi/liter measured at station W-27 during 1994.

### *C. Aquatic Exposure Pathway*


#### *1. Sediment/Silt*

Sediment samples were collected during March and August from each of three locations and were analyzed by gamma spectrometry. The results are presented in Table B-10. One man-made and a number of naturally occurring radioisotopes were detected in these samples. Cesium-137 was detected in two samples with an average activity of 148 pCi/kg (dry weight) and a range from 66.2 to 229 pCi/kg (dry weight). The highest reading for cesium-137 was obtained from station 11 located 5.80 miles SSE.

Naturally occurring potassium-40 was observed in all six samples with an average activity of 13520 pCi/kg (dry weight) and a range from 2160 to 23700 pCi/kg (dry weight). Radium-226 was measured in five samples with an average concentration of 1113 pCi/kg (dry weight) and a range of 795 to 1590 pCi/kg (dry weight). Also naturally occurring, thorium-228 was observed in all six samples with an average concentration of 661 pCi/kg (dry weight) and a range of 348 to 1080 pCi/kg (dry weight). Cesium-137 was measured in one sample with a concentration of 66.2 pCi/kg (dry weight). The August samples were analyzed for strontium-89 and strontium-90. There were no detections of strontium-89 or strontium-90 in aquatic sediment/silt.


During the preoperational period sediment samples were analyzed by gamma ray spectroscopy. Cesium-137 was measured in most of the samples with concentrations between 33 and 1210 pCi/kg (dry weight). Strontium-90 was measured in most of the samples with concentrations between 60 and 540 pCi/kg (dry weight). Strontium-89 was not measured. Potassium-40, radium-226, and thorium-228, all naturally occurring, were measured at background levels.

TRENDING GRAPH - 5: COBALT-60 IN SEDIMENT SILT




During the preoperational period, cobalt-60 was not detected in the samples analyzed.

TRENDING GRAPH - 6: CESIUM-134 IN SEDIMENT SILT




During the preoperational period, cesium-134 was not detected in the samples analyzed.

TRENDING GRAPH - 7: CESIUM-137 IN SEDIMENT SILT



TRENDING GRAPH - 8: CESIUM-134 IN FISH



During the preoperational period, cesium-134 was not detected in the samples analyzed.  
 Station 25 replaced station 09

Station-08      Station-09      Control-Sta-25      Required LLD's

## 2. Shoreline Soil

A sample of shoreline sediment was collected in February and August from station 09, 2.2 miles upstream of the North Anna Power Station. The samples were analyzed by gamma ray spectrometry. The results are presented in Table B-11. The naturally occurring nuclide potassium-40 was measured in both samples with an average activity of 4190 pCi/kg (dry weight) and a range of 2200 to 6180 pCi/kg (dry weight). Cosmogenic beryllium-7 was measured in one sample with an activity of 466 pCi/kg (dry weight). Thorium-228 was measured in both samples at an average of 1056 pCi/kg (dry weight) and a range of 461 to 1650 pCi/kg (dry weight). Radium-226 was measured in both samples with an average activity of 1935 pCi/kg (dry weight) and a range of 1330 to 2540 pCi/kg (dry weight). Cesium-137, a fission product, was monitored in both samples with an average level of 341 pCi/kg (dry weight) and a range of 189 to 493 pCi/kg (dry weight).

The August sample was analyzed for strontium and there were no detections of strontium-89 or strontium-90.

### D. *Ingestion Exposure Pathway*

#### 1. Milk

The results of the iodine-131 analysis of milk samples are presented in Table B-12. A sample was collected monthly from two stations. A total of 24 samples were analyzed during 1995. There were no measurements of iodine-131 above the detection limits.

The milk samples were also analyzed by gamma ray spectroscopy and the results are also presented in Table B-12. A total of 24 samples were analyzed. Naturally occurring potassium-40 was measured in all samples with an average of 1364 pCi/liter and a range of 1170 to 1640 pCi/liter. The fission product cesium-137 has been detected sporadically in recent years and the activity has been attributed to global fallout from past atmospheric weapons testing. However, cesium-137 was not detected at levels above LLD in any milk samples during 1995. All other gamma emitters were below their detection levels. A quarterly composite was prepared from each of the two collection stations and analyzed for strontium-89 and strontium-90. Strontium-89 was not detected at levels above LLD in any of the samples monitored. Strontium-90 was detected in the eight samples monitored with an average level of 1.39 pCi/liter and a range of 0.96 to 2.1 pCi/liter. This is similar to activities determined in previous years and lower than the preoperational levels of 2.2 to 5.4 pCi/liter.

## 2. Fish


Aquatic biota can be sensitive indicators of radionuclide accumulation in the environment because of their ability to concentrate certain chemical elements which have radioactive isotopes. The results are presented in Table B-13. Eight samples of fish were collected during 1995. These samples were analyzed by gamma ray spectroscopy and the naturally occurring isotope potassium-40 was found in all samples at an average of 1475 pCi/kg (wet weight) with a range of 1200 to 2110 pCi/kg (wet weight). The fission product cesium-137 was measured in three samples at an average of 37.2 pCi/kg (wet weight) and a range of 26.2 to 49.9 pCi/kg (wet weight). During the preoperational period cesium-137 was measured in one-fourth of the fish samples collected with concentrations between 31 and 66 pCi/kg (wet weight). All other gamma emitters were below their detection levels.

## 3. Food/Vegetation


Thirty-five food samples were collected from five locations and analyzed by gamma spectrometry. The results are presented in Table B-14. Naturally occurring potassium-40 was monitored in all 35 samples with an average activity level of 14981 pCi/kg (wet weight) and a range of 4510 to 33400 pCi/kg (wet weight). Cosmogenic beryllium-7 was detected in 34 of the 35 samples with an average concentration of 1542 pCi/kg (wet weight) and a range of 318 to 5730 pCi/kg (wet weight). Radium was measured in four samples with an average activity of 805 (wet weight) and a range of 440 to 1250 pCi/kg (wet weight). The terrestrial nuclide thorium-228 was detected in nine samples at an average activity of 149 pCi/kg (wet weight) and a range of 41.3 to 260 pCi/kg (wet weight).

The fission product cesium-134 was not detected at levels above LLD during 1995. Cesium-137 was detected in seven samples with an average concentration of 56.2 pCi/kg (wet weight) and a range of 13.9 to 159 pCi/kg (wet weight). These results are consistent with those measured in previous years. Cesium-137 was measured in broadleaf garden vegetation during the preoperational period with concentrations between 53 and 98 pCi/kg (wet weight).

TRENDING GRAPH - 9: CESIUM-137 IN FISH



TRENDING GRAPH - 10: ENVIRONMENTAL RADIATION - TLD's





## *E. Direct Radiation Exposure Pathway*

### *1. TLD Dosimeters*

Thermoluminescent dosimeters (TLDs) determine environmental radiation doses and the results are presented in Table B-14. Individual measurements of external radiation levels in the environs of the North Anna site had an average dose of 5.5 mR/standard month with a range of 3.9 to 8.3 mR/standard month. This is comparable to the preoperational range. The control station, No. 24, had an average reading of 5.2 mR/standard month with a range of 4.9 to 5.3 mR/standard month.

Sector TLDs are deployed quarterly at thirty-two locations in the environs of the North Anna site. Two badges are placed at each location. The results are presented in Table B-15. The average level of the 32 locations (two badges at each location) was 6.2 mR/standard month with a range of 3.7 to 9.4 mR/standard month. The eight control TLDs, collected quarterly from four locations, showed an average reading of 5.1 mR/standard month with a range of 3.9 to 6.8 mR/standard month. During the preoperational period (starting in 1977), when the calculation of the TLD dose included a correction for the in-transit dose, the doses were measured between 4.3 and 8.8 mR/standard month.

## ***VI. Conclusions***

The results of the 1995 Radiological Environmental Monitoring Program for the North Anna Nuclear Power Station have been presented. The following sections discuss each pathway individually followed by a program summary.

### ***Airborne Exposure Pathway***

Air particulate gross beta concentrations of all the indicator locations for 1995 followed the gross beta concentrations at the control location. The gross beta concentrations were comparable to levels observed since 1982 except for a five week period in 1986 which was influenced by the Chernobyl accident. Gross beta concentrations in the preoperational period were highly variable, ranging from 0.0043 to 0.75 pCi/CuM, due to occasional atmospheric nuclear weapons tests. Gamma isotopic analysis of the particulate samples identified the gamma emitting isotopes as natural products (beryllium-7 and potassium-40). There were no detections above the LLD for fission products nor other man-made isotopes in the particulate media during the first three quarters of 1995. Iodine-131 was not detected in the charcoal filters analyzed during the first three quarters of 1995.

A precipitation sample was collected monthly during 1995 and analyzed for gross beta activity. All the gross beta activities were comparable to those measured in previous years. During the preoperational period the average gross beta activity was 0.92 pCi/liter. Semi-annual composites were analyzed for gamma emitting isotopes and tritium. All gamma emitters were below their detection limits. Tritium was not observed above the LLD during this reporting period in 1995. During the preoperational period the average tritium activity was 165 pCi/liter.

### ***Waterborne Exposure Pathway***

No man-made or natural isotopes were monitored in the surface water of Lake Anna except tritium. The average tritium activity during 1995 at the waste heat treatment facility was 2775 pCi/liter which is 14.0% of the reporting level for a water sample. In 1994 the tritium level was 2850 pCi/liter. The preoperational level was 150 pCi/liter and has been rising since 1977. Tritium was not measured upstream of the site, at station 09A.

The samples of surface water collected by the Commonwealth of Virginia at the waste heat treatment facility had similar tritium results with a measurement of 2200 pCi/liter as compared to

2237 pCi/liter for 1994. The upstream location had three measurements at an average activity of 1033 pCi/liter as compared to 1510 pCi/liter for 1994. No gamma emitting isotopes were detected.

River water collected from the North Anna River, 5.8 miles downstream of the site had an average tritium level of 2825 pCi/liter. The average tritium in 1994 had been 2400 pCi/liter. No gamma emitters were detected.

Ground water from the environmental well on site contained no gamma emitters. There were also no detections of tritium in ground/well water during 1993.

### *Aquatic Pathway*

Sediment/silt samples provide a sensitive indicator of discharges from nuclear power stations. The sediment from North Anna environmental samples indicated that one man-made isotopes was present. Cesium-137 was detected in two samples at two locations. During the preoperational period, cesium-137 was measured in samples of aquatic sediment. Sediment contamination does not provide a direct dose pathway to man.

The samples of shoreline soil monitored downstream of the site contained no measurement of cesium-134. Cesium-137 was measured in both samples at an average level of 341 pCi/kg which was higher than the average of 134 pCi/kg detected in 1994.

### *Ingestion Pathway*

Iodine-131 was not detected in any of the twenty-four milk samples using the radiochemical separation method. Although cesium-137 has been detected occasionally in previous years and attributed to past atmospheric nuclear weapons testing there were no detections during 1995. Strontium-90 was measured in all eight milk samples. Strontium-90 is attributed to past atmospheric nuclear weapons testing. No strontium-89 was detected in any of the milk samples. Naturally occurring potassium-40 was measured in all the milk samples at normal environmental levels.

Activity in fish and vegetation samples along with milk does present a direct dose pathway to man. Fish samples during 1995 showed the presence of one man-made isotope, cesium-137. This isotope was at an activity level somewhat higher than preoperational levels but statistically similar to levels in 1987 through 1994. Only cesium-137 was measured in preoperational environmental fish samples. Due to primary and secondary steam generator problems experienced at North Anna during 1984/1985, a build up in activity levels both in effluents and fish did occur.

Repairs to the steam generators and better liquid waste processing have reduced these activity levels in effluents and thus decreased activity levels are now being observed in the fish. The average level of activity during 1995 of cesium-137 was 3.4% of the reporting level.

Vegetation samples did not contained the man-made isotope cesium-137 during 1995. Cesium-137 was measured during 1993 and in preoperational samples.

### ***Direct Exposure Pathway***

The direct exposure pathway as measured in the environment of the North Anna site by thermoluminescent dosimetry has remained essentially the same since the preoperational period in 1977 at 6 milliroentgens per month or 0.2 milliroentgens per day. The average dose levels monitored have shown a normal fluctuation about these levels which are less than the estimated whole body dose due to natural terrestrial and cosmic radiation and the internal dose from natural radionuclides.

### ***Program Conclusions***

The results were as expected for normal environmental samples. Naturally occurring activity was observed in sample media in the expected activity ranges. Occasional samples of nearly all media showed the presence of man-made isotopes. These have been discussed individually in the text. Observed activities were at very low concentrations and had no significant dose consequence.

As a method of referencing the measured radionuclide concentrations in sample media to the dose consequence, the data may be compared to the Reporting Level Concentrations listed in the Offsite Dose Calculation Manual. These concentrations are based upon 25% of the annual dose commitment recommended by 10CFR50, Appendix I, to meet the criterion "As Low as is Reasonably Achievable." Based upon the evidence of the environmental monitoring program the station is operating within regulatory limits. Thus, no unusual radiological characteristics were observed in the environs of the North Anna Nuclear Power Station during 1995.

## *VII. References*

1. Virginia Electric and Power Company, North Anna Power Station Technical Specifications, Units 1 and 2.
2. Virginia Electric and Power Company, Station Administrative Procedure, VPAP-2103, "Offsite Dose Calculation Manual.
3. Title 10 Code of Federal Regulation, Part 50 (10CFR50), "Domestic Licensing of Production and Utilization Facilities."
4. United States Nuclear Regulatory Commission Regulatory Guide 1.109, Rev. 1, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10CFR50, Appendix I," October, 1977.
5. United States Nuclear Regulatory Commission, Regulatory Guide 4.8 "Environmental Technical Specifications for Nuclear Power Plants," December, 1975.
6. USNRC Branch Technical Position, "Acceptable Radiological Environmental Monitoring Program," Rev. 1, November 1979.
7. NUREG 0472, "Radiological Effluent Technical Specifications for PWRs," Rev. 3, March 1982.
8. National Council on Radiation Protection and Measurements, Report No. 39, "Basic Radiation Protection Criteria," Washington, D.C., January 1971.
9. National Council on Radiation Protection and Measurements, Report No. 45, "Natural Background Radiation in the United States," Washington, D.C., November 1975.
10. National Council on Radiation Protection and Measurements, Report No. 93, "Radiation Exposure of the Population of the United States, Washington, D.C., December, 1987.
11. National Council on Radiation Protection and Measurements, Report No. 95, "Radiation Exposure of the U.S. Population from Consumer Products and Miscellaneous Sources," Washington, D.C., December 1987.
12. DOE/NE-0072, "Nuclear Energy and Electricity, The Harnessed Atom," US Dept. of Energy, 1986.
13. Eichholz, G., "Environmental Aspects of Nuclear Power," Lewis Publishers, Inc., 1985.
14. Eisenbud, M., "Environmental Radioactivity," Academy Press, Inc., Orlando, Fl, 1987.
15. Fitzgibbon, W., "Energy Skill Builders, Nuclear Reactor," Enterprise for Education, Inc., 1987.
16. Glasstone, S., and Jordan, W., "Nuclear Power and its Environmental Effects," American Nuclear Society, 1982.

**APPENDIX A**  
**RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM**  
**ANNUAL SUMMARY TABLES - 1995**



# RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

North Anna Nuclear Power Station, Louisa County, Virginia - 1995

Docket No. 50-338/339

Page 1 of 7

Medium or Pathway Sampled (Unit)	Analysis		LLD*	All Indicator Locations	Location with Highest Mean			Control Location	Non-routine
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	Reported Measurements
Air Iodine (pCi/m <sup>3</sup> )	I-131	636	0.04	-(0/583)	N/A		N/A	-(0/53)	0
				-				-	
Airborne Particulates (1E-03 pCi/m <sup>3</sup> )	Gross	636	5	18.6(583-583)	24	22.0 mi NW	20.3(53/53)	20.3(53/53)	0
	Beta			(3.8-31)			(9.3-33)	(9.3-33)	
	Gamma	48							
	Be-7	48	10	70.1(44/44)	02	5.130mi WSW	74.5(4/4)	70.5(4/4)	0
				(47.9-87.9)			(59.9-83.0)	(49.5-78.8)	
	K-40	48	10	10.6(11/44)	22	1.0 mi WSW	25.3(1/4)	4.88(2/4)	0
Ground Well Water (pCi/liter)				(2.68-29.9)			-	(4.18-5.58)	
	Sr-89	12	3	-(0/11)	N/A		N/A	-(0/1)	0
				-				-	
	Sr-90	12	0.4	-(0/11)	N/A		N/A	-(0/1)	0
				-				-	
	Gamma	4							
	K-40	4	60	-(0/4)	N/A		N/A	-(0/0)	0
				-				-	
	Tritium	4	2000	-(0/4)	N/A		N/A	-(0/0)	0
				-				-	
	Sr-89	1	3	-(0/1)	N/A		N/A	-(0/0)	0
				-				-	
	Sr-90	1	0.4	-(0/1)	N/A		N/A	-(0/0)	0
				-				-	

<sup>1</sup> LLD is the Lower Limit of Detection as defined and required in USNRC Branch Technical Position on an Acceptable Radiological Environmental Monitoring Program, Revision 1, November 1979.

# RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

North Anna Nuclear Power Station, Louisa County, Virginia - 1995

Docket No. 50-338/339

Page 2 of 7

Medium or Pathway Sampled (Unit)	Analysis		LLD*	All Indicator Locations	Location with Highest Mean			Control Location	Non-routine Reported Measurements
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	
<b>River Water</b> (pCi/liter)	Gamma	12							
	K-40	12	200	-(0/12)	N/A		N/A	-(0/0)	0
				-				-	
	Tritium	4	2000	2825(4/4) (2100-3600)	11	5.8 mi.SSE	2825(4/4) (2100-3600)	-(0/0)	0
				-				-	
	Sr-89	1	3	-(0/1)	N/A		N/A	-(0/0)	0
				-				-	
	Sr-90	1	0.4	-(0/1)	N/A		N/A	-(0/0)	0
<b>Precipitation</b> (pCi/liter)	Monthly								
	Gross Beta	12	4	4.34(12/12) (0.86-13)	01A	0.2 mi. NE	4.34(12/12) (0.86-13)	-(0/0)	0
				-				-	
	Gamma (Semi-Annually)	2							
	Be-7	2	70	61.5(1/2)	01A	0.2 mi NE	61.5(1/2)	-(0/0)	0
<b>Surface Water</b> (pCi/liter)				-				-	
	I-131	24	0.5	-(0/12)	N/A		N/A	-(0/12)	0
				-				-	
	Regular Monthlies								
	Gamma	24							
	K-40	24	200	-(0/12)	N/A		N/A	-(0/12)	0
				-				-	
	Tritium	8	2000	2775(4/4) (2100-3300)	08	1.10 mi SSE	2775(4/4) (2100-3300)	-(0/4)	0

1 LLD is the Lower Limit of Detection as defined and required in USNRC Branch Technical Position on an Acceptable Radiological Environmental Monitoring Program, Revision 1, November 1979.

# RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

North Anna Nuclear Power Station, Louisa County, Virginia - 1995

Docket No. 50-338/339

Page 3 of 7

Medium or Pathway Sampled (Unit)	Analysis		LLD*	All Indicator Locations	Location with Highest Mean			Control Location	Non-routine Reported Measurements
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	
<b>Surface Water</b> (pCi/liter) Regular Monthlies	Sr-89	1		-(0/1) -	N/A		N/A	-(0/1) -	0
	Sr-90	1		-(0/1) -	N/A		N/A	-(0/1) -	0
<b>Surface Water</b> (pCi/liter) State Splits	Gamma	24							
	K-40	24	200	-(0/24) -	N/A		N/A	-(0/0) -	0
	Tritium	8	2000	2200(7/8) (300-4200)	W33		3075(4/4) (2200-4200)	-(0/0) -	0
<b>Sediment Silt</b> (pCi/kg (dry))	Gamma	6							
	K-40	6	200	12530(4/4) (2160-23700)	11 5.8 mi SSE		21300(2/2) (18900-23700)	15500(2/2) (12000-19000)	0
	Cs-137	6	194	148(2/4) (66.2-229)	11 5.8 mi SSE		229(1/2) -	-(0/2) -	0
	Ra-226	6	100	1315(3/4) (795-1590)	11 5.8 mi SSE		1575(2/2) (1560-1590)	810(2/2) (800-819)	0
	Th-228	6	30	774(4/4) (348-1080)	11 5.8 mi. SSE		1012(2/2) (943-1080)	435(2/2) (354-515)	0
	Sr-89 (Annually)	3	4.0	-(0/2) -	N/A		N/A	-(0/1) -	0
	Sr-90 (Annually)	3	0.8	-(0/2) -	N/A		N/A	-(0/1) -	0

<sup>1</sup> LLD is the Lower Limit of Detection as defined and required in USNRC Branch Technical Position on an Acceptable Radiological Environmental Monitoring Program, Revision 1, November 1979.

# RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

North Anna Nuclear Power Station, Louisa County, Virginia - 1995

Docket No. 50-338/339

Page 4 of 7

Medium or Pathway Sampled (Unit)	AN/Allysis		LLD*	All Indicator Locations	Location with Highest Mean			Control Location	Non-routine Reported Measurements
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	
Soil (pCi/kg (dry))	Gamma	12							
	Be-7	12		1090(1/11)	05A	3.20 mi N	1090(1/1)	-(0/1)	0
				-			-	-	
	K-40	12		12295(11/11) (4300-23100)	23	0.93 mi SSE	23100(1/1)	3820(1/1)	0
				-			-	-	
	Cs-134	12	100	-(0/11)	N/A		N/A	-(0/1)	0
				-			-	-	
	Cs-137	12	180	342(9/11) (58.5-767)	21	1.00 mi WNW	767(1/1)	-(0/1)	0
				-			-	-	
	Ra-226	12	100	2075(9/11) (798-2900)	06	2.2 mi. NW	2900(1/1)	2150(1/1)	0
				-			-	-	
	Th-228	12	30	1189(11/11) (335-2020)	06	2.2 mi. NW	2020(1/1)	1720(1/1)	0
				-			-	-	
	Sr-89 (Annually)	12	200	-(0/11)	N/A		N/A	-(0/1)	0
				-			-	-	
	Sr-90 (Annually)	12	40	105(5/11) (68-170)	05	4.20 mi NNE	170(1/1)	-(0/1)	0
				-			-	-	

<sup>1</sup> LLD is the Lower Limit of Detection as defined and required in USNRC Branch Technical Position on an Acceptable Radiological Environmental Monitoring Program, Revision 1, November 1979.

# RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

North Anna Nuclear Power Station, Louisa County, Virginia - 1995

Docket No. 50-338/339

Page 5 of 7

Medium or Pathway Sampled (Unit)	AN/Alsis		LLD*	All Indicator Locations	Location with Highest Mean			Control Location	Non-routine Reported Measurements
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	
<b>Shoreline Soil</b> (pCi/kg (dry))	Gamma	2							
	Be-7	2		466(1/2)	9 2.2 mi. NW		466(1/2)	-(0/0)	0
				-			-	-	
	K-40	2	200	4190(2/2) (2200-6180)	9 2.2 mi. NW		4190(2/2) (2200-6180)	-(0/0)	0
								-	
	Cs-137	2	40	341(2/2) (189-493)	9 2.2 mi. NW		341(2/2) (189-493)	-(0/0)	0
								-	
<b>Milk</b> (pCi/liter)	Ra-226	2	100	1935(2/2) (1330-2540)	9 2.2 mi. NW		1935(1/2) (1330-2540)	-(0/0)	0
								-	
	Th-228	2	30	1056(2/2) (461-1650)	9 2.2 mi. NW		1056(2/2) (461-1650)	-(0/0)	0
								-	
	Sr-89 (Annually)	1	4.0	-(0/1)	N/A		N/A	-(0/0)	0
				-				-	
	Sr-90 (Annually)	1	0.8	-(0/1)	N/A		N/A	-(0/0)	0
<b>Milk</b> (pCi/liter)				-				-	
	I-131	24	0.5	-(0/24)	N/A		N/A	-(0/0)	0
				-				-	
	Gamma	24							
	K-40	24	100	1364(24/24) (1170-1640)	12 8.3 mi. NW		1423(12/12) (1320-1640)	-(0/0)	0
								-	
	Sr-89 (Quarterly)	8	5	-(0/8)	N/A		N/A	-(0/0)	0
<b>Milk</b> (pCi/liter)				-				-	
	Sr-90 (Quarterly)	8	0.8	1.39(8/8) (0.96-2.1)	13 5.60 mi. SSW		1.60(4/4) (1.2-2.1)	-(0/0)	0
								-	

<sup>1</sup> LLD is the Lower Limit of Detection as defined and required in USNRC Branch Technical Position on an Acceptable Radiological Environmental Monitoring Program, Revision 1, November 1979.

# RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

North Anna Nuclear Power Station, Louisa County, Virginia - 1995

Docket No. 50-338/339

Page 6 of 7

Medium or Pathway Sampled (Unit)	Analysis		LLD*	All Indicator Locations	Location with Highest Mean			Control Location	Non-routine Reported Measurements
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	
Fish pCi/kg (wet)	Gamma	8							
	K-40	8	200	1460(4/4) (1200-1650)	25	16.5 mi. NW	1490(4/4) (1220-2110)	1490(4/4) (1220-2110)	0
	Cs-137	8	40	37.2(3/4) (26.2-49.9)	08	1.10 mi. SSE	37.2(3/4) (26.2-49.9)	-(0/4) -	0
Food Vegetation (pCi/kg (wet))	Gamma	35							
	Dose								
	Be-7	35	-	1542(34/35) (318-5730)	16	12.6 mi NW	1988(7/7) (318-5730)	-(0/0) -	0
	K-40	35	-	14981(35/35) (4510-33400)	15	1.37 mi. SE	17547(7/7) (9730-33400)	-(0/0) -	0
	Cs-137	35	80	56.2(7/35) (13.9-159)	16	12.6 mi. NW	86.5(2/7) (13.9-159)	-(0/0) -	0
	Ra-226	35	-	805(4/35) (440-1250)	15	1.37 mi. SE	1250(1/7) -	-(0/0) -	0
Th-228	35	-	149(9/35) (41.3-260)	21	1.00 mi WNW	224(2/7) (187-260)	-(0/0) -	0	

<sup>1</sup> LLD is the Lower Limit of Detection as defined and required in USNRC Branch Technical Position on an Acceptable Radiological Environmental Monitoring Program, Revision 1, November 1979.

# RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

North Anna Nuclear Power Station, Louisa County, Virginia - 1995

Docket No. 50-338/339

Page 7 of 7

Medium or Pathway Sampled (Unit)	Analysis		LLD*	All Indicator Locations	Location with Highest Mean			Control Location	Non-routine Reported Measurements
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	

<b>Direct Radiation</b> (mR/std. month) (Regular TLDs)	Gamma Dose	48	0.2	5.60(44/44) (3.9-8.3)	01	0.2 mi. NE	7.75(4/4) (7.4-8.3,	5.18(4/4) (4.9-5.3)	0
--	------------	----	-----	--------------------------	----	------------	------------------------	------------------------	---

<b>Direct Radiation</b> (mR/std. Month) (Annual TLDs)	Gamma Dose	12	0.2	5.57(11/11) (4.3-7.7)	01	0.2 mi. NE	7.7(1/1) -	5.2(1/1) -	0
---	------------	----	-----	--------------------------	----	------------	---------------	---------------	---

<b>Direct Radiation</b> (mR/std. Month) (Sector TLDs)	Gamma Dose	286	0.2	6.23(254/254) (3.7-9.4)	21/53	0.30 mi. SW	8.59(8/8) (8.1-9.4)	5.08(32/32) (3.9-6.8)	0
---	------------	-----	-----	----------------------------	-------	-------------	------------------------	--------------------------	---

<sup>1</sup> LLD is the Lower Limit of Detection as defined and required in USNRC Branch Technical Position on an Acceptable Radiological Environmental Monitoring Program, Revision 1, November 1979.



**APPENDIX B**  
**DATA TABLES**

**TABLE B-1: IODINE-131 CONCENTRATIONS IN FILTERED AIR**

North Anna Power Station, Louisa County, Virginia - 1995

pCi/m<sup>3</sup> ± 2 Sigma

Page 1 of 2

Collection Date	01	02	03	04	STATIONS		06	07	21	22	23	24
					05	05A						
<b>JANUARY</b>												
12/28-01/05(a)	< .01	< .01	< .02	< .02	< .01	< .02	< .02	< .01	< .01	< .006	< .02	< .02
01/05-01/11(b)	< .02	< .02	< .02	< .01	< .03	< .02	< .02	< .02	< .02	< .009	< .02	< .01
01/11-01/18	< .01	< .01	< .01	< .01	< .007	< .01	< .01	< .01	< .01	< .009	< .02	< .02
01/18-01/25	< .01	< .01	< .01	< .01	< .009	< .02	< .02	< .02	< .02	< .01	< .01	< .01
01/25-02/01	< .02	< .02	< .02	< .02	< .007	< .01	< .01	< .01	< .01	< .009	< .02	< .02
<b>FEBRUARY</b>												
02/01-02/08	< .02	< .02	< .02	< .02	< .007	< .02	< .02	< .02	< .02	< .009	< .02	< .02
02/08-02/15	< .02	< .02	< .02	< .02	< .01	< .02	< .02	< .02	< .02	< .01	< .01	< .01
02/15-02/22	< .01	< .01	< .01	< .01	< .008	< .01	< .01	< .01	< .01	< .008	< .02	< .01
02/22-03/01	< .01	< .01	< .01	< .01	< .009	< .02	< .02	< .02	< .02	< .01	< .02	< .008
<b>MARCH</b>												
03/01-03/08	< .01	< .01	< .01	< .01	< .008	< .02	< .02	< .02	< .02	< .01	< .01	< .02
03/08-03/15	< .01	< .01	< .01	< .01	< .009	< .01	< .01	< .01	< .01	< .007	< .02	< .02
03/15-03/22	< .01	< .01	< .01	< .01	< .007	< .02	< .02	< .02	< .02	< .01	< .009	< .009
03/22-03/29	< .02	< .02	< .02	< .02	< .01	< .02	< .02	< .02	< .02	< .01	< .01	< .01
<b>APRIL</b>												
03/29-04/05	< .01	< .01	< .01	< .01	< .009	< .02	< .02	< .02	< .02	< .01	< .01	< .01
04/05-04/12	< .01	< .01	< .01	< .01	< .006	< .01	< .01	< .01	< .01	< .008	< .02	< .02
04/12-04/19	< .01	< .01	< .01	< .01	< .009	< .02	< .02	< .02	< .02	< .01	< .009	< .009
04/19-04/26	< .01	< .01	< .01	< .01	< .009	< .01	< .01	< .01	< .01	< .01	< .02	< .01
04/26-05/03	< .01	< .01	< .01	< .03	< .008	< .02	< .02	< .02	< .02	< .01	< .01	< .01
<b>MAY</b>												
05/03-05/10	< .02	< .02	< .02	< .02	< .01	< .02	< .02	< .02	< .02	< .01	< .01	< .01
05/10-05/17	< .01	< .01	< .01	< .01	< .009	< .02	< .02	< .02	< .02	< .01	< .02	< .02
05/17-05/24	< .01	< .01	< .01	< .01	< .01	< .02	< .02	< .02	< .02	< .01	< .02	< .02
05/24-05/31	< .02	< .02	< .02	< .02	< .01	< .01	< .01	< .01	< .01	< .009	< .01	< .01
<b>JUNE</b>												
05/31-06/07	< .02	< .02	< .02	< .02	< .01	< .01	< .01	< .01	< .01	< .008	< .01	< .01
06/07-06/14	< .01	< .01	< .01	< .01	< .008	< .02	< .02	< .02	< .02	< .01	< .01	< .01
06/14-06/21	< .01	< .01	< .01	< .01	< .008	< .02	< .02	< .02	< .02	< .01	< .008	< .01
06/21-06/28	< .02	< .02	< .02	< .02	< .01	< .02	< .02	< .02	< .02	< .01	< .01	< .01

(a) Several stations had a stop date of 01/04/95.

(b) Several stations had a start date of 01/04/95.

**TABLE B-1: IODINE-131 CONCENTRATION IN FILTERED AIR**

North Anna Power Station, Louisa County, Virginia - 1995

pCi/m<sup>3</sup> ± 2 Sigma

Page 2 of 2

Collection Date	STATIONS											
	01	02	03	04	05	05A	06	07	21	22	23	24
<b>JULY</b>												
06/28-07/05	< .02	< .02	< .02	< .02	< .01	< .02	< .02	< .02	< .02	< .01	< .02	< .01
07/05-07/12	< .02	< .02	< .02	< .02	< .01	< .02	< .02	< .02	< .02	< .01	< .02	< .01
07/12-07/19	< .02	< .02	< .02	< .02	< .01	< .01	< .01	< .01	< .01	< .009	< .01	< .01
07/19-07/27	< .01	< .01	< .01	< .01	< .007	< .01	< .01	< .01	< .01	< .01	< .008	< .008
07/27-08/02	< .02	< .02	< .02	< .02	< .01	< .02	< .02	< .02	< .02	< .009	< .02	< .02
<b>AUGUST</b>												
08/02-08/09	< .01	< .01	< .01	< .01	< .009	< .02	< .02	< .02	< .02	< .01	< .01	< .01
08/09-08/17	< .02	< .02	< .02	< .02	< .01	< .01	< .01	< .01	< .01	< .008	< .01	< .009
08/17-08/23	< .02	< .02	< .02	< .02	< .01	< .02	< .02	< .02	< .02	< .01	< .02	< .02
08/23-08/30	< .01	< .01	< .01	< .01	< .009	< .01	< .01	< .01	< .01	< .009	< .02	< .02
<b>SEPTEMBER</b>												
08/30-09/06	< .01	< .01	< .01	< .01	< .008	< .02	< .02	< .02	< .02	< .01	< .02	< .01
09/06-09/13	< .02	< .02	< .02	< .02	< .01	< .01	< .01	< .01	< .01	< .009	< .02	< .02
09/13-09/20	< .02	< .02	< .02	< .02	< .01	< .02	< .02	< .02	< .02	< .01	< .01	< .01
09/20-09/27	< .02	< .02	< .02	< .02	< .01	< .01	< .01	< .01	< .01	< .008	< .05	< .05
09/27-10/04	< .01	< .01	< .01	< .01	< .009	< .02	< .02	< .02	< .02	< .01	< .01	< .01
<b>OCTOBER</b>												
10/04-10/11	< .01	< .01	< .01	< .01	< .008	< .009	< .009	< .009	< .009	< .007	< .01	< .01
10/11-10/18	< .02	< .02	< .02	< .02	< .01	< .009	< .009	< .009	< .009	< .007	< .01	< .01
10/18-10/25	< .01	< .01	< .01	< .01	< .008	< .009	< .009	< .009	< .009	< .006	< .01	< .01
10/25-11/01	< .01	< .01	< .01	< .01	< .008	< .01	< .01	< .01	< .01	< .009	< .01	< .01
<b>NOVEMBER</b>												
11/01-11/09	< .01	< .01	< .01	< .01	< .008	< .01	< .01	< .01	< .01	< .008	< .008	< .007
11/09-11/16	< .01	< .01	< .01	< .01	< .008	< .01	< .01	< .01	< .01	< .006	< .02	< .007
11/16-11/22	< .02	< .02	< .02	< .02	< .01	< .02	< .02	< .02	< .02	< .01	< .02	< .02
11/22-11/29	< .01	< .01	< .01	< .01	< .008	< .01	< .01	< .01	< .01	< .008	< .01	< .01
<b>DECEMBER</b>												
11/29-12/06	< .01	< .01	< .01	< .01	< .008	< .01	< .01	< .01	< .01	< .009	< .01	< .01
12/06-12/13	< .01	< .01	< .01	< .01	< .009	< .009	< .009	< .009	< .009	< .007	< .01	< .01
12/13-12/20	< .02	< .03	< .03	< .03	< .02	< .02	< .02	< .02	< .02	< .01	< .03	< .03
12/20-12/27	< .02	< .02	< .02	< .02	< .01	< .02	< .02	< .02	< .02	< .01	< .02	< .007
12/27-01/03	< .01	< .009	< .01	< .01	< .007	< .02	< .02	< .02	< .02	< .02	< .01	< .01

TABLE B-2

(Page 1 of 4)

NORTH ANNA - 1995

## CONCENTRATIONS OF GROSS BETA IN AIR PARTICULATES

 $1.0\text{E-}03 \text{ pCi/m}^3 \pm 2 \text{ Sigma}$ 

COLLECTION DATE	01	02	03	04	05	05A	06	07	21	22	23	24	AVERAGE $\pm 2 \text{ s.d.}$
<b>JANUARY</b>													
12/28-01/05 (a)	21 $\pm$ 2	21 $\pm$ 2	20 $\pm$ 2	25 $\pm$ 2	16 $\pm$ 2	22 $\pm$ 2	21 $\pm$ 2	18 $\pm$ 2	20 $\pm$ 2	20 $\pm$ 2	18 $\pm$ 2	21 $\pm$ 2	20 $\pm$ 5
01/05-01/11 (b)	27 $\pm$ 2	24 $\pm$ 2	26 $\pm$ 2	28 $\pm$ 2	21 $\pm$ 4	27 $\pm$ 2	24 $\pm$ 2	26 $\pm$ 2	25 $\pm$ 2	26 $\pm$ 2	27 $\pm$ 2	29 $\pm$ 2	26 $\pm$ 4
01/11-01/18	18 $\pm$ 2	17 $\pm$ 2	19 $\pm$ 2	18 $\pm$ 2	17 $\pm$ 2	16 $\pm$ 2	12 $\pm$ 2	13 $\pm$ 2	16 $\pm$ 2	12 $\pm$ 2	14 $\pm$ 2	17 $\pm$ 2	16 $\pm$ 5
01/18-01/25	12 $\pm$ 2	13 $\pm$ 2	12 $\pm$ 2	14 $\pm$ 2	11 $\pm$ 2	10 $\pm$ 1	12 $\pm$ 2	12 $\pm$ 2	11 $\pm$ 2	11 $\pm$ 2	13 $\pm$ 2	12 $\pm$ 2	12 $\pm$ 2
01/25-02/01	18 $\pm$ 2	19 $\pm$ 2	19 $\pm$ 2	17 $\pm$ 2	17 $\pm$ 2	15 $\pm$ 2	16 $\pm$ 2	16 $\pm$ 2	19 $\pm$ 2	18 $\pm$ 2	17 $\pm$ 2	18 $\pm$ 2	17 $\pm$ 3
<b>FEBRUARY</b>													
02/01-02/08	21 $\pm$ 2	24 $\pm$ 2	26 $\pm$ 2	23 $\pm$ 2	24 $\pm$ 2	23 $\pm$ 2	23 $\pm$ 2	22 $\pm$ 2	21 $\pm$ 2	25 $\pm$ 2	22 $\pm$ 2	25 $\pm$ 2	23 $\pm$ 3
02/08-02/15	24 $\pm$ 2	22 $\pm$ 2	22 $\pm$ 2	22 $\pm$ 2	17 $\pm$ 2	20 $\pm$ 2	22 $\pm$ 2	21 $\pm$ 2	20 $\pm$ 2	18 $\pm$ 2	20 $\pm$ 2	24 $\pm$ 2	21 $\pm$ 4
02/15-02/22	22 $\pm$ 2	21 $\pm$ 2	18 $\pm$ 2	19 $\pm$ 2	18 $\pm$ 2	21 $\pm$ 2	18 $\pm$ 2	17 $\pm$ 2	17 $\pm$ 2	18 $\pm$ 2	19 $\pm$ 2	21 $\pm$ 2	19 $\pm$ 4
02/22-03/01	16 $\pm$ 2	14 $\pm$ 2	15 $\pm$ 2	17 $\pm$ 2	14 $\pm$ 2	11 $\pm$ 2	17 $\pm$ 2	12 $\pm$ 2	12 $\pm$ 2	13 $\pm$ 2	16 $\pm$ 2	18 $\pm$ 2	15 $\pm$ 5
<b>MARCH</b>													
03/01-03/08	20 $\pm$ 2	18 $\pm$ 2	20 $\pm$ 2	21 $\pm$ 2	18 $\pm$ 2	17 $\pm$ 2	16 $\pm$ 2	19 $\pm$ 2	17 $\pm$ 2	16 $\pm$ 2	17 $\pm$ 2	16 $\pm$ 2	18 $\pm$ 4
03/08-03/15	28 $\pm$ 2	25 $\pm$ 2	24 $\pm$ 2	26 $\pm$ 2	27 $\pm$ 2	26 $\pm$ 2	20 $\pm$ 2	23 $\pm$ 2	20 $\pm$ 2	22 $\pm$ 2	26 $\pm$ 2	26 $\pm$ 2	24 $\pm$ 5
03/15-03/22	19 $\pm$ 2	21 $\pm$ 2	19 $\pm$ 2	20 $\pm$ 2	19 $\pm$ 2	22 $\pm$ 2	19 $\pm$ 2	19 $\pm$ 2	18 $\pm$ 2	17 $\pm$ 2	18 $\pm$ 2	18 $\pm$ 2	19 $\pm$ 3
03/22-03/29	17 $\pm$ 2	18 $\pm$ 2	14 $\pm$ 2	17 $\pm$ 2	15 $\pm$ 2	15 $\pm$ 2	15 $\pm$ 2	15 $\pm$ 2	15 $\pm$ 2	15 $\pm$ 2	16 $\pm$ 2	18 $\pm$ 2	16 $\pm$ 3
Quarter Avg. $\pm 2 \text{ s.d.}$	20 $\pm$ 9	20 $\pm$ 7	20 $\pm$ 9	21 $\pm$ 8	18 $\pm$ 8	19 $\pm$ 11	18 $\pm$ 8	18 $\pm$ 9	18 $\pm$ 8	18 $\pm$ 9	19 $\pm$ 8	20 $\pm$ 9	20 $\pm$ 9

(a) Several stations had a stop date of 01/04/95.

(b) Several stations had a start date of 01/04/95.

TABLE B-2

(Page 2 of 4)

NORTH ANNA - 1995

## CONCENTRATIONS OF GROSS BETA IN AIR PARTICULATES

1.0E-03 pCi/m<sup>3</sup> ± 2 Sigma

COLLECTION DATE	01	02	03	04	05	05A	06	07	21	22	23	24	AVERAGE ± 2 s.d.
<b>APRIL</b>													
03/29-04/05	20 ± 2	21 ± 2	18 ± 2	18 ± 2	21 ± 2	20 ± 2	15 ± 2	20 ± 2	17 ± 2	21 ± 2	23 ± 2	22 ± 2	20 ± 5
04/05-04/12	18 ± 2	19 ± 2	21 ± 2	26 ± 2	22 ± 2	24 ± 2	21 ± 2	21 ± 2	21 ± 2	22 ± 2	22 ± 2	26 ± 2	22 ± 5
04/12-04/19	21 ± 2	19 ± 2	18 ± 2	18 ± 2	17 ± 2	16 ± 2	16 ± 2	17 ± 2	16 ± 2	18 ± 2	16 ± 2	19 ± 2	18 ± 3
04/19-04/26	16 ± 2	15 ± 2	16 ± 2	13 ± 2	13 ± 2	15 ± 2	15 ± 2	13 ± 2	13 ± 2	14 ± 2	13 ± 2	16 ± 2	14 ± 3
04/26-05/03	13 ± 2	14 ± 2	13 ± 2	19 ± 3	13 ± 2	13 ± 2	13 ± 2	13 ± 2	13 ± 2	13 ± 2	14 ± 2	16 ± 2	14 ± 4
<b>MAY</b>													
05/03-05/10	17 ± 2	17 ± 2	17 ± 2	18 ± 2	16 ± 2	16 ± 2	16 ± 2	15 ± 2	15 ± 2	15 ± 2	18 ± 2	18 ± 2	17 ± 2
05/10-05/17	14 ± 2	13 ± 2	11 ± 1	13 ± 2	3.8 ± 1.1 (a)	13 ± 2	13 ± 2	12 ± 2	12 ± 2	13 ± 2	13 ± 2	11 ± 1	12 ± 5
05/17-05/24	22 ± 2	19 ± 2	20 ± 2	20 ± 2	18 ± 2	18 ± 2	20 ± 2	18 ± 2	19 ± 2	19 ± 2	17 ± 2	19 ± 2	19 ± 3
05/24-05/31	15 ± 2	13 ± 2	12 ± 2	14 ± 2	12 ± 2	14 ± 2	12 ± 2	12 ± 2	12 ± 2	14 ± 2	12 ± 2	15 ± 2	13 ± 2
<b>JUNE</b>													
05/31-06/07	9.6 ± 1.5	13 ± 2	13 ± 2	14 ± 2	13 ± 2	12 ± 2	13 ± 2	12 ± 2	13 ± 2	11 ± 2	14 ± 2	12 ± 2	12 ± 2
06/07-06/14	16 ± 2	14 ± 2	14 ± 2	17 ± 2	13 ± 2	14 ± 2	16 ± 2	15 ± 2	14 ± 2	13 ± 2	15 ± 2	14 ± 2	15 ± 2
06/14-06/21	17 ± 2	17 ± 2	16 ± 2	17 ± 2	14 ± 2	18 ± 2	14 ± 2	13 ± 2	14 ± 2	16 ± 2	15 ± 2	19 ± 2	16 ± 4
06/21-06/28	12 ± 2	8.5 ± 1.3	9.3 ± 1.4	10 ± 1	8.7 ± 1.4	9.8 ± 1.4	7.9 ± 1.3	8.3 ± 1.3	11 ± 1	10 ± 1	11 ± 1	9.3 ± 1.4	10 ± 2
Quarter Avg. ± 2 s.d.	16 ± 7	16 ± 7	15 ± 7	17 ± 8	14 ± 10	16 ± 7	15 ± 7	15 ± 7	15 ± 6	15 ± 7	16 ± 7	17 ± 9	15 ± 7

(a) Results confirmed by recalculation.

TABLE B-2

(Page 3 of 4)

NORTH ANNA - 1995

CONCENTRATIONS OF GROSS BETA IN AIR PARTICULATES

 $1.0\text{E-}03 \text{ pCi/m}^3 \pm 2 \text{ Sigma}$ 

COLLECTION DATE	01	02	03	04	05	05A	06	07	21	22	23	24	AVERAGE $\pm 2 \text{ s.d.}$
<b>JULY</b>													
06/28-07/05	15 $\pm$ 2	14 $\pm$ 2	12 $\pm$ 2	13 $\pm$ 2	13 $\pm$ 2	12 $\pm$ 2	12 $\pm$ 2	12 $\pm$ 2	12 $\pm$ 2	14 $\pm$ 2	14 $\pm$ 2	15 $\pm$ 2	13 $\pm$ 2
07/05-07/12	19 $\pm$ 2	15 $\pm$ 2	15 $\pm$ 2	16 $\pm$ 2	15 $\pm$ 2	17 $\pm$ 2	16 $\pm$ 2	15 $\pm$ 2	16 $\pm$ 2	18 $\pm$ 2	18 $\pm$ 2	17 $\pm$ 2	17 $\pm$ 3
07/12-07/19	29 $\pm$ 2	28 $\pm$ 2	27 $\pm$ 2	25 $\pm$ 2	27 $\pm$ 2	26 $\pm$ 2	29 $\pm$ 2	27 $\pm$ 2	26 $\pm$ 2	30 $\pm$ 2	28 $\pm$ 2	27 $\pm$ 2	27 $\pm$ 3
07/19-07/27	21 $\pm$ 2	21 $\pm$ 2	22 $\pm$ 2	20 $\pm$ 2	21 $\pm$ 2	20 $\pm$ 2	19 $\pm$ 2	18 $\pm$ 2	22 $\pm$ 2	20 $\pm$ 2	21 $\pm$ 2	21 $\pm$ 2	21 $\pm$ 2
07/27-08/02	22 $\pm$ 2	22 $\pm$ 2	18 $\pm$ 2	21 $\pm$ 2	20 $\pm$ 2	20 $\pm$ 2	18 $\pm$ 2	21 $\pm$ 2	17 $\pm$ 2	19 $\pm$ 2	22 $\pm$ 2	23 $\pm$ 2	20 $\pm$ 4
<b>AUGUST</b>													
08/02-08/09	15 $\pm$ 2	12 $\pm$ 2	10 $\pm$ 1	12 $\pm$ 2	12 $\pm$ 2	12 $\pm$ 2	11 $\pm$ 1	12 $\pm$ 2	13 $\pm$ 2	11 $\pm$ 1	13 $\pm$ 2	12 $\pm$ 2	12 $\pm$ 2
08/09-08/17	21 $\pm$ 2	18 $\pm$ 2	18 $\pm$ 2	18 $\pm$ 2	16 $\pm$ 2	23 $\pm$ 2	17 $\pm$ 2	15 $\pm$ 2	17 $\pm$ 2	21 $\pm$ 2	20 $\pm$ 2	21 $\pm$ 2	19 $\pm$ 5
08/17-08/23	27 $\pm$ 2	26 $\pm$ 2	22 $\pm$ 2	25 $\pm$ 2	24 $\pm$ 2	24 $\pm$ 2	25 $\pm$ 2	20 $\pm$ 2	20 $\pm$ 2	23 $\pm$ 2	23 $\pm$ 2	25 $\pm$ 2	24 $\pm$ 4
08/23-08/30	18 $\pm$ 2	20 $\pm$ 2	18 $\pm$ 2	20 $\pm$ 2	18 $\pm$ 2	18 $\pm$ 2	18 $\pm$ 2	16 $\pm$ 2	16 $\pm$ 2	20 $\pm$ 2	17 $\pm$ 2	19 $\pm$ 2	18 $\pm$ 3
<b>SEPTEMBER</b>													
08/30-09/06	30 $\pm$ 2	27 $\pm$ 2	26 $\pm$ 2	27 $\pm$ 2	27 $\pm$ 2	26 $\pm$ 2	22 $\pm$ 2	23 $\pm$ 2	24 $\pm$ 2	26 $\pm$ 2	26 $\pm$ 2	29 $\pm$ 2	26 $\pm$ 5
09/06-09/13	26 $\pm$ 2	27 $\pm$ 2	27 $\pm$ 2	25 $\pm$ 2	25 $\pm$ 2	26 $\pm$ 2	28 $\pm$ 2	24 $\pm$ 2	23 $\pm$ 2	27 $\pm$ 2	25 $\pm$ 2	30 $\pm$ 2	26 $\pm$ 4
09/13-09/20	21 $\pm$ 2	19 $\pm$ 2	17 $\pm$ 2	18 $\pm$ 2	17 $\pm$ 2	19 $\pm$ 2	17 $\pm$ 2	16 $\pm$ 2	15 $\pm$ 2	15 $\pm$ 2	16 $\pm$ 2	18 $\pm$ 2	17 $\pm$ 4
09/20-09/27	19 $\pm$ 2	18 $\pm$ 2	15 $\pm$ 2	15 $\pm$ 2	16 $\pm$ 2	16 $\pm$ 2	15 $\pm$ 2	13 $\pm$ 2	13 $\pm$ 2	14 $\pm$ 2	16 $\pm$ 2	17 $\pm$ 2	16 $\pm$ 4
09/27-10/04	31 $\pm$ 2	31 $\pm$ 2	28 $\pm$ 2	25 $\pm$ 2	30 $\pm$ 2	27 $\pm$ 2	24 $\pm$ 2	22 $\pm$ 2	24 $\pm$ 2	29 $\pm$ 2	29 $\pm$ 2	33 $\pm$ 2	28 $\pm$ 7
Quarter Avg. $\pm 2 \text{ s.d.}$	22 $\pm$ 11	21 $\pm$ 12	20 $\pm$ 12	20 $\pm$ 10	20 $\pm$ 11	20 $\pm$ 10	20 $\pm$ 11	18 $\pm$ 10	18 $\pm$ 9	21 $\pm$ 12	21 $\pm$ 10	22 $\pm$ 12	22 $\pm$ 11

TABLE B-2

(Page 4 of 4)

NORTH ANNA - 1995

## CONCENTRATIONS OF GROSS BETA IN AIR PARTICULATES

1.0E-03 pCi/m<sup>3</sup>  $\pm$  2 Sigma

COLLECTION DATE	01	02	03	04	05	05A	06	07	21	22	23	24	AVERAGE $\pm$ 2 s.d.
<b>OCTOBER</b>													
10/04-10/11	20 $\pm$ 2	17 $\pm$ 2	14 $\pm$ 2	17 $\pm$ 2	15 $\pm$ 2	15 $\pm$ 2	14 $\pm$ 2	15 $\pm$ 2	11 $\pm$ 1	16 $\pm$ 2	15 $\pm$ 2	19 $\pm$ 2	16 $\pm$ 5
10/11-10/18	27 $\pm$ 2	23 $\pm$ 2	22 $\pm$ 2	22 $\pm$ 2	21 $\pm$ 2	21 $\pm$ 2	21 $\pm$ 2	21 $\pm$ 2	22 $\pm$ 2	26 $\pm$ 2	24 $\pm$ 2	27 $\pm$ 2	23 $\pm$ 5
10/18-10/25	20 $\pm$ 2	20 $\pm$ 2	20 $\pm$ 2	21 $\pm$ 2	18 $\pm$ 2	18 $\pm$ 2	19 $\pm$ 2	19 $\pm$ 2	21 $\pm$ 2	22 $\pm$ 2	20 $\pm$ 2	22 $\pm$ 2	20 $\pm$ 3
10/25-11/01	18 $\pm$ 2	19 $\pm$ 2	16 $\pm$ 2	16 $\pm$ 2	16 $\pm$ 2	17 $\pm$ 2	14 $\pm$ 2	16 $\pm$ 2	14 $\pm$ 2	16 $\pm$ 2	16 $\pm$ 2	20 $\pm$ 2	17 $\pm$ 4
<b>NOVEMBER</b>													
11/01-11/09	20 $\pm$ 2	18 $\pm$ 2	17 $\pm$ 2	19 $\pm$ 2	17 $\pm$ 2	19 $\pm$ 2	18 $\pm$ 2	17 $\pm$ 2	17 $\pm$ 2	20 $\pm$ 2	20 $\pm$ 2	20 $\pm$ 2	19 $\pm$ 3
11/09-11/16	18 $\pm$ 2	17 $\pm$ 2	16 $\pm$ 2	15 $\pm$ 2	15 $\pm$ 2	15 $\pm$ 2	14 $\pm$ 2	16 $\pm$ 2	18 $\pm$ 2	15 $\pm$ 2	17 $\pm$ 2	17 $\pm$ 2	16 $\pm$ 3
11/16-11/22	25 $\pm$ 2	22 $\pm$ 2	22 $\pm$ 2	24 $\pm$ 2	18 $\pm$ 2	22 $\pm$ 2	22 $\pm$ 2	19 $\pm$ 2	23 $\pm$ 2	22 $\pm$ 2	22 $\pm$ 2	23 $\pm$ 2	22 $\pm$ 4
11/22-11/29	28 $\pm$ 2	27 $\pm$ 2	25 $\pm$ 2	25 $\pm$ 2	26 $\pm$ 2	25 $\pm$ 2	27 $\pm$ 2	22 $\pm$ 2	25 $\pm$ 2	27 $\pm$ 2	26 $\pm$ 2	27 $\pm$ 2	26 $\pm$ 3
<b>DECEMBER</b>													
11/29-12/06	22 $\pm$ 2	20 $\pm$ 2	23 $\pm$ 2	24 $\pm$ 2	20 $\pm$ 2	21 $\pm$ 2	24 $\pm$ 2	21 $\pm$ 2	22 $\pm$ 2	21 $\pm$ 2	27 $\pm$ 2	27 $\pm$ 2	23 $\pm$ 5
12/06-12/13	24 $\pm$ 2	25 $\pm$ 2	24 $\pm$ 2	27 $\pm$ 2	22 $\pm$ 2	25 $\pm$ 2	25 $\pm$ 2	21 $\pm$ 2	24 $\pm$ 2	23 $\pm$ 2	26 $\pm$ 2	25 $\pm$ 2	24 $\pm$ 3
12/13-12/20	29 $\pm$ 2	28 $\pm$ 2	28 $\pm$ 2	28 $\pm$ 2	28 $\pm$ 2	29 $\pm$ 2	27 $\pm$ 2	25 $\pm$ 2	22 $\pm$ 2	29 $\pm$ 2	30 $\pm$ 2	29 $\pm$ 2	28 $\pm$ 4
12/20-12/27	17 $\pm$ 2	13 $\pm$ 2	12 $\pm$ 2	14 $\pm$ 2	13 $\pm$ 2	15 $\pm$ 2	13 $\pm$ 2	12 $\pm$ 2	14 $\pm$ 2	14 $\pm$ 2	15 $\pm$ 2	15 $\pm$ 2	14 $\pm$ 3
12/27-01/03	17 $\pm$ 2	16 $\pm$ 2	17 $\pm$ 2	19 $\pm$ 2	18 $\pm$ 2	17 $\pm$ 2	17 $\pm$ 2	16 $\pm$ 2	19 $\pm$ 2	19 $\pm$ 2	17 $\pm$ 2	18 $\pm$ 2	18 $\pm$ 2
Quarter Avg. $\pm$ 2 s.d.	22 $\pm$ 9	20 $\pm$ 9	20 $\pm$ 10	21 $\pm$ 9	19 $\pm$ 9	20 $\pm$ 9	20 $\pm$ 10	19 $\pm$ 7	19 $\pm$ 9	21 $\pm$ 9	21 $\pm$ 10	22 $\pm$ 9	20 $\pm$ 9
Annual Avg. $\pm$ 2 s.d.	20 $\pm$ 10	19 $\pm$ 10	19 $\pm$ 10	20 $\pm$ 9	18 $\pm$ 10	19 $\pm$ 10	18 $\pm$ 10	17 $\pm$ 9	18 $\pm$ 9	19 $\pm$ 10	19 $\pm$ 10	20 $\pm$ 11	19 $\pm$ 10



**TABLE B-3: GAMMA EMITTER\* AND STRONTIUM CONCENTRATIONS IN AIR PARTICULATES**

North Anna Power Station, Louisa County, Virginia - 1995

1.0 E-03 pCi/m<sup>3</sup> ± 2 Sigma

Page 1 of 3

Station	Nuclide	First Quarter 12/298-03/29	Second Quarter 03/29-06/28	Third Quarter 06/28-09/27	Fourth Quarter 09/27-01/03	Average ± 2 s.d.
STA-01	Sr-89	(a)	< 0.6	(a)	(a)	-
	Sr-90	(a)	< 0.1	(a)	(a)	-
	Be-7	76.1 ± 7.6	81.6 ± 8.2	81.5 ± 8.1	55.6 ± 5.6	73.7 ± 24.7
	K-40	< 5	4.56 ± 1.86	< 5	11.7 ± 2.3	8.13 ± 10.1
	Co-60	< 0.3	< 0.3	< 0.2	< 0.2	-
	Ru-103	< 0.3	< 0.3	< 0.3	< 0.2	-
	Cs-134	< 0.3	< 0.2	< 0.2	< 0.2	-
	Cs-137	< 0.3	< 0.3	< 0.2	< 0.2	-
	Th-228	< 0.5	< 0.4	< 0.4	< 0.3	-
STA-02	Sr-89	(a)	< 0.8	(a)	(a)	-
	Sr-90	(a)	< 0.1	(a)	(a)	-
	Be-7	81.2 ± 8.1	74.0 ± 7.4	83.0 ± 8.3	59.9 ± 6.0	74.5 ± 21.0
	K-40	< 5	8.01 ± 2.30	< 6	< 5	8.01 ± 23.0
	Co-60	< 0.3	< 0.3	< 0.2	< 0.2	-
	Ru-103	< 0.3	< 0.3	< 0.3	< 0.3	-
	Cs-134	< 0.2	< 0.3	< 0.3	< 0.2	-
	Cs-137	< 0.3	< 0.2	< 0.3	< 0.2	-
	Th-228	< 0.5	< 0.3	< 0.6	< 0.4	-
STA-03	Sr-89	(a)	< 0.7	(a)	(a)	-
	Sr-90	(a)	< 0.2	(a)	(a)	-
	Be-7	70.5 ± 7.0	70.2 ± 7.0	65.7 ± 6.6	57.7 ± 5.8	66.0 ± 11.9
	K-40	< 7	< 10	< 9	< 5	-
	Co-60	< 0.3	< 0.3	< 0.3	< 0.2	-
	Ru-103	< 0.3	< 0.3	< 0.3	< 0.2	-
	Cs-134	< 0.2	< 0.3	< 0.3	< 0.2	-
	Cs-137	< 0.3	< 0.3	< 0.3	< 0.2	-
	Th-228	< 0.3	< 0.4	< 0.4	< 0.4	-
STA-04	Sr-89	(a)	< 1	(a)	(a)	-
	Sr-90	(a)	< 0.2	(a)	(a)	-
	Be-7	73.4 ± 7.3	83.0 ± 8.3	75.1 ± 7.5	58.1 ± 5.8	72.4 ± 20.8
	K-40	< 10	< 4	< 4	< 6	-
	Co-60	< 0.3	< 0.2	< 0.2	< 0.3	-
	Ru-103	< 0.3	< 0.3	< 0.3	< 0.3	-
	Cs-134	< 0.3	< 0.2	< 0.2	< 0.3	-
	Cs-137	< 0.3	< 0.2	< 0.3	< 0.3	-
	Th-228	< 0.4	< 0.4	< 0.4	< 0.6	-

\* All gamma emitters other than those listed were <LLD.  
(a) Strontium-89/90 analyses performed only on second quarter samples.

**TABLE B-3: GAMMA EMITTER\* AND STRONTIUM CONCENTRATIONS IN AIR PARTICULATES**

North Anna Power Station, Louisa County, Virginia - 1995

1.0 E-03 pCi/m<sup>3</sup> ± 2 Sigma

Page 2 of 3

Station	Nuclide	First Quarter 12/28-03/29	Second Quarter 03/29-06/28	Third Quarter 06/28-09/27	Fourth Quarter 09/27-01/03	Average ± 2 s.d.
STA-05	Sr-89	(a)	< 0.7	(a)	(a)	-
	Sr-90	(a)	< 0.2	(a)	(a)	-
	Be-7	75.5 ± 7.5	64.9 ± 6.5	66.5 ± 6.6	50.8 ± 5.1	64.4 ± 20.4
	K-40	< 4	< 6	< 4	< 7	-
	Co-60	< 0.3	< 0.2	< 0.2	< 0.2	-
	Ru-103	< 0.3	< 0.2	< 0.3	< 0.3	-
	Cs-134	< 0.2	< 0.2	< 0.2	< 0.3	-
	Cs-137	< 0.3	< 0.2	< 0.3	< 0.3	-
	Th-228	< 0.4	< 0.3	< 0.3	< 0.4	-
STA-05A	Sr-89	(a)	< 0.9	(a)	(a)	-
	Sr-90	(a)	< 0.2	(a)	(a)	-
	Be-7	70.0 ± 7.0	87.9 ± 8.8	79.8 ± 8.0	50.3 ± 5.0	72.0 ± 32.4
	K-40	19.3 ± 2.9	< 5	< 10	3.12 ± 1.75	11.2 ± 22.9
	Co-60	< 0.3	< 0.3	< 0.4	< 0.2	-
	Ru-103	< 0.3	< 0.3	< 0.4	< 0.3	-
	Cs-134	< 0.2	< 0.3	< 0.4	< 0.2	-
	Cs-137	< 0.3	< 0.2	< 0.3	< 0.3	-
	Th-228	< 0.4	< 0.5	< 0.5	< 0.4	-
STA-06	Sr-89	(a)	< 0.5	(a)	(a)	-
	Sr-90	(a)	< 0.09	(a)	(a)	-
	Be-7	83.4 ± 8.3	72.7 ± 7.3	77.4 ± 7.7	50.4 ± 5.0	71.0 ± 28.8
	K-40	< 5	< 4	< 5	2.68 ± 1.38	2.68 ± 1.38
	Co-60	< 0.3	< 0.2	< 0.3	< 0.2	-
	Ru-103	< 0.3	< 0.3	< 0.3	< 0.2	-
	Cs-134	< 0.3	< 0.2	< 0.2	< 0.2	-
	Cs-137	< 0.3	< 0.2	< 0.3	< 0.3	-
	Th-228	< 0.5	< 0.4	< 0.4	< 0.3	-
STA-07	Sr-89	(a)	< 0.9	(a)	(a)	-
	Sr-90	(a)	< 0.2	(a)	(a)	-
	Be-7	77.7 ± 7.8	76.1 ± 7.6	63.8 ± 6.4	47.9 ± 4.8	66.4 ± 27.6
	K-40	3.20 ± 1.84	< 6	29.9 ± 3.7	< 9	16.6 ± 37.8
	Co-60	< 0.3	< 0.3	< 0.3	< 0.3	-
	Ru-103	< 0.3	< 0.3	< 0.3	< 0.4	-
	Cs-134	< 0.2	< 0.3	< 0.3	< 0.3	-
	Cs-137	< 0.2	< 0.3	< 0.3	< 0.3	-
	Th-228	< 0.4	< 0.6	< 0.4	< 0.5	-

\* All gamma emitters other than those listed were <LLD.  
(a) Strontium-89/90 analyses performed only on second quarter samples.

**TABLE B-3: GAMMA EMITTER\* AND STRONTIUM CONCENTRATIONS IN AIR PARTICULATES**

North Anna Power Station, Louisa County, Virginia - 1995

1.0 E-03 pCi/m<sup>3</sup> ± 2 Sigma

Page 3 of 3

Station	Nuclide	First Quarter 12/28-03/29	Second Quarter 03/29-06/28	Third Quarter 06/28-09/27	Fourth Quarter 09/27-01/03	Average ± 2 s.d.
STA-21	Sr-89	(a)	< 0.7	(a)	(a)	-
	Sr-90	(a)	< 0.1	(a)	(a)	-
	Be-7	85.6 ± 8.6	68.7 ± 6.9	79.0 ± 7.9	58.0 ± 5.8	72.8 ± 24.2
	K-40	< 6	< 9	< 4	< 4	-
	Co-60	< 0.3	< 0.3	< 0.3	< 0.3	-
	Ru-103	< 0.4	< 0.3	< 0.3	< 0.3	-
	Cs-134	< 0.3	< 0.3	< 0.2	< 0.2	-
	Cs-137	< 0.4	< 0.3	< 0.3	< 0.2	-
	Th-228	< 0.7	< 0.4	< 0.5	< 0.4	-
STA-22	Sr-89	(a)	< 1	(a)	(a)	-
	Sr-90	(a)	< 0.2	(a)	(a)	-
	Be-7	70.0 ± 7.0	73.2 ± 7.3	65.7 ± 6.6	50.6 ± 5.1	64.9 ± 20.0
	K-40	< 8	< 5	< 5	25.3 ± 3.2	25.3 ± 3.2
	Co-60	< 0.3	< 0.3	< 0.3	< 0.3	-
	Ru-103	< 0.3	< 0.3	< 0.3	< 0.3	-
	Cs-134	< 0.3	< 0.2	< 0.2	< 0.3	-
	Cs-137	< 0.3	< 0.3	< 0.2	< 0.3	-
	Th-228	< 0.4	< 0.4	< 0.4	< 0.3	-
STA-23	Sr-89	(a)	< 1	(a)	(a)	-
	Sr-90	(a)	< 0.2	(a)	(a)	-
	Be-7	72.9 ± 7.3	73.1 ± 7.3	71.1 ± 7.1	73.3 ± 7.3	72.6 ± 2.0
	K-40	< 4	3.29 ± 1.50	< 4	< 5	3.29 ± 1.50
	Co-60	< 0.2	< 0.2	< 0.2	< 0.3	-
	Ru-103	< 0.2	< 0.2	< 0.3	< 0.3	-
	Cs-134	< 0.2	< 0.2	< 0.2	< 0.2	-
	Cs-137	< 0.3	< 0.3	< 0.2	< 0.2	-
	Th-228	< 0.4	< 0.3	< 0.3	< 0.4	4
STA-24	Sr-89	(a)	< 1	(a)	(a)	-
	Sr-90	(a)	< 0.2	(a)	(a)	-
	Be-7	78.8 ± 7.9	77.2 ± 7.7	76.3 ± 7.6	49.5 ± 4.9	70.5 ± 28.0
	K-40	4.18 ± 1.75	5.58 ± 2.47	< 4	< 4	4.88 ± 1.98
	Co-60	< 0.2	< 0.4	< 0.2	< 0.3	-
	Ru-103	< 0.2	< 0.4	< 0.2	< 0.3	-
	Cs-134	< 0.2	< 0.4	< 0.2	< 0.2	-
	Cs-137	< 0.2	< 0.3	< 0.2	< 0.2	-
	Th-228	< 0.3	< 0.5	< 0.3	< 0.4	-

\* All gamma emitters other than those listed were <LLD.  
(a) Strontium-89/90 analyses performed only on second quarter samples.

**TABLE B-4: GROSS BETA, TRITIUM AND GAMMA EMITTER\*  
CONCENTRATIONS IN PRECIPITATION**

**Station 01A -- (On Site)**

North Anna Power Station, Louisa County, Virginia - 1995

pCi/l  $\pm$  2 Sigma

Page 1 of 1

Collection Dates	Gross Beta	Rainfall (inches)
12/28/94-01/25/95	13 $\pm$ 1	6.52
01/25/95-03/01/95	3.1 $\pm$ 0.7	1.61
03/01/95-03/30/95	1.6 $\pm$ 0.6	2.37
03/30/95-04/26/95	3.2 $\pm$ 0.7	1.73
04/26/95-05/31/95	2.3 $\pm$ 0.6	2.96
05/31/95-06/28/95	3.4 $\pm$ 0.7	3.78
06/28/95-07/27/95	3.8 $\pm$ 0.8	3.07
07/27/95-08/30/95	13 $\pm$ 2	0.76
08/30/95-09/27/95	1.8 $\pm$ 0.6	2.58
09/27/95-10/25/95	0.86 $\pm$ 0.49	6.62
10/25/95-11/29/95	3.0 $\pm$ 0.7	4.80
11/29/95-12/27/95	3.0 $\pm$ 0.7	2.15
<b>Average <math>\pm</math> 2 s.d.</b>	<b>4.3 <math>\pm</math> 8.3</b>	

**SEMI-ANNUAL PRECIPITATION COMPOSITES**

12/28/94-06/28/95	06/28/95-12/28/95
Be-7 = < 40	Be-7 = 61.5 $\pm$ 30.1
H-3 = < 200	H-3 = < 200

\* All gamma emitters other than those listed were <LLD.

TABLE B-5

NORTH ANNA - 1995

CONCENTRATIONS OF GAMMA EMITTERS\* IN SOIL

pCi/kg  $\pm$  2 Sigma

STATION	COLL DATES	Sr-89	Sr-90	Be-7	K-40	Cs-134	Cs-137	Ra-226	Th-228
01	07/05/95	< 200	< 80	< 600	18700 $\pm$ 1900	< 50	< 50	2240 $\pm$ 790	1300 $\pm$ 130
02	07/05/95	< 100	< 30	< 300	6450 $\pm$ 650	< 20	128 $\pm$ 25	< 400	335 $\pm$ 34
03	07/05/95	< 200	< 70	< 500	10100 $\pm$ 1000	< 50	104 $\pm$ 34	< 800	752 $\pm$ 75
04	07/05/95	< 100	< 40	< 700	4300 $\pm$ 590	< 50	592 $\pm$ 61	1410 $\pm$ 670	816 $\pm$ 82
05	07/05/95	< 200	170 $\pm$ 50	< 500	13200 $\pm$ 1300	< 40	707 $\pm$ 71	2370 $\pm$ 570	1560 $\pm$ 160
05A	07/05/95	< 300	< 100	1090 $\pm$ 370	13000 $\pm$ 1300	< 40	58.5 $\pm$ 28.4	1590 $\pm$ 600	1110 $\pm$ 110
06	07/05/95	< 200	68 $\pm$ 33	< 700	11000 $\pm$ 1100	< 60	231 $\pm$ 35	2900 $\pm$ 660	2020 $\pm$ 200
07	07/05/95	< 200	< 60	< 500	5580 $\pm$ 590	< 50	< 50	2830 $\pm$ 730	1810 $\pm$ 180
21	07/05/95	< 100	87 $\pm$ 31	< 400	11300 $\pm$ 1100	< 30	767 $\pm$ 77	798 $\pm$ 449	614 $\pm$ 61
22	07/05/95	< 200	72 $\pm$ 43	< 600	18500 $\pm$ 1800	< 60	234 $\pm$ 45	2260 $\pm$ 730	1180 $\pm$ 120
23	07/05/95	< 200	130 $\pm$ 50	< 700	23100 $\pm$ 2300	< 60	255 $\pm$ 41	2280 $\pm$ 790	1580 $\pm$ 160
24	07/05/95	< 100	< 50	< 500	3820 $\pm$ 470	< 40	< 40	2150 $\pm$ 610	1720 $\pm$ 170
Average $\pm$ 2 s.d.			105 $\pm$ 87	1090 $\pm$ 370	11588 $\pm$ 12269		342 $\pm$ 543	2083 $\pm$ 1292	1233 $\pm$ 1050

\* All other gamma emitters were &lt; LLD.

**TABLE B-6: GAMMA EMITTER\*, STRONTIUM AND TRITIUM CONCENTRATIONS  
IN GROUND AND WELL WATER**

North Anna Power Station, Louisa County, Virginia - 1995

pCi/l  $\pm$  2 Sigma

Page 1 of 1

Collection Dates	Sr-89	Sr-90	H-3	Be-7	K-40	I-131	Ba-140	Th-228
---------------------	-------	-------	-----	------	------	-------	--------	--------

**STATION 01A**

03/29/95	(a)	(a)	< 200	< 30	< 50	< 0.2	< 5	< 7
06/30/95	< 0.9	< 0.2	< 200	< 30	< 70	< 0.5	< 9	< 6
09/28/95	(a)	(a)	< 200	< 30	< 50	< 0.2	< 5	< 8
12/21/95	(a)	(a)	< 100	< 40	< 100	< 0.3	< 9	< 6

\* All gamma emitters other than those listed were <LLD.

(a) Strontium-89/90 analyses performed only on second quarter sample.

**TABLE B-7: GAMMA EMITTER\*, STRONTIUM AND TRITIUM CONCENTRATIONS  
IN RIVER WATER**

North Anna Power Station, Louisa County, Virginia - 1995

pCi/l  $\pm$  2 Sigma

Page 1 of 1

Collection Dates	Sr-89	Sr-90	H-3	Be-7	K-40	I-131	Cs-137	Ba-140	Ra-226	Th-228
---------------------	-------	-------	-----	------	------	-------	--------	--------	--------	--------

**STATION - 11**

01/18/95	(a)	(a)	3300 $\pm$ 200	< 40	< 100	< 0.3	< 5	< 5	< 90	< 8
02/13/95	(a)	(a)	(b)	< 40	< 100	< 0.2	< 4	< 6	< 70	< 6
03/23/95	(a)	(a)	(b)	< 30	< 100	< 0.2	< 4	< 5	< 70	< 7
04/18/95	< 4	< 0.7	3600 $\pm$ 200	< 40	< 70	< 0.2	< 4	< 7	< 100	< 9
05/23/95	(a)	(a)	(b)	< 30	< 60	< 0.2	< 4	< 6	< 90	< 7
06/20/95	(a)	(a)	(b)	< 40	< 100	< 0.2	< 4	< 8	< 70	< 7
07/17/95	(a)	(a)	2100 $\pm$ 200	< 40	< 100	< 0.2	< 4	< 7	< 70	< 7
08/23/95	(a)	(a)	(b)	< 30	< 50	< 0.2	< 4	< 5	< 60	< 5
09/20/95	(a)	(a)	(b)	< 30	< 50	< 0.3	< 4	< 7	< 70	< 6
10/16/95	(a)	(a)	2300 $\pm$ 200	< 40	< 100	< 0.4	< 4	< 7	< 80	< 7
11/22/95	(a)	(a)	(b)	< 30	< 100	< 0.2	< 4	< 5	< 70	< 6
12/20/95	(a)	(a)	(b)	< 40	< 100	< 0.4	< 4	< 7	< 70	< 7

Average  $\pm$  2 s.d.

2825  $\pm$  1473

\* All gamma emitters other than those listed were <LLD.

(a) Sr-89/90 analyses performed only on second quarter samples.

(b) Tritium analysis performed on quarterly composite.

**TABLE B-8: GAMMA EMITTER\*, STRONTIUM AND TRITIUM CONCENTRATIONS IN SURFACE WATER**

North Anna Power Station, Louisa County, Virginia - 1995

pCi/l  $\pm$  2 Sigma

Page 1 of 1

Collection Dates	Sr-89	Sr-90	H-3	Be-7	K-40	I-131**	Cs-137	Ba-140	Ra-226	Th-228
---------------------	-------	-------	-----	------	------	---------	--------	--------	--------	--------

**STATION - 08**

01/18	(a)	(a)	3300 $\pm$ 200	< 30	< 60	< 0.2	< 4	< 5	< 70	< 6
02/13	(a)	(a)	(b)	< 30	< 50	< 0.2	< 3	< 6	< 60	< 6
03/23	(a)	(a)	(b)	< 30	< 60	< 0.2	< 4	< 5	< 90	< 7
04/18	< 4	< 0.7	3300 $\pm$ 200	< 30	< 90	< 0.2	< 4	< 5	< 70	< 7
05/23	(a)	(a)	(b)	< 30	< 50	< 0.2	< 4	< 5	< 80	< 7
06/20	(a)	(a)	(b)	< 30	< 50	< 0.2	< 4	< 7	< 80	< 7
07/17	(a)	(a)	2100 $\pm$ 200	< 30	< 60	< 0.2	< 3	< 7	< 90	< 7
08/23	(a)	(a)	(b)	< 30	< 100	< 0.2	< 4	< 6	< 70	< 7
09/20	(a)	(a)	(b)	< 30	< 70	< 0.3	< 4	< 8	< 100	< 8
10/16	(a)	(a)	2400 $\pm$ 200	< 30	< 60	< 0.4	< 3	< 8	< 70	< 6
11/22	(a)	(a)	(b)	< 30	< 70	< 0.2	< 4	< 6	< 90	< 8
12/20	(a)	(a)	(b)	< 30	< 60	< 0.3	< 4	< 7	< 90	< 7

Avg. 2775  $\pm$  1237  
 $\pm$  2. s.d.

**STATION - 09A**

01/18	(a)	(a)	< 200	< 40	< 100	< 0.2	< 4	< 5	< 80	< 6
02/13	(a)	(a)	(b)	< 30	< 50	< 0.2	< 3	< 5	< 60	< 6
03/23	(a)	(a)	(b)	< 40	< 70	< 0.2	< 4	< 6	< 100	< 9
04/18	< 3	< 0.6	< 200	< 30	< 60	< 0.1	< 4	< 6	< 90	< 7
05/23	(a)	(a)	(b)	< 40	< 100	< 0.2	< 4	< 6	< 70	< 7
06/20	(a)	(a)	(b)	< 40	< 60	< 0.2	< 4	< 8	< 100	< 8
07/17	(a)	(a)	< 200	< 30	< 70	< 0.2	< 4	< 6	< 100	< 8
08/23	(a)	(a)	(b)	< 30	< 50	< 0.2	< 4	< 5	< 70	< 6
09/20	(a)	(a)	(b)	< 40	< 100	< 0.3	< 4	< 8	< 70	< 6
10/16	(a)	(a)	< 200	< 40	< 70	< 0.4	< 4	< 6	< 100	< 10
11/22	(a)	(a)	(b)	< 30	< 90	< 0.2	< 4	< 5	< 70	< 6
12/20	(a)	(a)	(b)	< 30	< 70	< 0.3	< 4	< 7	< 70	< 6

\* All gamma emitters other than those listed were <LLD.

\*\* I-131 by radiochemistry

(a) Analysis performed only with second quarter.

(b) Analysis performed quarterly.



**TABLE B-9: GAMMA EMITTER\* AND TRITIUM CONCENTRATIONS  
IN SURFACE WATER**

**State-Split Samples**

North Anna Power Station, Louisa County, Virginia - 1995

pCi/l  $\pm$  2 Sigma

Page 1 of 1

Collection Dates	H-3	Be-7	K-40	I-131	Cs-137	Ba-140	Ra-226	Th-228
---------------------	-----	------	------	-------	--------	--------	--------	--------

**STATION - W-27**

01/31	300 $\pm$ 110	< 30	< 50	< 0.3	< 4	< 6	< 60	< 5
02/28	(a)	< 30	< 50	< 0.6	< 4	< 10	< 70	< 6
03/31	(a)	< 30	< 40	< 0.8	< 3	< 10	< 60	< 5
04/30	< 300	< 40	< 90	< 0.7	< 4	< 10	< 90	< 8
05/31	(a)	< 40	< 50	< 0.7	< 4	< 20	< 70	< 6
06/30	(a)	< 50	< 50	< 0.5	< 3	< 30	< 60	< 5
07/31	1300 $\pm$ 200	< 30	< 60	< 0.4	< 3	< 6	< 70	< 6
08/30	(a)	< 30	< 50	< 0.6	< 3	< 9	< 60	< 6
09/30	(a)	< 30	< 50	< 0.5	< 4	< 9	< 70	< 6
10/31	1500 $\pm$ 200	< 30	< 60	< 0.4	< 4	< 9	< 90	< 10
11/30	(a)	< 30	< 30	< 2 (b)	< 3	< 10	< 50	< 4
12/31	(a)	< 40	< 60	< 1	< 3	< 10	< 70	< 7

Avg. 1033  $\pm$  1286  
 $\pm$  2 s.d.

**STATION - W-33**

01/31	4200 $\pm$ 200	< 50	< 100	< 0.3	< 5	< 9	< 90	< 8
02/28	(a)	< 30	< 50	< 0.7	< 4	< 10	< 60	< 5
03/31	(a)	< 30	< 50	< 0.9	< 3	< 10	< 70	< 5
04/30	3600 $\pm$ 300	< 50	< 80	< 0.8	< 5	< 10	< 100	< 9
05/31	(a)	< 40	< 40	< 1	< 4	< 20	< 60	< 6
06/30	(a)	< 40	< 40	< 0.6	< 3	< 10	< 70	< 7
07/31	2300 $\pm$ 200	< 30	< 70	< 0.3	< 3	< 5	< 60	< 6
08/30	(a)	< 40	< 60	< 0.7	< 3	< 10	< 70	< 6
09/30	(a)	< 30	< 70	< 0.5	< 3	< 8	< 60	< 6
10/31	2200 $\pm$ 200	< 40	< 70	< 0.3	< 4	< 8	< 100	< 8
11/30	(a)	< 20	< 30	< 2 (b)	< 3	< 10	< 40	< 3
12/31	(a)	< 30	< 70	< 0.9	< 3	< 10	< 60	< 5

Avg. 3075  $\pm$  1969  
 $\pm$  2 s.d.

\* All gamma emitters other than those listed were <LLD.

(a) Tritium analysis performed on the first monthly composite of each quarter.

(b) LLD was not met due to the late arrival (29 days) from time of collection to receipt at laboratory.

**TABLE B-10: GAMMA EMITTER\* AND STRONTIUM CONCENTRATIONS IN  
SEDIMENT SILT**

North Anna Power Station, Louisa County, Virginia - 1995

pCi/kg  $\pm$  2 Sigma

Page 1 of 1

Nuclide	STA-08 03/10	STA-09A 03/10	STA-11 03/10	STA-08 08/23	STA-09A 08/23	STA-11 08/23	Average $\pm$ 2 Sigma
Sr-89	(a)	(a)	(a)	< 500	< 400	< 500	-
Sr-90	(a)	(a)	(a)	< 40	< 30	< 30	-
Be-7	< 300	< 400	< 300	< 300	< 200	< 400	-
K-40	2160 $\pm$ 350	12000 $\pm$ 1200	18900 $\pm$ 1900	5360 $\pm$ 540	19000 $\pm$ 1900	23700 $\pm$ 2400	13520 $\pm$ 16984
Mn-54	< 30	< 40	< 30	< 30	< 20	< 40	-
Co-58	< 30	< 40	< 30	< 30	< 20	< 40	-
Co-60	< 40	< 30	< 30	< 30	< 20	< 40	-
Cs-134	< 30	< 40	< 40	< 40	< 20	< 40	-
Cs-137	66.2 $\pm$ 23.8	< 40	< 40	< 40	< 30	229 $\pm$ 42	148 $\pm$ 230
Ra-226	< 800	800 $\pm$ 467	1560 $\pm$ 500	795 $\pm$ 431	819 $\pm$ 303	1590 $\pm$ 600	1113 $\pm$ 844
Th-228	348 $\pm$ 41	515 $\pm$ 52	1080 $\pm$ 110	725 $\pm$ 72	354 $\pm$ 35	943 $\pm$ 94	661 $\pm$ 615

<sup>1</sup> All gamma emitters other than those listed were <LLD.

(a) Strontium 89/90 analyses performed annually.

**TABLE B-11: GAMMA EMITTER\* AND STRONTIUM CONCENTRATIONS IN  
SHORELINE SOIL**

North Anna Power Station, Louisa County, Virginia - 1995

pCi/kg  $\pm$  2 Sigma

Page 1 of 1

Nuclide	Station-09 02/13	Station-09 08/17	Average $\pm$ 2 Sigma
Sr-89	(a)	< 400	-
Sr-90	(a)	< 80	-
Be-7	< 500	466 $\pm$ 224	466 $\pm$ 224
K-40	6180 $\pm$ 650	2200 $\pm$ 350	4190 $\pm$ 5629
Mn-54	< 50	< 30	-
Co-58	< 50	< 30	-
Co-60	< 50	< 30	-
Cs-134	< 60	< 40	-
Cs-137	493 $\pm$ 57	189 $\pm$ 27	341 $\pm$ 430
Ra-226	2540 $\pm$ 780	1330 $\pm$ 420	1935 $\pm$ 1711
Th-228	1650 $\pm$ 170	461 $\pm$ 46	1056 $\pm$ 1682

\* All gamma emitters other than those listed were <LLD.

(a) Strontium 89/90 analyses performed annually.

**TABLE B-12: GAMMA EMITTER\* AND STRONTIUM CONCENTRATIONS IN MILK**

North Anna Power Station, Louisa County, Virginia - 1995

pCi/l  $\pm$  2 Sigma

Page 1 of 2

MONTH	NUCLIDE	STATION-12	STATION-13
JANUARY	Sr-89	< 2	< 2
	Sr-90	1.4 $\pm$ 0.3	1.9 $\pm$ 0.3
	K-40	1640 $\pm$ 160	1390 $\pm$ 140
	Cs-137	< 5	< 4
	I-131	< 0.5	< 0.5
FEBRUARY	Sr-89	(a)	(a)
	Sr-90	(a)	(a)
	K-40	1500 $\pm$ 150	1330 $\pm$ 130
	Cs-137	< 4	< 4
	I-131	< 0.3	< 0.3
MARCH	Sr-89	(a)	(a)
	Sr-90	(a)	(a)
	K-40	1510 $\pm$ 150	1330 $\pm$ 130
	Cs-137	< 4	< 5
	I-131	< 0.2	< 0.3
APRIL	Sr-89	< 2	< 2
	Sr-90	0.96 $\pm$ 0.24	1.2 $\pm$ 0.2
	K-40	1410 $\pm$ 140	1330 $\pm$ 130
	Cs-137	< 5	< 4
	I-131	< 0.2	< 0.2
MAY	Sr-89	(a)	(a)
	Sr-90	(a)	(a)
	K-40	1420 $\pm$ 140	1340 $\pm$ 130
	Cs-137	< 5	< 4
	I-131	< 0.3	< 0.2
JUNE	Sr-89	(a)	(a)
	Sr-90	(a)	(a)
	K-40	1490 $\pm$ 150	1290 $\pm$ 130
	Cs-137	< 4	< 4
	I-131	< 0.2	< 0.2

\* All gamma emitters other than those listed were <LLD.

(a) Strontium 89/90 analyses performed on the last monthly sample of each quarter.

**TABLE B-12: GAMMA EMITTER\* AND STRONTIUM CONCENTRATIONS IN MILK**

North Anna Power Station, Louisa County, Virginia - 1995

$\mu\text{Ci/l} \pm 2 \text{ Sigma}$

Page 2 of 2

MONTH	NUCLIDE	STATION-12	STATION-13
JULY	Sr-89	< 0.7	< 0.8
	Sr-90	$1.4 \pm 0.2$	$1.2 \pm 0.2$
	K-40	$1360 \pm 140$	$1320 \pm 130$
	Cs-137	< 4	< 5
	I-131	< 0.5	< 0.4
AUGUST	Sr-89	(a)	(a)
	Sr-90	(a)	(a)
	K-40	$1340 \pm 130$	$1170 \pm 120$
	Cs-137	< 4	< 4
	I-131	< 0.2	< 0.2
SEPTEMBER	Sr-89	(a)	(a)
	Sr-90	(a)	(a)
	K-40	$1360 \pm 140$	$1240 \pm 120$
	Cs-137	< 4	< 4
	I-131	< 0.2	< 0.3
OCTOBER	Sr-89	< 0.9	< 0.9
	Sr-90	$0.98 \pm 0.16$	$2.1 \pm 0.2$
	K-40	$1320 \pm 130$	$1320 \pm 130$
	Cs-137	< 4	< 3
	I-131	< 0.2	< 0.5
NOVEMBER	Sr-89	(a)	(a)
	Sr-90	(a)	(a)
	K-40	$1330 \pm 130$	$1340 \pm 130$
	Cs-137	< 4	< 4
	I-131	< 0.2	< 0.2
DECEMBER	Sr-89	(a)	(a)
	Sr-90	(a)	(a)
	K-40	$1390 \pm 140$	$1270 \pm 130$
	Cs-137	< 4	< 4
	I-131	< 0.3	< 0.3

\* All gamma emitters other than those listed were <LLD.

(a) Strontium 89/90 analyses performed on the last monthly sample of each quarter.

**TABLE B-13: GAMMA EMITTER\* CONCENTRATIONS IN FISH**

North Anna Power Station, Louisa County, Virginia - 1995

pCi/kg  $\pm$  2 Sigma

Page 1 of 1

Collection Date	Station	Sample Type	K-40	Co-58	Cs-134	Cs-137
02/13	08	Fish (a)	1620 $\pm$ 170	< 20	< 20	35.5 $\pm$ 14.5
03/13	25	Fish (a)	1250 $\pm$ 190	< 20	< 20	< 20
02/28	08	Catfish (b)	1370 $\pm$ 140	< 20	< 10	49.9 $\pm$ 13.2
03/01	25	Catfish (b)	1220 $\pm$ 130	< 20	< 20	< 20
08/09	08	Fish (a)	1200 $\pm$ 270	< 20	< 30	< 30
08/10	25	Fish (a)	2110 $\pm$ 250	< 20	< 20	< 20
08/09	08	Catfish (b)	1650 $\pm$ 190	< 20	< 20	26.2 $\pm$ 12.9
08/10	25	Catfish	1380 $\pm$ 190	< 20	< 20	< 20
Avg. $\pm$ 2 s.d.			1475 $\pm$ 617			37.2 $\pm$ 23.9

- \* All gamma emitters other than those listed were <LLD.  
(a) Non-bottom dwelling species of gamefish.  
(b) Bottom dwelling species of fish.

**TABLE B-14: GAMMA EMITTER\* CONCENTRATIONS IN FOOD/VEGETATION**

North Anna Power Station, Louisa County, Virginia - 1995

pCi/kg  $\pm$  2 Sigma

Page 1 of 2

Collection Date	Be-7	K-40	I-131	Ru-103	Cs-134	Cs-137	Ra-226	Th-228
-----------------	------	------	-------	--------	--------	--------	--------	--------

**STATION 14**

There were no food/vegetation samples for all stations during the first quarter, November and December 1995, due to seasonal unavailability.

04/19	1710 $\pm$ 170	19200 $\pm$ 1300	< 20	< 20	< 10	< 10	< 200	< 20
05/24	912 $\pm$ 404	9930 $\pm$ 990	< 40	< 70	< 60	< 60	< 900	< 90
06/21	1770 $\pm$ 430	14500 $\pm$ 1500	< 30	< 60	< 50	< 50	< 700	< 70
07/19	1870 $\pm$ 280	25000 $\pm$ 2500	< 10	< 40	< 40	< 40	< 600	112 $\pm$ 29
08/23	698 $\pm$ 120	7480 $\pm$ 750	< 10	< 20	< 10	< 10	< 300	< 30
09/20	2640 $\pm$ 350	6210 $\pm$ 620	< 50	< 50	< 40	< 40	< 700	< 70
10/18	2370 $\pm$ 350	4510 $\pm$ 450	< 10	< 50	< 40	< 40	< 700	< 60

**STATION 15**

04/19	1880 $\pm$ 190	18900 $\pm$ 1900	< 40	< 20	< 20	< 20	< 300	< 30
05/24	1130 $\pm$ 140	13500 $\pm$ 1400	< 40	< 20	< 20	< 20	< 400	95.3 $\pm$ 19.1
06/21	1090 $\pm$ 310	9730 $\pm$ 970	< 30	< 40	< 30	< 40	< 600	195 $\pm$ 48
07/19	1310 $\pm$ 180	11900 $\pm$ 1200	< 10	< 30	< 30	< 20	< 400	< 40
08/23	1170 $\pm$ 310	33400 $\pm$ 3300	< 9	< 50	< 40	< 40	< 600	< 60
09/20	1940 $\pm$ 290	19000 $\pm$ 1900	< 30	< 40	< 40	< 40	1250 $\pm$ 500	< 70
10/18	994 $\pm$ 99	16400 $\pm$ 1600	< 9	< 10	< 10	< 10	< 200	< 20

**STATION 16**

04/19	330 $\pm$ 44	7390 $\pm$ 740	< 10	< 7	< 7	< 6	< 100	< 10
05/24	318 $\pm$ 52	10600 $\pm$ 1100	< 50	< 9	< 9	< 9	< 200	< 10
06/21	1310 $\pm$ 200	10300 $\pm$ 1000	< 20	< 30	< 20	< 20	00	< 30
07/19	5730 $\pm$ 570	27600 $\pm$ 2800	< 10	< 50	< 50	< 50	800	157 $\pm$ 40
08/23	720 $\pm$ 289	16900 $\pm$ 1700	< 20	< 40	< 40	159 $\pm$ 35	< 700	121 $\pm$ 33
09/20	346 $\pm$ 79	12800 $\pm$ 1300	< 20	< 10	< 10	13.9 $\pm$ 7.6	< 200	41.3 $\pm$ 13.9
10/18	5160 $\pm$ 520	14200 $\pm$ 1400	< 10	< 30	< 30	< 30	< 400	< 40

\* All gamma emitters other than those listed were <LLD.

**TABLE B-14: GAMMA EMITTER\* CONCENTRATION IN FOOD/VEGETATION**

North Anna Power Station, Louisa County, Virginia - 1995

pCi/kg  $\pm$  2 Sigma

Page 2 of 2

Collection Date	Be-7	K-40	I-131	Ru-103	Cs-134	Cs-137	Ra-226	Th-228
-----------------	------	------	-------	--------	--------	--------	--------	--------

**STATION 21**

04/19	2170 $\pm$ 220	14400 $\pm$ 1400	< 7	< 20	< 20	51.2 $\pm$ 13.4	767 $\pm$ 255	260 $\pm$ 26
05/24	1060 $\pm$ 360	8070 $\pm$ 810	< 50	< 60	< 50	57.3 $\pm$ 32.8	< 700	< 70
06/21	1490 $\pm$ 210	13000 $\pm$ 1300	< 30	< 30	< 30	29.1 $\pm$ 14.2	440 $\pm$ 237	187 $\pm$ 22
07/19	2380 $\pm$ 240	20800 $\pm$ 2100	< 10	< 30	< 40	36.9 $\pm$ 20.1	763 $\pm$ 356	< 50
08/23	367 $\pm$ 138	25600 $\pm$ 2600	< 10	< 20	< 20	< 20	< 300	< 30
09/20	2020 $\pm$ 200	15000 $\pm$ 1500	< 30	< 20	< 20	< 20	< 400	< 40
10/18	639 $\pm$ 130	21400 $\pm$ 2100	< 9	< 20	< 20	< 20	< 300	< 30

**STATION 23**

04/19	1810 $\pm$ 180	17300 $\pm$ 1700	< 10	< 20	< 20	< 20	< 400	< 40
05/24	502 $\pm$ 206	6120 $\pm$ 610	< 40	< 40	< 40	< 40	< 600	168 $\pm$ 30
06/21	854 $\pm$ 155	8830 $\pm$ 880	< 30	< 30	< 20	< 20	< 300	< 30
07/19	1530 $\pm$ 390	18400 $\pm$ 1800	< 10	< 70	< 60	< 60	< 1000	< 100
08/23	< 400	20800 $\pm$ 2100	< 10	< 40	< 40	< 40	< 600	< 60
09/20	804 $\pm$ 97	18800 $\pm$ 1900	< 20	< 10	< 10	46.2 $\pm$ 11.6	< 200	< 20
10/18	1390 $\pm$ 350	6350 $\pm$ 640	< 10	< 60	< 50	< 50	< 900	< 80

<b>Average</b>	<b>1542 <math>\pm</math> 2362</b>	<b>14981 <math>\pm</math> 13556</b>				<b>56.2 <math>\pm</math> 95.2</b>	<b>805 <math>\pm</math> 668</b>	<b>149 <math>\pm</math> 128</b>
<b><math>\pm</math> 2 s.d.</b>								

\* All gamma emitters other than those listed were <LLD.



**TABLE B-15: DIRECT RADIATION MEASUREMENTS - QUARTERLY AND ANNUAL TLD RESULTS**

North Anna Power Station, Louisa County, Virginia - 1995

mR/Std. Month (30.4 days)  $\pm$  2 Sigma

Page 1 of 1

Station Number	First Qtr 01/05/95 03/29/95	Second Qtr 03/29/95 06/28/95	Third Qtr 06/28/95 09/27/95	Fourth Qtr 09/27/95 12/28/95	Quarterly Average	Annual TLD 06/29/94 06/28/95
01	7.8 $\pm$ 0.5	7.5 $\pm$ 0.1	7.4 $\pm$ 0.2	8.3 $\pm$ 0.2	7.8 $\pm$ 0.8	7.7 $\pm$ 0.3
02	4.5 $\pm$ 0.3	4.2 $\pm$ 0.1	4.0 $\pm$ 0.1	3.9 $\pm$ 2.5	4.2 $\pm$ 0.5	4.3 $\pm$ 0.0
03	4.3 $\pm$ 0.1	5.2 $\pm$ 0.5	3.9 $\pm$ 0.2	4.1 $\pm$ 0.2	4.4 $\pm$ 1.1	4.4 $\pm$ 0.1
04	4.5 $\pm$ 0.3	4.4 $\pm$ 0.1	4.3 $\pm$ 0.1	4.6 $\pm$ 0.2	4.5 $\pm$ 0.3	4.5 $\pm$ 0.1
05	6.6 $\pm$ 0.1	5.3 $\pm$ 0.3	5.0 $\pm$ 0.1	5.3 $\pm$ 0.9	5.6 $\pm$ 1.4	5.3 $\pm$ 0.2
05A	5.5 $\pm$ 0.2	5.2 $\pm$ 0.2	5.0 $\pm$ 0.1	5.2 $\pm$ 0.1	5.2 $\pm$ 0.4	5.3 $\pm$ 0.2
06	6.7 $\pm$ 0.1	6.6 $\pm$ 0.2	6.8 $\pm$ 0.3	6.8 $\pm$ 0.3	6.7 $\pm$ 0.2	6.5 $\pm$ 0.2
07	5.3 $\pm$ 0.5	5.1 $\pm$ 0.2	4.7 $\pm$ 0.1	5.2 $\pm$ 0.2	5.1 $\pm$ 0.5	5.1 $\pm$ 0.1
21	5.2 $\pm$ 0.2	6.0 $\pm$ 0.3	4.8 $\pm$ 0.1	5.4 $\pm$ 0.3	5.4 $\pm$ 1.0	5.1 $\pm$ 0.1
22	6.3 $\pm$ 0.3	6.6 $\pm$ 0.8	6.0 $\pm$ 0.2	6.2 $\pm$ 0.1	6.3 $\pm$ 0.5	6.0 $\pm$ 0.1
23	7.0 $\pm$ 0.3	6.4 $\pm$ 0.2	6.3 $\pm$ 0.2	7.0 $\pm$ 0.1	6.7 $\pm$ 0.8	7.1 $\pm$ 0.4
24	5.2 $\pm$ 0.2	5.3 $\pm$ 0.2	4.9 $\pm$ 0.1	5.3 $\pm$ 0.3	5.2 $\pm$ 0.4	5.2 $\pm$ 0.1
<b>Average <math>\pm</math> 2 s.d.</b>	<b>5.7 <math>\pm</math> 2.2</b>	<b>5.7 <math>\pm</math> 2.0</b>	<b>5.3 <math>\pm</math> 2.2</b>	<b>5.3 <math>\pm</math> 2.5</b>	<b>5.6 <math>\pm</math> 2.5</b>	<b>5.5 <math>\pm</math> 2.2</b>

**TABLE B-16: DIRECT RADIATION MEASUREMENTS -  
SECTOR QUARTERLY TLD RESULTS**

North Anna Power Station, Louisa County, Virginia - 1995

mR/Std. Month (30.4 days)  $\pm$  2 Sigma

Page 1 of 2

Station Number	First Qtr. 01/05-03/29	Second Qtr. 03/29-06/28	Third Qtr. 06/28-09/27	Fourth Qtr. 09/27-12/28	Average $\pm$ 2 s.d.
N-1	6.1 $\pm$ 0.3	6.0 $\pm$ 0.3	5.7 $\pm$ 0.2	6.5 $\pm$ 0.1	6.1 $\pm$ 0.7
N-2	5.6 $\pm$ 0.4	4.7 $\pm$ 0.1	4.8 $\pm$ 0.1	5.3 $\pm$ 0.2	5.1 $\pm$ 0.8
NNE-3	8.2 $\pm$ 0.8	8.3 $\pm$ 0.1	8.0 $\pm$ 0.1	9.4 $\pm$ 1.0	8.5 $\pm$ 1.3
NNE-4	5.2 $\pm$ 0.3	6.1 $\pm$ 0.2	5.0 $\pm$ 0.2	5.5 $\pm$ 0.4	5.5 $\pm$ 1.0
NE-5	7.9 $\pm$ 0.5	8.2 $\pm$ 0.2	7.0 $\pm$ 0.1	8.0 $\pm$ 0.1	7.8 $\pm$ 1.1
NE-6	5.4 $\pm$ 0.3	5.2 $\pm$ 0.2	4.9 $\pm$ 0.4	5.6 $\pm$ 0.7	5.3 $\pm$ 0.6
ENE-7	6.6 $\pm$ 0.3	8.4 $\pm$ 0.5	6.2 $\pm$ 0.2	6.6 $\pm$ 0.2	7.0 $\pm$ 2.0
ENE-8	(a)	4.3 $\pm$ 0.2	4.2 $\pm$ 0.3	4.6 $\pm$ 0.3	4.4 $\pm$ 0.4
E-9	6.9 $\pm$ 0.2	6.6 $\pm$ 0.1	6.5 $\pm$ 0.2	7.1 $\pm$ 0.3	6.8 $\pm$ 0.6
E-10	6.2 $\pm$ 0.0	6.8 $\pm$ 0.6	5.5 $\pm$ 0.1	6.1 $\pm$ 0.3	6.2 $\pm$ 1.1
ESE-11	5.9 $\pm$ 0.1	5.6 $\pm$ 0.1	5.8 $\pm$ 0.9	6.5 $\pm$ 0.8	6.0 $\pm$ 0.8
ESE-12	6.8 $\pm$ 1.1	6.5 $\pm$ 0.4	6.6 $\pm$ 0.4	6.8 $\pm$ 0.2	6.7 $\pm$ 0.3
SE-13	6.4 $\pm$ 0.2	5.8 $\pm$ 0.1	5.7 $\pm$ 0.1	5.8 $\pm$ 0.8	5.9 $\pm$ 0.6
SE-14	8.9 $\pm$ 0.5	8.5 $\pm$ 0.7	8.3 $\pm$ 0.2	8.5 $\pm$ 0.2	8.6 $\pm$ 0.5
SSE-15	5.9 $\pm$ 0.3	7.2 $\pm$ 0.6	6.6 $\pm$ 0.2	6.7 $\pm$ 0.1	6.6 $\pm$ 1.1
SSE-16	5.3 $\pm$ 0.3	5.1 $\pm$ 0.3	4.9 $\pm$ 0.2	5.3 $\pm$ 0.2	5.2 $\pm$ 0.4
S-17	8.3 $\pm$ 0.1	7.7 $\pm$ 0.8	7.9 $\pm$ 0.2	8.4 $\pm$ 0.8	8.1 $\pm$ 0.7
S-18	4.5 $\pm$ 0.7	4.0 $\pm$ 0.3	4.1 $\pm$ 0.1	4.4 $\pm$ 0.3	4.3 $\pm$ 0.5
SSW-19	7.8 $\pm$ 0.7	9.2 $\pm$ 0.8	7.0 $\pm$ 0.4	7.5 $\pm$ 0.4	7.9 $\pm$ 1.9
SSW-20	4.2 $\pm$ 0.2	3.9 $\pm$ 0.1	4.0 $\pm$ 0.0	4.3 $\pm$ 0.4	4.1 $\pm$ 0.4
SW-21	5.5 $\pm$ 0.2	5.0 $\pm$ 0.2	5.1 $\pm$ 0.1	5.4 $\pm$ 0.5	5.3 $\pm$ 0.5
SW-22	6.4 $\pm$ 0.4	6.3 $\pm$ 0.2	6.0 $\pm$ 0.4	6.6 $\pm$ 0.2	6.3 $\pm$ 0.5
WSW-23	7.6 $\pm$ 0.2	7.7 $\pm$ 1.3	7.4 $\pm$ 0.3	7.9 $\pm$ 0.4	7.7 $\pm$ 0.4
WSW-24	6.3 $\pm$ 0.3	6.2 $\pm$ 0.1	6.2 $\pm$ 0.1	6.6 $\pm$ 0.2	6.3 $\pm$ 0.4
W-25	8.5 $\pm$ 0.3	8.2 $\pm$ 0.8	7.7 $\pm$ 0.1	8.3 $\pm$ 0.2	8.2 $\pm$ 0.7
W-26	4.5 $\pm$ 0.4	4.6 $\pm$ 0.1	4.6 $\pm$ 0.1	5.1 $\pm$ 0.0	4.7 $\pm$ 0.5
WNW-27	5.1 $\pm$ 0.1	5.2 $\pm$ 0.2	4.9 $\pm$ 0.2	5.2 $\pm$ 0.2	5.1 $\pm$ 0.3
WNW-28	5.5 $\pm$ 1.6	4.7 $\pm$ 0.1	4.5 $\pm$ 0.1	5.0 $\pm$ 0.1	4.9 $\pm$ 0.9
NW-29	6.9 $\pm$ 0.1	6.7 $\pm$ 0.1	7.3 $\pm$ 0.2	7.8 $\pm$ 0.5	7.2 $\pm$ 1.0
NW-30	5.1 $\pm$ 0.2	6.2 $\pm$ 0.2	4.7 $\pm$ 0.1	5.3 $\pm$ 0.1	5.3 $\pm$ 1.3
NNW-31	6.0 $\pm$ 0.3	6.3 $\pm$ 0.5	4.8 $\pm$ 0.2	5.7 $\pm$ 0.5	5.7 $\pm$ 1.3
NNW-32	5.8 $\pm$ 0.1	6.7 $\pm$ 0.3	5.2 $\pm$ 0.2	5.7 $\pm$ 0.3	5.9 $\pm$ 1.2
N-33	6.6 $\pm$ 0.2	6.3 $\pm$ 0.8	5.9 $\pm$ 0.1	6.5 $\pm$ 0.2	6.3 $\pm$ 0.6
N-34	5.2 $\pm$ 0.2	4.7 $\pm$ 0.3	4.5 $\pm$ 0.2	4.2 $\pm$ 1.6	4.7 $\pm$ 0.8
NNE-35	8.8 $\pm$ 0.4	8.3 $\pm$ 0.3	7.9 $\pm$ 0.1	8.9 $\pm$ 0.3	8.5 $\pm$ 0.9
NNE-36	5.7 $\pm$ 0.1	5.4 $\pm$ 0.1	5.4 $\pm$ 0.4	5.7 $\pm$ 0.2	5.6 $\pm$ 0.3
NE-37	8.1 $\pm$ 0.2	7.8 $\pm$ 0.6	7.0 $\pm$ 0.2	7.9 $\pm$ 0.2	7.7 $\pm$ 1.0
NE-38	5.6 $\pm$ 0.2	5.1 $\pm$ 0.1	4.9 $\pm$ 0.2	5.7 $\pm$ 0.6	5.3 $\pm$ 0.8
ENE-39	6.9 $\pm$ 0.1	6.9 $\pm$ 1.4	6.5 $\pm$ 0.2	7.6 $\pm$ 0.8	7.0 $\pm$ 0.9
ENE-40	(a)	4.2 $\pm$ 0.1	4.2 $\pm$ 0.1	4.9 $\pm$ 0.8	4.4 $\pm$ 0.8
E-41	7.2 $\pm$ 0.2	7.7 $\pm$ 0.5	6.5 $\pm$ 0.2	7.7 $\pm$ 0.1	7.3 $\pm$ 1.1
E-42	6.2 $\pm$ 0.2	6.5 $\pm$ 0.1	5.7 $\pm$ 0.1	6.8 $\pm$ 0.2	6.3 $\pm$ 0.9
ESE-43	6.1 $\pm$ 0.1	6.5 $\pm$ 0.2	5.4 $\pm$ 0.1	6.4 $\pm$ 0.1	6.1 $\pm$ 1.0
ESE-44	6.8 $\pm$ 0.1	6.6 $\pm$ 0.9	6.1 $\pm$ 0.2	7.8 $\pm$ 1.3	6.8 $\pm$ 1.4
SE-45	6.5 $\pm$ 0.2	5.7 $\pm$ 0.2	5.9 $\pm$ 0.6	6.8 $\pm$ 0.9	6.2 $\pm$ 1.0

(a) TLD missing.

**TABLE B-16: DIRECT RADIATION MEASUREMENTS**  
**SECTOR QUARTERLY TLD RESULTS**

North Anna Power Station, Louisa County, Virginia - 1995

mR5/Std. Month (30.4 days)  $\pm$  2 Sigma

Page 2 of 2

Station Number	First Qtr 01/05-03/29	Second Qtr 03/29-06/28	Third Qtr 06/28-09/27	Fourth Qtr 09/27-12/28	Average $\pm$ 2 S.d.
SE-46	8.6 $\pm$ 0.3	8.4 $\pm$ 0.2	8.1 $\pm$ 0.2	9.4 $\pm$ 1.0	8.6 $\pm$ 1.1
SSE-47	6.8 $\pm$ 0.2	6.6 $\pm$ 0.3	6.0 $\pm$ 0.2	6.8 $\pm$ 0.3	6.6 $\pm$ 0.8
SSE-48	5.7 $\pm$ 0.1	5.3 $\pm$ 0.5	4.7 $\pm$ 0.1	5.7 $\pm$ 0.2	5.4 $\pm$ 0.9
S-49	8.6 $\pm$ 0.1	8.4 $\pm$ 0.6	7.9 $\pm$ 0.3	9.0 $\pm$ 0.9	8.5 $\pm$ 0.9
S-50	4.6 $\pm$ 0.1	5.2 $\pm$ 0.3	3.7 $\pm$ 0.1	5.0 $\pm$ 0.4	4.6 $\pm$ 1.3
SSW-51	8.4 $\pm$ 0.3	9.0 $\pm$ 0.5	7.0 $\pm$ 0.2	8.3 $\pm$ 0.1	8.2 $\pm$ 1.7
SSW-52	4.7 $\pm$ 0.1	4.2 $\pm$ 0.1	4.0 $\pm$ 0.1	5.0 $\pm$ 0.1	4.5 $\pm$ 0.9
SW-53	5.5 $\pm$ 0.1	5.1 $\pm$ 0.8	5.0 $\pm$ 0.1	5.7 $\pm$ 0.3	5.3 $\pm$ 0.7
SW-54	6.5 $\pm$ 0.1	6.7 $\pm$ 0.1	6.3 $\pm$ 0.2	6.7 $\pm$ 0.3	6.6 $\pm$ 0.4
WSW-55	7.4 $\pm$ 0.1	7.0 $\pm$ 0.5	7.1 $\pm$ 0.1	8.3 $\pm$ 0.3	7.5 $\pm$ 1.2
WSW-56	6.0 $\pm$ 0.3	5.3 $\pm$ 0.6	6.1 $\pm$ 0.1	6.7 $\pm$ 0.7	6.0 $\pm$ 1.1
W-57	8.6 $\pm$ 0.2	7.3 $\pm$ 1.2	7.4 $\pm$ 0.3	8.4 $\pm$ 0.4	7.9 $\pm$ 1.3
W-58	4.6 $\pm$ 0.1	5.2 $\pm$ 0.9	4.5 $\pm$ 0.1	5.3 $\pm$ 0.3	4.9 $\pm$ 0.8
WNW-59	5.2 $\pm$ 0.2	4.7 $\pm$ 0.1	4.8 $\pm$ 0.1	5.4 $\pm$ 0.2	5.0 $\pm$ 0.7
WNW-60	5.6 $\pm$ 0.4	4.6 $\pm$ 0.1	4.7 $\pm$ 0.1	5.2 $\pm$ 0.2	5.0 $\pm$ 0.9
NW-61	6.8 $\pm$ 0.3	6.1 $\pm$ 0.3	7.2 $\pm$ 0.1	8.1 $\pm$ 0.2	7.1 $\pm$ 1.7
NW-62	5.0 $\pm$ 0.1	5.2 $\pm$ 0.2	4.6 $\pm$ 0.1	5.3 $\pm$ 0.3	5.0 $\pm$ 0.6
NNW-63	5.7 $\pm$ 0.4	5.2 $\pm$ 0.1	5.2 $\pm$ 0.1	6.1 $\pm$ 0.7	5.6 $\pm$ 0.9
NNW-64	5.8 $\pm$ 0.1	5.7 $\pm$ 0.5	5.3 $\pm$ 0.2	6.1 $\pm$ 0.7	5.7 $\pm$ 0.7
C-1	5.1 $\pm$ 0.1	5.1 $\pm$ 0.1	4.8 $\pm$ 0.2	5.4 $\pm$ 0.4	5.1 $\pm$ 0.5
C-2	5.2 $\pm$ 0.2	5.1 $\pm$ 0.2	4.8 $\pm$ 0.1	5.1 $\pm$ 0.2	5.1 $\pm$ 0.3
C-3	4.9 $\pm$ 0.3	5.1 $\pm$ 0.3	5.0 $\pm$ 0.1	4.3 $\pm$ 2.8	4.8 $\pm$ 0.7
C-4	5.0 $\pm$ 0.1	5.3 $\pm$ 0.4	4.8 $\pm$ 0.1	5.4 $\pm$ 0.1	5.1 $\pm$ 0.6
C-5	4.2 $\pm$ 0.1	4.0 $\pm$ 0.1	3.9 $\pm$ 0.2	4.4 $\pm$ 0.1	4.1 $\pm$ 0.4
C-6	4.2 $\pm$ 0.4	3.9 $\pm$ 0.1	4.0 $\pm$ 0.2	4.5 $\pm$ 0.1	4.2 $\pm$ 0.5
C-7	6.2 $\pm$ 0.4	6.8 $\pm$ 0.6	5.7 $\pm$ 0.1	6.5 $\pm$ 0.2	6.3 $\pm$ 0.9
C-8	6.2 $\pm$ 0.2	5.9 $\pm$ 0.2	5.7 $\pm$ 0.2	6.2 $\pm$ 0.3	6.0 $\pm$ 0.5
<b>Average</b>	<b>6.2 <math>\pm</math> 2.5</b>	<b>6.1 <math>\pm</math> 2.7</b>	<b>5.7 <math>\pm</math> 2.4</b>	<b>6.4 <math>\pm</math> 2.7</b>	<b>6.2 <math>\pm</math> 5.5</b>

**APPENDIX C**  
**LAND USE CENSUS - 1995**

**VIRGINIA POWER**  
**NORTH ANNA POWER STATION**  
**Annual Radiological Environmental Land Use Census Data for 1995**  
**July (1-31)**

Sector	Nearest Resident KM	Nearest Site Boundary KM	Milk * Cow KM	Meat Animal KM	Milk * Goat KM	Veg. Garden 500 Sq Ft. KM
N	2.14	1.40		3.23		2.98
NNE	1.51	1.36		4.22		1.87
NE	1.57	1.32		2.51		1.80
ENE	3.17	1.31		4.12		3.17
E	1.95	1.33				1.95
ESE	2.53	1.37		7.74		5.63
SE	2.20	1.41		2.20		2.20
SSE	1.47	1.47		3.83		1.55
S	1.67	1.52		2.32		1.67
SSW	2.30	1.62		6.61		2.20
SW	4.83	1.70				4.83
WSW	2.86	1.75		2.86		2.86
W	2.60	1.71				3.20
WNW	1.61	1.64		6.13		4.28
NW	1.57	1.56				1.77
NNW	1.72	1.45		3.57		1.80

\* Note: No milk cow or goats within a five mile radius of North Anna Power Station  
 KM = Kilometer

**VIRGINIA POWER**  
**NORTH ANNA POWER STATION**  
**Annual Radiological Environmental Land Use Census Data for 1995**  
**July (1-31)**

Sector	Nearest Resident M	Nearest Site Boundary M	Milk * Cow M	Meat Animal M	Milk * Goat M	Veg. Garden 500 Sq Ft. M
N	1.33	0.87		2.01		1.85
NNE	0.94	0.85		2.62		1.16
NE	0.98	0.82		1.56		1.12
ENE	1.97	0.81		2.56		1.97
E	1.21	0.83				1.21
ESE	1.57	0.85		4.81		3.50
SE	1.37	0.88		1.37		1.37
SSE	0.91	0.91		2.38		0.96
S	1.04	0.94		1.44		1.04
SSW	1.43	1.01		4.11		1.37
SW	3.00	1.06				3.00
WSW	1.78	1.09		1.78		1.78
W	1.61	1.06				1.99
WNW	1.00	1.02		3.83		2.66
NW	0.98	0.97				1.10
NNW	1.07	0.90		2.22		1.12

\* Note: No milk cow or goats within a five mile radius of North Anna Power Station  
M = Mile

**VIRGINIA POWER**  
**NORTH ANNA POWER STATION**  
**COMPARISON OF THE 1995 TO 1994 LAND USE CENSUS**

- I. Changes in the nearest resident status as compared to previous year are as follows:
  - a. E Sector: 2.03 Km (1994) to 1.95 Km (1995)
  - b. ESE Sector: 2.60 Km (1994) to 2.53 Km (1995)
- II. No changes were observed in the nearest site boundary distances.
- III. No changes were observed in the nearest milk cow/goat status.
- IV. Changes in nearest vegetable garden as compared to previous year are as follows.
  - a. E Sector: 2.53 Km (1994) to 1.95 Km (1995)
- V. No changes were observed in the nearest meat animal status.



**APPENDIX D**  
**SYNOPSIS OF ANALYTICAL PROCEDURES**

## ***ANALYTICAL PROCEDURES SYNOPSIS***

Appendix D is a synopsis of the analytical procedures performed on samples collected for the North Anna Power Station's Radiological Environmental Monitoring Program. All analyses have been mutually agreed upon by VEPCO and Teledyne Brown Engineering and include those recommended by the USNRC Branch Technical Position, Rev. 1, November 1979.

<u><b>ANALYSIS TITLE</b></u>	<u><b>PAGE</b></u>
Gross Beta Analysis of Samples .....	93
Airborne Particulates .....	93
Water .....	94
Analysis of Samples for Tritium (Liquid Scintillation) .....	95
Analysis of Samples for Strontium-89 and -90 .....	96
Total Water .....	96
Milk .....	96
Soil and Sediment .....	96
Organic Solids .....	97
Air Particulates .....	99
Analysis of Samples for Iodine-131 .....	99
Milk or Water .....	99
Gamma Spectrometry of Samples .....	100
Milk and Water .....	100
Dried Solids other than Soils and Sediment .....	100
Fish .....	100
Soils and Sediments .....	100
Charcoal Cartridges (Air Iodine) .....	100
Airborne Particulates .....	100
Environmental Dosimetry .....	102

## GROSS BETA ANALYSIS OF SAMPLES

### Air Particulates

After a delay of five or more days, allowing for the radon-222 and radon-220 (thoron) daughter products to decay, the filters are counted in a gas-flow proportional counter. An unused air particulate filter, supplied by the customer, is counted as the blank.

Calculations of the results, the two sigma error and the lower limit of detection (LLD):

$$\text{RESULT (pCi/m}^3\text{)} = ((S/T) - (B/t))/(2.22 \text{ V E})$$

$$\text{TWO SIGMA ERROR (pCi/m}^3\text{)} = 2((S/T^2) + (B/t^2))^{1/2}/(2.22 \text{ V E})$$

$$\text{LLD (pCi/m}^3\text{)} = 4.66 (B^{1/2})/(2.22 \text{ V E t})$$

where:

- S = Gross counts of sample including blank
- B = Counts of blank
- E = Counting efficiency
- T = Number of minutes sample was counted
- t = Number of minutes blank was counted
- V = Sample aliquot size (cubic meters)

## **DETERMINATION OF GROSS BETA ACTIVITY IN WATER SAMPLES**

### **Introduction**

The procedures described in this section are used to measure the overall radioactivity of water samples without identifying the radioactive species present. No chemical separation techniques are involved.

One liter of the sample is evaporated on a hot plate. A smaller volume may be used if the sample has a significant salt content as measured by a conductivity meter. If requested by the customer, the sample is filtered through No. 54 filter paper before evaporation, removing particles greater than 30 microns in size.

After evaporating to a small volume in a beaker, the sample is rinsed into a 2-inch diameter stainless steel planchette which is stamped with a concentric ring pattern to distribute residue evenly. Final evaporation to dryness takes place under heat lamps.

Residue mass is determined by weighing the planchette before and after mounting the sample. The planchette is counted for beta activity on an automatic proportional counter. Results are calculated using empirical self-absorption curves which allow for the change in effective counting efficiency caused by the residue mass.

### **Detection Capability**

Detection capability depends upon the sample volume actually represented on the planchette, the background and the efficiency of the counting instrument, and upon self-absorption of beta particles by the mounted sample. Because the radioactive species are not identified, no decay corrections are made and the reported activity refers to the counting time.

The minimum detectable level (MDL) for water samples is nominally 1.6 picoCuries per liter for gross beta at the 4.66 sigma level (1.0 pCi/l at the 2.83 sigma level), assuming that 1 liter of sample is used and that  $\frac{1}{2}$  gram of sample residue is mounted on the planchette. These figures are based upon a counting time of 50 minutes and upon representative values of counting efficiency and background of 0.2 and 1.2 cpm, respectively.

The MDL becomes significantly lower as the mount weight decreases because of reduced self-absorption. At a zero mount weight, the 4.66 sigma MDL for gross beta is 0.9 picoCuries per liter. These values reflect a beta counting efficiency of 0.38.

## ANALYSIS OF SAMPLES FOR TRITIUM

(Liquid Scintillation)

### Water

Ten milliliters of water are mixed with 10 ml of a liquid scintillation "cocktail" and then the mixture is counted in an automatic liquid scintillator.

Calculation of the results, the two sigma error and the lower limit detection (LLD) in pCi/l:

$$\text{RESULT} = (N-B)/(2.22 V E)$$

$$\text{TWO SIGMA ERROR} = 2((N + B)/\Delta t)^{1/2} / (2.22 V E)$$

$$\text{LLD} = 4.66 (B/\Delta t)^{1/2} / (2.22 V E)$$

where:

N	=	the gross cpm of the sample
B	=	the background of the detector in cpm
2.22	=	conversion factor changing dpm to pCi
V	=	volume of the sample in ml
E	=	efficiency of the detector
$\Delta t$	=	counting time for the sample

## **ANALYSIS OF SAMPLES FOR STRONTIUM-89 AND -90**

### **Water**

Stable strontium carrier is added to 1 liter of sample and the volume is reduced by evaporation. Strontium is precipitated as  $\text{Sr}(\text{NO}_3)_2$  using nitric acid. A barium scavenge and an iron (ferric hydroxide) scavenge are performed followed by addition of stable yttrium carrier and a minimum of 5 day period for yttrium ingrowth. Yttrium is then precipitated as hydroxide, dissolved and re-precipitated as oxalate. The yttrium oxalate is mounted on a nylon planchette and is counted in a low level beta counter to infer Sr-90 activity. Strontium-89 activity is determined by precipitating  $\text{SrCO}_3$  from the sample after yttrium separation. This precipitate is mounted on a nylon planchette and is covered with an  $80 \text{ mg/cm}^2$  aluminum absorber for low level beta counting.

### **Milk**

Stable strontium carrier is added to 1 liter of sample and the sample is first evaporated, then ashed in a muffle furnace. The ash is dissolved and strontium is precipitated as phosphate, then is dissolved and precipitated as  $\text{SrNO}_3$  using fuming (90%) nitric acid. A barium chromate scavenge and an iron (ferric hydroxide) scavenge are then performed. Stable yttrium carrier is added and the sample is allowed to stand for a minimum of 5 days for yttrium ingrowth. Yttrium is then precipitated as hydroxide, dissolved and re-precipitated as oxalate. The yttrium oxalate is mounted on a nylon planchette and is counted in a low level beta counter to infer Sr-90 activity. Strontium-89 is determined by precipitating  $\text{SrCO}_3$  from the sample after yttrium separation. This precipitate is mounted on a nylon planchette and is covered with an  $80 \text{ mg/cm}^2$  aluminum absorber for low level beta counting.

### **Soil and Sediment**

The sample is first dried under heat lamps and an aliquot is taken. Stable strontium carrier is added and the sample is leached in hydrochloric acid. The mixture is filtered and strontium is precipitated from the liquid portion as phosphate. Strontium is precipitated as  $\text{Sr}(\text{NO}_3)_2$  using fuming (90% nitric acid). A barium chromate scavenge and an iron (ferric hydroxide) scavenge are then performed. Stable yttrium carrier is added and the sample is allowed to stand for a minimum of 5 days for yttrium ingrowth. Yttrium is then precipitated as hydroxide, dissolved and re-precipitated as oxalate. The yttrium oxalate is mounted on a nylon planchette and is counted in a low level beta counter to infer Sr-90 activity. Strontium-89 activity is determined by precipitating  $\text{SrCO}_3$  from the sample after yttrium separation. This precipitate is mounted on a nylon planchette and is covered with an  $80 \text{ mg/cm}^2$  aluminum absorber for low level beta counting.

## Organic Solids

A wet portion of the sample is dried and then ashed in a muffle furnace. Stable strontium carrier is added and the ash is leached in hydrochloric acid. The sample is filtered and strontium is precipitated from the liquid portion as phosphate. Strontium is precipitated as  $\text{Sr}(\text{NO}_3)_2$  using fuming (90%) nitric acid. An iron (ferric hydroxide) scavenge is performed, followed by addition of stable yttrium carrier and a minimum of 5 days period for yttrium ingrowth. Yttrium is then precipitated as hydroxide, dissolved and re-precipitated as oxalate. The yttrium oxalate is mounted on a nylon planchette and is counted in a low level beta counter to infer strontium-90 activity. Strontium-89 activity is determined by precipitating  $\text{SrCO}_3$  from the sample after yttrium separation. This precipitate is mounted on a nylon planchette and is covered with an  $80 \text{ mg/cm}^2$  aluminum absorber for low level beta counting.

## Air Particulates

Stable strontium carrier is added to the sample and it is leached in nitric acid to bring deposits into solution. The mixture is then filtered and the filtrate is reduced in volume by evaporation. Strontium is precipitated as  $\text{Sr}(\text{NO}_3)_2$  using fuming (90%) nitric acid. A barium scavenge is used to remove some interfering species. An iron (ferric hydroxide) scavenge is performed, followed by addition of stable yttrium carrier and a 7 to 10 day period for yttrium ingrowth. Yttrium is then precipitated as hydroxide, dissolved and re-precipitated as oxalate. The yttrium oxalate is mounted on a nylon planchette and is counted in a low level beta counter to infer strontium-90 activity. Strontium-89 activity is determined by precipitating  $\text{SrCO}_3$  from the sample after yttrium separation. This precipitate is mounted on a nylon planchette and is covered with  $80 \text{ mg/cm}^2$  aluminum absorber for low level beta counting.

Calculations of the results, two sigma errors and lower limits of detection (LLD) are expressed in activity of pCi/volume or pCi/mass:

$$\begin{aligned}\text{RESULT Sr-89} &= (N/Dt - B_C - B_A)/(2.22 \text{ V } Y_S \text{ DF}_{\text{SR-89}} E_{\text{SR-89}}) \\ \text{TWO SIGMA ERROR Sr-89} &= 2((N/Dt + B_C + B_A)/\Delta t)^{1/2}/(2.22 \text{ V } Y_S \text{ DF}_{\text{SR-89}} E_{\text{SR-89}}) \\ \text{LLD Sr-89} &= 4.66((B_C + B_A)/\Delta t)^{1/2}/(2.22 \text{ V } Y_S \text{ DF}_{\text{SR-89}} E_{\text{SR-89}}) \\ \text{RESULT Sr-90} &= (N/\Delta t - B)/(2.22 \text{ V } Y_1 Y_2 \text{ DF IF E}) \\ \text{TWO SIGMA ERROR Sr-90} &= 2((N/\Delta t + B)/\Delta t)^{1/2}/(2.22 \text{ V } Y_1 Y_2 \text{ DF E IF}) \\ \text{LLD Sr-90} &= 4.66(B/\Delta t)^{1/2}/(2.22 \text{ V } Y_1 Y_2 \text{ IF DF E})\end{aligned}$$



WHERE:	N	=	total counts from sample (counts)
	$\Delta t$	=	counting time for sample (min)
	$B_C$	=	background rate of counter (cpm) using absorber configuration
	2.22	=	dpm/pCi
	V	=	volume or weight of sample analyzed
	$B_A$	=	background addition from Sr-90 and ingrowth of Y-90
	$B_A$	=	$0.016 (K) + (K) E_{Y/abs} (IG_{Y-90})$
	$Y_S$	=	chemical yield of strontium
	DF SR-89	=	decay factor from the mid collection date to the counting date for SR-89
	$E_{SR-89}$	=	efficiency of the counter for SR-89 with the 80 mg/cm.sq. aluminum absorber
	K	=	$(N\Delta t - B_C)Y_{-90}/(E_{Y-90} IF_{Y-90} DF_{Y-90} Y_1)$
	DF <sub>Y-90</sub>	=	the decay factor for Y-90 from the "milk" time to the mid count time
	$E_{Y-90}$	=	efficiency of the counter for Y-90
	IF <sub>Y-90</sub>	=	ingrowth factor for Y-90 from scavenge time to milking time
	IG <sub>Y-90</sub>	=	the ingrowth factor for Y-90 into the strontium mount from the "milk" time to the mid count time
	0.016	=	the efficiency of measuring SR-90 through a No. 6 absorber
	$E_{Y/abs}$	=	the efficiency of counting Y-90 through a No. 6 absorber
	B	=	background rate of counter (cpm)
	$Y_1$	=	chemical yield of yttrium
	$Y_2$	=	chemical yield of strontium
	DF	=	decay factor of yttrium from the radiochemical milking time to the mid count time
	E	=	efficiency of the counter for Y-90
	IF	=	ingrowth factor for Y-90 from scavenge time to the radio-chemical milking time

## ANALYSIS OF SAMPLES FOR IODINE-131

### Milk or Water

Two liters of sample are first equilibrated with stable iodide carrier. A batch treatment with anion exchange resin is used to remove iodine from the sample. The iodine is then stripped from the resin with sodium hypochlorite solution, is reduced with hydroxylamine hydrochloride and is extracted into carbon tetrachloride as free iodine. It is then back-extracted as iodide into sodium bisulfite solution and is precipitated as palladium iodide. The sodium bisulfite solution and is precipitated as palladium iodide. The precipitate is weighed for chemical yield and is mounted on a nylon planchette for low level beta counting. The chemical yield is corrected by measuring the stable iodide content of the milk or the water with a specific ion electrode.

Calculations of results, two sigma error and the lower limit of detection (LLD) in pCi/l:

$$\text{RESULT} = (N/\Delta t - B)/(2.22 E V Y DF)$$

$$\text{TWO SIGMA ERROR} = 2((N/\Delta t + B)/\Delta t)^{1/2}/(2.22 E V Y DF)$$

$$\text{LLD} = 4.66(B/\Delta t)^{1/2}/(2.22 E V Y DF)$$

where:	N	=	total counts from sample (counts)
	$\Delta t$	=	counting time for sample (min)
	B	=	background rate of counter (cpm)
	2.22	=	dpm/pCi
	V	=	volume or weight of sample analyzed
	Y	=	chemical yield of the mount or sample counted
	DF	=	decay factor from the collection to the counting date
	E	=	efficiency of the counter for I-131, corrected for self absorption effects by the formula
	E	=	$E_s(\exp-0.0061M)/(\exp-0.0061M_s)$
	$E_s$	=	efficiency of the counter determined from an I-131 standard mount
	$M_s$	=	mass of $\text{PdI}_2$ on the standard mount, mg
	M	=	mass of $\text{PdI}_2$ on the sample mount, mg

## **GAMMA SPECTROMETRY OF SAMPLES**

### **Milk and Water**

A 1.0 liter Marinelli beaker is filled with a representative aliquot of the sample. The sample is then counted for approximately 1000 minutes with a shielded Ge(Li) detector coupled to a mini-computer-based data acquisition system which performs pulse height analysis.

### **Dried Solids Other Than Soils and Sediments**

A large quantity of the sample is dried at a low temperature, less than 100°C. As much as possible (up to the total sample) is loaded into a tared 1-liter Marinelli and weighed. The sample is then counted for approximately 1000 minutes with a shielded Ge(Li) detector coupled to a mini-computer-based data acquisition system which performs pulse height analysis.

### **Fish**

As much as possible (up to the total sample) of the edible portion of the sample is loaded into a tared Marinelli and weighed. The sample is then counted for approximately 1000 minutes with a shielded Ge(Li) detector coupled to a mini-computer-based data acquisition system which performs pulse height analysis.

### **Soils and Sediments**

Soils and sediments are dried at a low temperature, less than 100°C. The soil or sediment is loaded fully into a tared, standard 300 cc container and weighed. The sample is then counted for approximately six hours with a shielded Ge(Li) detector coupled to a mini-computer-based data acquisition system which performs pulse height and analysis.

### **Charcoal Cartridges (Air Iodine)**

Charcoal cartridges are counted up to five at a time, with one positioned on the face of a Ge(Li) detector and up to four on the side of the Ge(Li) detector. Each Ge(Li) detector is calibrated for both positions. The detection limit for I-131 of each charcoal cartridge can be determined (assuming no positive I-131) uniquely from the volume of air which passed through it. In the event I-131 is observed in the initial counting of a set, each charcoal cartridge is then counted separately, positioned on the face of the detector.

### **Air Particulate**

The thirteen airborne particulate filters for a quarterly composite for each field station are aligned one in front of another and then counted for at least six hours with a shielded Ge(Li)

detector coupled to a mini-computer-based data acquisition system which performs pulse height analysis.

A mini-computer software program defines peaks by certain changes in the slope of the spectrum. The program also compares the energy of each peak with a library of peaks for isotope identification and then performs the radioactivity calculation using the appropriate fractional gamma ray abundance, half life, detector efficiency, and net counts in the peak region. The calculation of results, two sigma error and the lower limit of detection (LLD) in pCi/volume of pCi/mass:

$$\text{RESULT} = (S-B)/(2.22 \text{ t E V F DF})$$

$$\text{TWO SIGMA ERROR} = 2(S+B)^{1/2}/(2.22 \text{ t E V F DF})$$

$$\text{LLD} = 4.66(B)^{1/2}/(2.22 \text{ t E V F DF})$$

where:

S	=	Area, in counts, of sample peak and background (region of spectrum of interest)
B	=	Background area, in counts, under sample peak, determined by a linear interpolation of the representative backgrounds on either side of the peak
t	=	length of time in minutes the sample was counted
2.22	=	dpm/pCi
E	=	detector efficiency for energy of interest and geometry of sample
V	=	sample aliquot size (liters, cubic meters, kilograms, or grams)
F	=	fractional gamma abundance (specific for each emitted gamma)
DF	=	decay factor from the mid-collection date to the counting date

## ENVIRONMENTAL DOSIMETRY

Teledyne Brown Engineering uses a  $\text{CaSO}_4:\text{Dy}$  thermoluminescent dosimeter (TLD) which the company manufactures. This material has a high light output, negligible thermally induced signal loss (fading), and negligible self dosing. The energy response curve (as well as all other features) satisfies NRC Reg. Guide 4.13. Transit doses are accounted for by use of separate TLDs.

Following the field exposure period the TLDs are placed in a Teledyne Brown Engineering Model 8300. One fourth of the rectangular TLD is heated at a time and the measured light emission (luminescence) is recorded. The TLD is then annealed and exposed to a known Cs-137 dose; each area is then read again. This provides a calibration of each area of each TLD after every field use. The transit controls are read in the same manner.

Calculations of results and the two sigma error in net milliRoentgen (mR):

$$\begin{aligned}\text{RESULT} &= D = (D_1 + D_2 + D_3 + D_4)/4 \\ \text{TWO SIGMA ERROR} &= 2((D_1 - D)^2 + (D_2 - D)^2 + (D_3 - D)^2 + (D_4 - D)^2/3)^{1/2}\end{aligned}$$

WHERE:	$D_1$	=	the net mR of area 1 of the TLD, and similarly for $D_2$ , $D_3$ , and $D_4$
	$D_1$	=	$I_1 K/R_1 - A$
	$I_1$	=	the instrument reading of the field dose in area 1
	$K$	=	the known exposure by the Cs-137 source
	$R_1$	=	the instrument reading due to the Cs-137 dose on area 1
	$A$	=	average dose in mR, calculated in similar manner as above, of the transit control TLDs
	$D$	=	the average net mR of all 4 areas of the TLD.

**APPENDIX E**  
**EPA INTERLABORATORY COMPARISON PROGRAM**

### ***EPA Interlaboratory Comparison Program***

Teledyne Brown Engineering participates in the US EPA Interlaboratory Comparison Program to the fullest extent possible. That is, we participate in the program for all radioactive isotopes prepared and at the maximum frequency of availability. In this section the 1995 data summary tables are presented for isotopes in the various sample media applicable to the North Anna Power Station's Radiological Environmental Monitoring Program. The footnotes of the table discuss investigations of problems encountered in a few cases and the steps taken to prevent reoccurrence.



VEPCO - NORTH CAROLINA  
EPA INTERLABORATORY COMPARISON PROGRAM 1995  
(Page 1 of 2)

EPA Preparation	Date TI Mailed Results	Date EPA Issued Results	Media	Nuclide	EPA Results(a)		TI Results(b)		Norm Dev. (Known)(c)	**Warning ***Action
01/13/95	03/24/95	04/21/95	Water	Sr-89	20.0 ±	5.0	19.00 ±	2.65	-0.35	
				Sr-90	15.0 ±	5.0	14.00 ±	0.00	-0.35	
01/27/95	03/24/95	03/24/95	Water	Gr-Alpha	5.0 ±	5.0	5.00 ±	1.00	0.00	
				Gr-Beta	5.0 ±	5.0	6.00 ±	1.00	0.35	
02/03/95	03/20/95	04/21/95	Water	I-131	100.0 ±	10.0	88.33 ±	2.31	-2.02	** (d)
02/10/95	04/07/95	05/23/95	Water	Ra-226	19.1 ±	2.9	20.67 ±	0.58	0.94	
				Ra-228	20.0 ±	5.0	18.67 ±	0.58	-0.46	
03/10/95	04/06/95	05/19/95	Water	H-3	7435.0 ±	744.0	7066.67 ±	115.47	-0.86	
03/17/95	05/12/95	06/05/95	Water	Pu-239	11.1 ±	1.1	10.33 ±	0.58	-1.21	
04/18/95	06/30/95	08/18/95	Water	Gr-Beta	86.6 ±	10.0	80.33 ±	2.52	-1.09	
				Sr-89	20.0 ±	5.0	20.67 ±	1.15	0.23	
				Sr-90	15.0 ±	5.0	14.67 ±	0.58	-0.12	
				Co-60	29.0 ±	5.0	31.67 ±	2.08	0.92	
				Cs-134	20.0 ±	5.0	19.67 ±	1.73	-0.12	
				Cs-137	11.0 ±	5.0	11.67 ±	1.53	0.23	
				Gr-Alpha	47.5 ±	11.9	39.67 ±	2.52	-1.14	
				Ra-226	14.9 ±	2.2	15.67 ±	0.58	0.60	
				Ra-228	15.8 ±	4.0	13.00 ±	1.73	-1.21	
06/09/95	08/09/95	02/26/96	Water	Co-60	40.0 ±	5.0	42.33 ±	2.52	0.81	
				Zn-65	76.0 ±	8.0	82.33 ±	3.51	1.37	
				Cs-134	50.0 ±	5.0	46.67 ±	2.08	-1.15	
				Cs-137	35.0 ±	5.0	37.67 ±	1.15	0.92	
				Ba-133	79.0 ±	8.0	74.33 ±	2.08	-1.01	
06/16/95	08/09/95	09/05/95	Water	Ra-226	14.8 ±	2.2	15.00 ±	0.00	0.16	
				Ra-228	15.0 ±	3.8	14.00 ±	0.00	-0.46	
07/14/95	08/09/95	09/05/95	Water	Sr-89	20.0 ±	5.0	18.33 ±	1.53	-0.58	
				Sr-90	8.0 ±	5.0	8.0 ±	0.00	0.00	
07/21/95	08/18/95	09/27/95	Water	Gr-Alpha	27.5 ±	6.9	18.33 ±	1.53	-2.30	** (e)
				Gr-Beta	19.4 ±	5.0	19.33 ±	1.53	-0.02	
08/04/95	09/01/95	09/29/95	Water	H-3	4872.0 ±	487.0	4866.67 ±	152.75	-0.02	

Footnotes at end of table.

**VEPCO - NORTH ANNA**  
EPA INTERLABORATORY COMPARISON PROGRAM 1995  
(Page 2 of 2)

EPA Preparation	Date TI Mailed Results	Date EPA Issued Results	Media	Nuclide	EPA Results(a)		TI Results(b)		Norm Dev. (Known)	**Warning ***Action
08/25/95	10/21/95	02/29/96	Air Filter	Gr-Alpha	25.0 ±	6.3	23.67 ±	1.53	-0.37	
				Gr-Beta	86.6 ±	10.0	84.67 ±	1.53	-0.33	
				Sr-90	30.0 ±	5.0	25.33 ±	0.58	-1.62	
				Cs-137	25.0 ±	5.0	27.00 ±	1.00	0.69	
09/15/95	11/10/95	02/26/96	Water	Ra-226	24.8 ±	3.7	27.33 ±	1.15	1.19	
				Ra-228	20.0 ±	5.0	14.67 ±	0.58	-1.85	
09/29/95	11/28/95	02/29/96	Milk	Sr-89	20.0 ±	5.0	23.33 ±	3.06	1.15	
				Sr-90	15.00 ±	5.0	16.33 ±	0.58	0.46	
				I-131	99.0 ±	10.0	103.33 ±	5.77	0.75	
				Cs-137	50.0 ±	5.0	54.67 ±	2.52	1.62	
				Total K	1654.0 ±	83.0	1683.33 ±	136.50	0.61	
10/06/95	11/10/95	02/26/96	Water	I-131	148.0 ±	15.0	150.00 ±	0.00	0.23	
10/27/95	12/01/95	03/04/96	Water	Gr-Alpha	51.2 ±	12.8	37.00 ±	3.00	-1.92	
				Gr-Beta	24.8 ±	5.0	25.33 ±	1.53	0.18	

**Footnotes:**

(a) Average ± experimental sigma.

(b) Expected laboratory precision (1 sigma, 1 determination)


(c) Normalized deviation from the known.

(d) The normalized deviation marginally exceeded the warning level and an apparent trend in the results appeared. The cause was a probable high bias in the beta counting efficiency. Check source control charts did not indicate any changes in the counting equipment, so the I-131 calibration was suspected. New I-131 calibrations were performed July 3 through 6, 1995 after receiving a new standard from the EPA. The intercomparison sample data sheets were recalculated with the new efficiencies and the average result was in excellent agreement with the EPA (96 pCi/l versus the EPA value of 100 pCi/l). The discrepancy in the I-131 efficiency between the current calibration and the previous one (aside from the uncertainty in the standard) appears to be an abnormally low yield in the preparation of the standard for the older calibration which created a high bias in the counter efficiencies. The bias was less than ten percent, therefore further corrective action or revision of previously reported data is deemed not necessary.

(e) The mineral salt content of the water used by the EPA to prepare the samples has been shown to vary substantially throughout the year. Absorption curves to account for mount weight may vary from the true absorption characteristics of a specific sample. Previous results do not indicate a trend toward "out of control" for gross alpha/beta analysis and the normalized deviation from the grand average is only -0.36. The normalized deviation from the known for TBE-ES does not exceed three standard deviation and internal spikes have been in control. No corrective action is planned at this time.


## EPA CROSS CHECK PROGRAM

GROSS ALPHA IN AIR PARTICULATES (pg. 1 of 1)




# EPA CROSS CHECK PROGRAM

## GROSS BETA IN AIR PARTICULATES (pg. 1 of 1)




# EPA CROSS CHECK PROGRAM

## STRONTIUM-90 IN AIR PARTICULATES (pg. 1 of 1)




# EPA CROSS CHECK PROGRAM

## CESIUM-137 IN AIR PARTICULATES (pg. 1 of 1)



# EPA CROSS CHECK PROGRAM


## STRONTIUM-89 IN MILK (pg. 1 of 1)






# EPA CROSS CHECK PROGRAM

## STRONTIUM-90 IN MILK (pg. 1 of 1)




# EPA CROSS CHECK PROGRAM

## POTASSIUM-40 IN MILK (pg. 1 of 1)




# EPA CROSS CHECK PROGRAM

IODINE-131 IN MILK (pg. 1 of 1)




# EPA CROSS CHECK PROGRAM

## CESIUM-137 IN MILK (pg. 1 of 1)




# EPA CROSS CHECK PROGRAM


GROSS ALPHA IN WATER (pg. 1 of 1)



EPA CROSS CHECK PROGRAM  
GROSS BETA IN WATER (pg. 1 of 2)




EPA CROSS CHECK PROGRAM  
GROSS BETA IN WATER (pg. 2 of 2)






## EPA CROSS CHECK PROGRAM

TRITIUM IN WATER (pg. 1 of 2)




## EPA CROSS CHECK PROGRAM

TRITIUM IN WATER (pg. 2 of 2)




# EPA CROSS CHECK PROGRAM

IODINE-131 IN WATER (pg. 1 of 1)




# EPA CROSS CHECK PROGRAM

COBALT-60 IN WATER (pg 1 of 2)




# EPA CROSS CHECK PROGRAM

## COBALT-60 IN WATER (pg. 2 of 2)




EPA CROSS CHECK PROGRAM  
CESIUM-134 IN WATER (pg. 1 of 2)




# EPA CROSS CHECK PROGRAM

## CESIUM-134 IN WATER (pg. 2 of 2)






EPA CROSS CHECK PROGRAM  
CESIUM-137 IN WATER (pg. 1 of 2)




## EPA CROSS CHECK PROGRAM

CESIUM-137 IN WATER (pg. 2 of 2)




EPA CROSS CHECK PROGRAM  
STRONTIUM-89 IN WATER (pg. 1 of 2)



# EPA CROSS CHECK PROGRAM

## STRONTIUM-89 IN WATER (pg. 2 of 2)



EPA CROSS CHECK PROGRAM  
STRONTIUM-90 IN WATER (pg. 1 of 1)

