

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

MAR 6 1985

Mr. A. Schwencer, Chief
Licensing Branch No. 2
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Docket Nos: 50-352
50-353

SUBJECT: Limerick Generating Station
Meteorological Monitoring Program
Meteorological and Effluent Treatment Branch (METB)

REFERENCE: PECO and NRC Telecon dated February 26, 1985

FILE: GOVT 1-1 (NRC)

Dear Mr. Schwencer:

As requested by the Meteorological Branch reviewer in the reference conference call, we are providing for your review as attachment no. 1 to this letter, the summarized hourly data comparisons between Limerick meteorological towers 1 and 2 for the period October 15, 1983 to December 31, 1984. This summary indicates that Tower 2 data correlate well with data from corresponding levels on Tower 1 for the parameters required by LGS Technical Specification 3.3.7.3 and Regulatory Guide 1.97, Revision 2. Therefore, it is appropriate that Tower 2 data be used as backup when Tower 1 is inoperable, as permitted by present Limerick technical specifications.

Sincerely,

JW Gallagher
for
JS Kemper

RJS/dg/03068501

Attachment

(See Attached Service List)

13021
1/1

8503120269 850306
PDR ADDCK 05000352
R PDR