

April 17, 2020

Docket Nos.: 52-025

ND-20-0309
10 CFR 52.99(c)(1)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Southern Nuclear Operating Company
Vogtle Electric Generating Plant Unit 3
ITAAC Closure Notification on Completion of ITAAC E.3.9.05.01.04 [Index Number 852]


Ladies and Gentlemen:

In accordance with 10 CFR 52.99(c)(1), the purpose of this letter is to notify the Nuclear Regulatory Commission (NRC) of the completion of Vogtle Electric Generating Plant (VEGP) Unit 3 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item E.3.9.05.01.04 [Index Number 852] for confirming the Technical Support Center (TSC) is located within the protected area, and no major security barriers exist between the TSC and the VEGP Unit 3 control room. The closure process for this ITAAC is based on the guidance described in Nuclear Energy Institute (NEI) 08-01, "Industry Guideline for the ITAAC Closure Process Under 10 CFR Part 52," which was endorsed by the NRC in Regulatory Guide 1.215.

This letter contains no new NRC regulatory commitments. Southern Nuclear Operating Company (SNC) requests NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99.

If there are any questions, please contact Tom Petrak at 706-848-1575.

Respectfully submitted,



Michael J. Yox
Regulatory Affairs Director Vogtle 3 & 4

Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 3
Completion of ITAAC E.3.9.05.01.04 [Index Number 852]

MJY/RLB/sfr

To:

Southern Nuclear Operating Company/ Georgia Power Company

Mr. Peter P. Sena III (w/o enclosures)

Mr. D. L. McKinney (w/o enclosures)

Mr. M. D. Meier (w/o enclosures)

Mr. D. H. Jones (w/o enclosures)

Mr. G. Chick

Mr. M. Page

Mr. P. Martino

Mr. M. J. Yox

Mr. A. S. Parton

Ms. K. A. Roberts

Mr. T. G. Petrak

Mr. C. T. Defnall

Mr. C. E. Morrow

Mr. R. L. Beilke

Mr. S. Leighty

Ms. A. C. Chamberlain

Mr. J. C. Haswell

Document Services RTYPE: VND.LI.L06

File AR.01.02.06

cc:

Nuclear Regulatory Commission

Mr. W. Jones (w/o enclosures)

Mr. C. P. Patel

Mr. G. J. Khouri

Ms. S. E. Temple

Mr. N. D. Karlovich

Mr. A. Lerch

Mr. C. J. Even

Mr. B. J. Kemker

Ms. N. C. Coover

Mr. C. Welch

Mr. J. Gaslevic

Mr. V. Hall

Mr. G. Armstrong

Ms. T. Lamb

Mr. M. Webb

Mr. T. Fredette

Mr. C. Weber

Mr. S. Smith

Mr. C. Santos

Mrs. M. Bailey

Mr. S. Rose

Mr. B. Davis

Mr. J. Vasquez

Mr. J. Eargle

Ms. K. Carrington
Mr. P. Heher
Mr. M. King
Mr. E. Davidson

Oglethorpe Power Corporation

Mr. R. B. Brinkman
Mr. E. Rasmussen

Municipal Electric Authority of Georgia

Mr. J. E. Fuller
Mr. S. M. Jackson

Dalton Utilities

Mr. T. Bundros

Westinghouse Electric Company, LLC

Dr. L. Oriani (w/o enclosures)
Mr. D. C. Durham (w/o enclosures)
Mr. M. M. Corletti
Mr. Z. S. Harper
Mr. J. L. Coward

Other

Mr. J. E. Hesler, *Bechtel Power Corporation*
Ms. L. Matis, *Tetra Tech NUS, Inc.*
Dr. W. R. Jacobs, Jr., Ph.D., *GDS Associates, Inc.*
Mr. S. Roetger, *Georgia Public Service Commission*
Ms. S. W. Kernizan, *Georgia Public Service Commission*
Mr. K. C. Greene, *Troutman Sanders*
Mr. S. Blanton, *Balch Bingham*

**Southern Nuclear Operating Company
ND-20-0309
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 3
Completion of ITAAC E.3.9.05.01.04 [Index Number 852]**

ITAAC Statement

Program Commitment

5.1 The licensee has established a technical support center (TSC) and an onsite operations support center (OSC). [H.1]

Inspections/Tests/Analyses

5.1 An inspection of the as-built TSC and OSC will be performed, including a test of the capabilities.

Acceptance Criteria

5.1.4 The TSC is located within the protected area, and no major security barriers exist between the TSC and the control room.

ITAAC Determination Basis

Multiple ITAAC are performed to confirm that the licensee has established a technical support center (TSC) and an onsite operations support center (OSC). This ITAAC performs an inspection of the TSC location to confirm that the as-built TSC is located within the protected area, and no major security barriers exist between the TSC and the Vogtle Electric Generating Plant (VEGP) Unit 3 control room. As described in NUREG-0696, Functional Criteria for Emergency Response Facilities (Reference 1), there should be no major security barriers between the TSC and the control room other than access control stations for the TSC and control room.

An inspection (walkdown) was completed using TSC and protected area approved construction drawings and visual observations to confirm that the as-built TSC is located within the protected area. The inspection also documents the performance of a visual observation walkdown of the travel path between the VEGP Unit 3 control room and the TSC to confirm there are no major security barriers between the TSC and the control room other than the access control stations to the TSC and control room.

The inspection results are documented in Principal Closure Document SV3-ERF-ITR-800852 (Reference 2) supporting the Unit 3 ITAAC E.3.9.05.01.04 Completion Package (Reference 3) and verify that the TSC is located within the protected area, and no major security barriers exist between the TSC and the VEGP Unit 3 control room.

Reference 2 is available for NRC inspection as part of the Unit 3 ITAAC E.3.9.05.01.04 Completion Package (Reference 3).

ITAAC Finding Review

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of all findings pertaining to the subject ITAAC and associated corrective actions. This review found there are no relevant ITAAC findings associated with this ITAAC. The ITAAC completion review is documented in the ITAAC Completion Package for ITAAC E.3.9.05.01.04 (Reference 3) and is available for NRC review.

ITAAC Completion Statement

Based on the above information, SNC hereby notifies the NRC that ITAAC E.3.9.05.01.04 was performed for VEGP Unit 3 and that the prescribed acceptance criteria were met.

Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

References (available for NRC inspection)

1. NUREG-0696, Functional Criteria for Emergency Response Facilities, 1981
2. SV3-ERF-ITR-800852, Rev. 0, "Unit 3 ITAAC 852 Walkdown Inspection: ITAAC E.3.9.05.01.04"
3. E.3.9.05.01.04-U3-CP-Rev0, ITAAC Completion Package