



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

April 27, 2020

LICENSEE: Energy Harbor Nuclear Corp.  
FACILITY: Beaver Valley Power Station, Unit Nos. 1 and 2  
SUBJECT: SUMMARY OF MARCH 31, 2020, PUBLIC MEETING WITH ENERGY HARBOR NUCLEAR CORP. TO DISCUSS COVID-19 POTENTIAL SUBMITTALS OF REGULATORY ACTIONS

On March 31, 2020, the U.S. Nuclear Regulatory Commission (NRC) staff held a public teleconference with representatives from Energy Harbor Nuclear Corp. (the licensee). The purpose of the meeting was to discuss potential submittals of up to six regulatory actions resulting from the COVID-19 pandemic specifically focused on providing relief from specific requirements of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code and the Operations and Maintenance Code. The meeting notice and agenda, dated March 30, 2020, are available in the Agencywide Documents Access and Management System at Accession No. ML20090H762. A list of attendees is enclosed.

At the start of the meeting, the U.S. Nuclear Regulatory Commission (NRC) reinforced that the meeting was an information gathering dialogue only, and as always, for NRC public meetings, no regulatory decisions would be made. Additionally, the NRC stated that none of the information provided in the meeting was to be taken as a request by the licensee or a decision by the NRC staff. It was stated that actual licensing requests should still be submitted in the normal fashion and coordinated with the Beaver Valley Power Station, Unit Nos. 1 and 2, project manager.

Mr. Phillip Lashley of Energy Harbor Nuclear Corp. led the discussion with the NRC staff regarding identification of regulatory reliefs related to the COVID-19 pandemic. Items for discussion were the following:

Potential Relief Requests

- Hot leg nozzle inspection – request to extend the frequency of Code Case N-770-2, Table 1, Item A-2, that the weld surface must be visually examined each refueling outage (requested by April 12)
- Bottom mounted instrumentation – request to extend the examination frequency specified in Code Case N-722-1, Table 1, for Item B15.80, to examine all penetrations every other refuel outage (requested by April 12)
- Relief valve testing – request to extend the 10-year interval required by Mandatory Appendix I, 1-1350, and Mandatory Appendix I, 1-1390 (requested by April 8)

- Motor-operated valve testing – request to extend the testing frequency required by Code Case OMN-1, including the 6-month allowance allowed by OMN-20 (requested by April 6)
- Containment isolation valve water testing – request to extend the 2-year testing frequency specified in ISTC-3630(a) (requested by April 12)
- Safety-significant dynamic restraint (snubber) testing – request to extend the testing requirement specified in ISTD 5200 to inspect snubbers each fuel cycle (requested by April 4)

Members of the public were not in attendance; no public meeting feedback forms were received. Please direct any inquiries to me at 301-415-2328 or [Jennifer.Tobin@nrc.gov](mailto:Jennifer.Tobin@nrc.gov).

*/RA/*

Jennifer C. Tobin, Project Manager  
Plant Licensing Branch I  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-412

Enclosure:  
List of Attendees

LIST OF ATTENDEES

MARCH 31, 2020, PUBLIC MEETING WITH ENERGY HARBOR NUCLEAR CORP.

REGARDING BEAVER VALLEY POWER STATION, UNIT NOS. 1 AND 2

COVID-19 POTENTIAL REGULATORY ACTIONS

<b>Name</b>	<b>Organization</b>
Neil Sheehan	NRC
Scott Burnell	NRC
Ed Miller	NRC
James Danna	NRC
Jennifer Tobin	NRC
Tom Scarbrough	NRC
Matt Mitchell	NRC
Michael Farnan	NRC
John Tsao	NRC
Jason Huang	NRC
Jay Collins	NRC
Gurjendra Bedi	NRC
Dennis Galvin	NRC
Steven Sewell	Luminant Power
Eric Epstein	TMI Alert
William Freebairn	S&P Global Platts
Lawrence Winker	Pennsylvania Department of Environmental Protection
Marisa Garcia Heras	Tecnatom
Phil Lashley	Energy Harbor
Dave McCreary	Energy Harbor
Ken McMullen	Energy Harbor
Mark Manoleras	Energy Harbor
Dave Jones	Energy Harbor
Mike Testa	Energy Harbor
Andrew Crotty	Energy Harbor
Ben Spiesman	Energy Harbor
Brandon Padgett	Energy Harbor
Jeff Morgan	Energy Harbor
Gary Alberti	Energy Harbor
Kathy Nevins	Energy Harbor

SUBJECT: SUMMARY OF MARCH 31, 2020, PUBLIC MEETING WITH ENERGY HARBOR NUCLEAR CORP. TO DISCUSS COVID-19 POTENTIAL SUBMITTALS OF REGULATORY ACTIONS DATED APRIL 27, 2020

**DISTRIBUTION:**

PUBLIC	TScarbrough, NRR
PM File Copy	MMitchell, NRR
RidsACRS_MailCTR Resource	MFarnan, NRR
RidsNrrDorlLpl1 Resource	JTsao, NRR
RidsNrrLALRonewicz Resource	JHuang, NRR
RidsOpaMail Resource	JCollins, NRR
RidsNrrDorl Resource	GBedi, NRR
NSheehan, NRR	DGalvin, NRR
SBurnell, OPA	EMiller, NRR
MMcCoppin, OEDO	OLopez-Santiago, OEDO
LBetancourt, NRR	CdeMessiers, NRR

**ADAMS Accession No.: ML20111A014**

OFFICE	NRR/DORL/LPL1/PM	NRR/DORL/LPL1/LA	NRR/DORL/LPL1/BC	NRR/DORL/LPL1/PM
NAME	JTobin	LRonewicz	JDanna	JTobin
DATE	04/22/2020	04/21/2020	4/27/2020	04/27/2020

**OFFICIAL RECORD COPY**