



GPU Nuclear Corporation
Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

May 7, 1996
6730-96-2144

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station
Operating License No. DPR-16
Docket No. 50-219
Technical Specification Change Request No. 247

In accordance with 10 CFR 50.4(b)(1), enclosed is Technical Specification Change Request (TSCR) No. 247. Also enclosed is a Certificate of Service for this request certifying service to the chief executive of the township in which the facility is located, as well as the designated official of the State of New Jersey, Bureau of Nuclear Engineering.

The proposed change to the technical specifications would adopt the provisions of the Standard Technical Specifications (STS) NUREG 1433, Revision 1, dated April 7, 1995, which clarify surveillance requirement applicability and allow a maximum period of 24 hours to complete a surveillance requirement upon discovery that the surveillance has been missed. The basis for the delay period includes, among other considerations, the safety significance of the delay in completing the required surveillance and the recognition that the most probable result of any particular surveillance being performed is the successful verification of conformance with the requirements.

130048


9605130321 960507
PDR ADOCK 05000219
P PDR

Acc
11

Technical Specification Change Request 247
6730-96-2144
Page 2

Pursuant to 10 CFR 50.91(a)(1), enclosed is an analysis applying the standards in 10 CFR 50.92 to make a determination of no significant hazards consideration. If any additional information is needed, please contact Mr. David J. Distel, Senior Regulatory Affairs Engineer, at 201-316-7955.

Very truly yours,



Michael B. Roche
Vice President & Director
Oyster Creek

MBR:DJD/gl

Enclosure

cc: Administrator, NRC Region I
NRC Project Manager
NRC Resident Inspector