

Docket No. 50-346

License No. NPF-3

Serial No. 1131

March 8, 1985



RICHARD P. CROUSE  
Vice President  
Nuclear  
(419) 259-5221

Director of Nuclear Reactor Regulation  
Attn.: Mr. John F. Stolz  
Operating Reactor Branch No. 4  
Division of Licensing  
United States Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Stolz:

This is in response to the Supplemental Safety Evaluation Report of January 31, 1985 (Log No. 1683), regarding the Automatic Shunt Trip Design; Generic Letter 83-28, Item 4.3.

Toledo Edison implemented the reactor trip breaker shunt trip modification during the 1984 refueling outage, as committed to in our letter dated June 22, 1984 (Serial No. 1054). Additionally, the seismic qualification of the shunt trip attachment has been completed satisfactorily.

Regarding your request that Toledo Edison submit proposed technical specifications consistent with the test procedure outline submitted in Toledo Edison letter dated June 22, 1984, a telephone conversation was conducted with Mr. A. DeAgazio (NRC Project Manager) on February 14, 1985, requesting additional time to review the request for submitting technical specifications. Toledo Edison will provide a response to this request by April 30, 1985.

Very truly yours,

RPC:LCS:SGW:nlf  
cc: DB-1 NRC Resident Inspector

8503120512 850308  
PDR ADOCK 05000346  
PDR

*Aoss*  
*1/0*