



300 Madison Avenue
Toledo, OH 43652-0001
419-249-2300

John P. Stetz
Vice President - Nuclear
Davis-Besse

Docket Number 50-346

License Number NPF-3

Serial Number 2376

May 8, 1996

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: Technical Specification 4.4.5.5a Report of Steam Generator Tube
Plugging

Ladies and Gentlemen:

This letter is submitted in accordance with the requirements of the Davis-Besse Nuclear Power Station (DBNPS) Unit Number 1, Operating License, Appendix A, Technical Specifications. Technical Specification 4.4.5.5a requires Toledo Edison to report to the Nuclear Regulatory Commission (NRC) the number of tubes plugged in each steam generator (SG) following each inservice inspection of steam generator tubes.

The Tenth Refueling Outage SG tube inservice inspection was completed on April 26, 1996. As a result of the inspection findings, 1 tube (10-64) was plugged in SG 1-1 and 5 tubes (78-52, 3-34, 29-104, 58-119, and 110-80) were plugged in SG 1-2.

Toledo Edison will provide the complete results of the steam generator tube inservice inspection in accordance with Technical Specifications 4.4.5.5b and 6.9.1.5b by March 31, 1997. This report will include: 1) the number and extent of tubes inspected, 2) the location and percent of wall-thickness penetration for each indication of an imperfection, and 3) the identification of tubes plugged or sleeved.

Should you have any questions, please contact Mr. J. L. Freels, Manager - Regulatory Affairs at (419) 321-8466.

Very truly yours,

Dy - for JP Stetz
FWK/laj

cc: L. L. Gundrum, DB-1 NRC/NRR Project Manager
H. J. Miller, Regional Administrator, NRC Region III
S. Stasek, DB-1 NRC Senior Resident Inspector
Utility Radiological Safety Board

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

9605140077 960508
PDR ADOCK 05000346
P PDR

*A001
1/0*