



Duquesne Light

Nuclear Construction Division
Robinson Plaza, Building 2, Suite 210
Pittsburgh, PA 15205

2NRC-5-039
(412) 787-5141
(412) 923-1960
Telecopy (412) 787-2629
March 7, 1985

United States Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Mr. George W. Knighton, Chief
Licensing Branch 3
Office of Nuclear Reactor Regulation

SUBJECT: Beaver Valley Power Station - Unit No. 2
Docket No. 50-412
S.E.R. Outstanding Issues Status


Gentlemen:

Attached is a current list, as of February 25, 1985, which provides our understanding of the outstanding issues which remain open. Items identified as "complete" are those for which responses have been provided and no confirmation of status has yet been received from the staff. We consider these items satisfactorily closed unless notified otherwise. In order to permit timely resolution of items identified as "complete" which may not be resolved to the staff's satisfaction, please provide a specific description of the issue which remains to be resolved. Items identified as "confirmatory" are based upon formal or informal communications or agreements with the staff. Please inform us of any disagreement of status described on the attached list.

As indicated by the attached list, the number of outstanding issues remaining open is less than 20. Please provide a schedule for issuing the Safety Evaluation Report.

DUQUESNE LIGHT COMPANY

By


E. J. Woolever
Vice President

GHO/wjs
Attachment

cc: Mr. H. R. Denton, Director NRR (w/attachment)
Mr. H. Thompson, Director Division of Licensing (w/attachment)
Mr. B. K. Singh, Project Manager (w/attachment)
Mr. T. Novak, Assistant Director Division of Licensing (w/attachment)
Mr. G. Walton, NRC Resident Inspector (w/attachment)

8503180509 850307
PDR ADDCK 05000412
E PDR

8001
11

BVPS-2 Outstanding Issues Status

<u>DIV.</u>	<u>BRANCH</u>	<u>REVIEWER</u>	<u>ISSUE</u>	<u>NOTE</u>	<u>APPLICANT RESPONSE DATE</u>	<u>REMARKS</u>
DSI	RSB	E. Lantz	° Qualification of RHR pumps	Closed	02/08/85	
			° Natural Circulation Test	A		
	ICSB	F. Burrows	° Steam Generator Level Control and Protection	B	05/30/84	
	ASB	R. Anand	° Internally Generated Missiles - Outside containment	Closed	01/08/85	
			° Internally Generated Missiles - Inside containment	Closed	01/08/85	
			° Protection against postulated pipe breaks outside containment	Confirmatory	01/08/85	
			° Fuel Pool Cooling and Cleanup system	Closed	01/08/85	
			° Overhead heavy load handling system	NRC	02/13/85	
			° Standby service water system	Closed	01/08/85	
			° Primary Component Cooling Water system	A	04/30/85	
			° Condensate and Feedwater System	Closed	01/08/85	
			° Auxiliary Feedwater System	NRC	01/08/85	
	PSB	J. Knox	° Electrical - 17 open items	A		
		R. Giardina	° Mechanical - 46 open items	A		
	CPB	A. Gill	° Loose part detection	A	02/28/85	
			° Inadequate core cooling instrumentation	A	03/31/85	
		M. Dunefeld	° Analysis of combined LOCA and seismic loads	A		
			° On-line detection method	Closed	09/07/84	
	METB	E. Markee	° x/q	B	02/15/85	
			° Snow & Ice Load	B	01/16/85	
	AFB	K. Dempsey	° Radiation consequences of LOCA	B	11/08/84	
			° Rod ejection accidents	B	11/08/84	
	MEB	Y. Li	° Primary vs. secondary loads	Complete	02/20/85	
			° In service testing	A	06/85	

DIV.	BRANCH	REVIEWER	ISSUE	NOTE	APPLICANT RESPONSE DATE	REMARKS
DE	MEB	O. Rothberg	° Asymmetric LOCA loads	NRC		
			° PIV leak testing	NRC		
	SGEB	K. Leu	° Seismic Input	Closed	02/01/85	
			° Seismic system analysis	Closed	02/01/85	
			° Concrete containment	Closed	12/21/84	
			° Concrete and Structural steel internal structures	Closed	12/21/84	
			° Other Category I structures	Closed	12/17/84	
			° Foundations	Closed	12/17/84	
			° Soil Structure Interaction (SSI) Analysis	NRC	02/01/85	
	GSB	G. Giese-Koch	° Seismology	A	02/15/85	
	EQB	H. Walker	° Environmental Qualification	Confirmatory	08/05/84	
		J. Lombardo	° Pump & Valve	Confirmatory	08/05/84	
		A. Lee	° Seismic Qualification	Confirmatory	08/05/84	
	MTEB	M. Hum	° Preservice Inspection Program	A	06/85	
			° Inservice inspection of Class 2 & 3 components	A	06/85	
		D. Smith	° Underclad cracking of forgings in R.V.	Closed	08/10/84	
	CHEB	J. Stang	° Safe shutdown	A	09/85	
			° Alternate shutdown	A	09/85	
			° Fire in Cable spreading room	B	05/30/84	
	EHFB	R. Gonzales	° Potential for flooding from local precipitation	B	05/30/84	
			° Flooding from Peggs Run	B	05/30/84	
DHFS	HFEB	R. Eckenrode	° Safety parameter display system and control room design review	A	03/01/85	
	LQB	F. Allenspack	° Management & Organization	A		

<u>DIV.</u>	<u>BRANCH</u>	<u>REVIEWER</u>	<u>ISSUE</u>	<u>NOTE</u>	<u>APPLICANT RESPONSE DATE</u>	<u>REMARKS</u>
DHFS	PSRB	R. Becker	° Initial test program	A		
		S. Bryan	° Emergency operating procedure	Closed		
INE	EPB	J. Simmonds	° Emergency Preparedness Plan	A	03/15/85	
Reg.1			° Cross-Training program	A	03/01/85	

NOTE: These open issues include backfit items

A - Applicant to provide information
B - Backfit