

Attachment III to JPN-96-023

MARKED-UP TECHNICAL SPECIFICATION PAGES

PORC REVIEW OF FIRE PROTECTION PROGRAM

(JPTS-95-005)

New York Power Authority

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

Docket No. 50-333

DPR-59

9605230052 960516
PDR ADOCK 05000333
P PDR

JAFNPP

6.5.1.3 Alternates

Alternative members shall be appointed in writing by the PORC Chairman to serve on a temporary basis.

6.5.1.4 Meeting Frequency

Meetings will be called by the Chairman as the occasions for review or investigation arise. Meetings will be no less frequent than once a month.

6.5.1.5 Quorum

A quorum of the PORC shall consist of the Chairman or a Vice-Chairman and five members including designated alternates. Vice-Chairmen may act as members when not acting as Chairman. A quorum shall contain no more than two alternates.

6.5.1.6 Responsibilities

The PORC shall be responsible for the:

- a. Review of 10 CFR 50.59 safety and environmental impact evaluations associated with procedures and programs required by Specification 6.8, and changes thereto.
- b. Review of proposed tests and experiments that affect nuclear safety.
- c. Review of proposed changes to the Operating License and Technical Specifications.
- d. Review of proposed changes or modifications to plant systems or equipment that affect nuclear safety.
- e. Investigation of violations of the Technical Specifications. The PORC shall prepare and present a report covering the evaluations and recommendations to prevent recurrence to the Site Executive Officer, who will then forward the report to the Chief Nuclear Officer, the Vice President Regulatory Affairs and Special Projects, and to the Chairman of the Safety Review Committee.
- f. Review of plant operations to detect potential safety hazards.
- g. Performance of special reviews and/or investigations at the request of the Site Executive Officer.
- h. Review of all reportable events.
- i. Review of the Process Control Program and the Offsite Dose Calculation Manual (ODCM) and changes thereto.
- j. Review the FitzPatrick Fire Protection Program and implementing procedures and changes thereto.

6.12 INDUSTRIAL SECURITY PROGRAM

An industrial security program shall be maintained throughout the life of the plant in accordance with the provisions of the Plant Security Plan.

6.13 EMERGENCY PLAN

THIS SECTION PURPOSELY BLANK

6.14 FIRE PROTECTION PROGRAM

- A. An independent fire protection and loss prevention inspection and audit shall be performed annually utilizing either qualified licensee personnel or an outside fire protection firm.
- B. An inspection and audit by an outside qualified fire consultant shall be performed at intervals no greater than 3 years.

THIS SECTION PURPOSELY BLANK