

Duke Power Company
Catawba Nuclear Station
4800 Concord Road
York, SC 29745

(803)831-3000



DUKE POWER

March 21, 1996

RE: Catawba Nuclear Station
Selected License Commitment
Section 16.9 Auxiliary Systems - Fire Protection Systems

Please replace the following pages in the Selected License Commitment manual due to word change.

Remove

Section 16.9-4 - Page 1
Section 16.9-6 - Page 1

Insert

Section 16.9-4 - Page 1
Section 16.9-4 - Page 1

If you have any questions concerning contents of this package update, contact the undersigned at (803) 831-3640.

M.S. Kitlan, Manager

Barbara S. Asbury
By: Barbara S. Asbury
Regulatory Compliance

Attachments

040103

9606050099 960130
PDR ADOCK 05000413
F PDR

Acob
11

COMMITMENT:

The fire hose stations given in Table 16.9-2 shall be OPERABLE:

APPLICABILITY:

Whenever equipment the areas protected by the fire hose stations id required to be OPERABLE.

REMEDIAL ACTION:

With one or more of the fire hose stations given in Table 16.9-2 inoperable, provide gated wye(s) on the nearest OPERABLE hose stations(s). One outlet of the wye shall be connected to the standard length of hose provided for the hose stations. The second outlet of the wye shall be connected to a length of hose sufficient to provide coverage for the area left unprotected by the physical routing the fire hose would result in a recognizable hazard to station personnel, plant equipment, or the hose itself, the for hose shall be stored in a roll at the outlet of the OPERABLE hose station. Signs shall be mounted above the gated wye(s) to identify the proper hose to use. The above REMEDIAL ACTION requirement shall be accomplished within 1 hour if the inoperable fire hose is the primary means of fire suppression; otherwise route the additional hose within 24 hours.

TESTING REQUIREMENTS:

- a. Each of the fire hose stations given in Table 16.9-2 shall be demonstrated OPERABLE:
 - i. By a visual inspection of the fire hose stations, accessible during plant operations, to assure all required equipment is at the station and the fire hose shows no physical damage. The frequency of the inspection shall be determined by the performance based criteria stated in the Bases Section.

COMMITMENT:

As a minimum, the fire detection instrumentation for each fire detection zone shown in Table 16.9-3 shall be OPERABLE.

APPLICABILITY:

Whenever equipment protected by the fire detection instrument is required to be OPERABLE.

REMEDIAL ACTION:

- a. With any, but not more than one-half the total in any fire zone, Function A fire detection instruments shown in Table 16.9-3 inoperable, restore the inoperable instrument(s) to OPERABLE status within 14 days or within 1 hour establish a fire watch patrol to inspect the zone(s) with the inoperable instrument(s) at least once per hour, unless the instrument(s) is located inside the containment, then inspect that containment zone at least once per 8 hours or monitor the containment air temperature at least once per hour at the locations listed in Technical Specification Surveillance 4.6.1.5.1
- b. With more than one-half of the Function A fire detection instruments in any fire zone shown in Table 16.9-3 inoperable, or with any Function B fire detection instruments shown in Table 16.9-3 inoperable, or with any two or more adjacent fire detection instruments shown in Table 16.9-3 inoperable, within 1 hour establish a fire watch patrol to inspect the zone(s) with the inoperable instrument(s) at least once per hour, unless the instrument(s) is located inside the containment, then inspect that containment zone at least once per 8 hours or monitor the containment air temperature at least once per hour at the locations listed in Technical Specification Surveillance 4.6.1.5.1.

TESTING REQUIREMENTS

- a. Each of the above required flame detection instruments shall be demonstrated operable at least once per 6 months by the performance of a VISUAL INSPECTION and at least once per year by performance of a TRIP ACTUATING DEVICE OPERATIONAL TEST.