

Commonwealth Edison Company
Quad Cities Generating Station
22710 200th Avenue North
Cordova, IL 61242-9740
Tel 809-654-2241



LWP-96-041

Date: May 29, 1996

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Reference: Quad Cities Nuclear Station
Docket Number 50-265, DPR-30, Unit Two
*(50-254, DPR-29, Unit One)

Subject: Licensee Event Report (LER) 254/91-003 Supplemental
Information.

As stated in LER 254/91-003 Supplement 1, supplemental information is being provided. This information constitutes revision 02 to the original LER documentation.

Attachment 1 is a reproduction of the supplement 1 text of LER 254/91-003.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(ii)(B), "Any event or condition that resulted in the condition of the nuclear power plant, including its principal safety barriers, being seriously degraded or that resulted in the nuclear plant being in a condition that was outside the design basis of the plant."

Containment Atmosphere Monitoring piping and Mark I support installation work will be completed prior to startup from the current Unit 2 forced outage Q2F41.

Work required to resolve the Atmosphere Containment Atmosphere Dilution piping support issues will be completed prior to startup from the current Refuel Outage Q1R14 (for Unit 1) and prior to startup from forced outage Q2F41 (for Unit 2).

050027

9606050199 960529
PDR ADOCK 05000254
S PDR

STMGR/96041.LWP

A. J. Macdonald Company

IF22
11

If there are any questions or comments concerning this letter, please refer them to Nick Chrissotimos, Regulatory Assurance Administrator at 309-654-2241, ext. 3100.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR STATION

D.B. Cook for

L.W. Pearce
Station Manager

Attachment 1- LER 254/91-003 Supplement 1 (Copy)

cc: P. Piet
C. Miller
INPO Records Center
NRC Region III