

CALVERT CLIFFS - UNIT 1

3/4 6-23

Amendment No. 4/8, 8/8, 9/7

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

PENETRATION NO.	ISOLATION CHANNEL	ISOLATION VALVE IDENTIFICATION NO.	FUNCTION	ISOLATION TIME (SECONDS)
44	NA NA NA	238-1 238-1 MOV-6200 *	Fire Protection	NA NA NA
47A	NA NA	SV-6540A * SV-6507A *	Hydrogen Sample Outlet	NA NA
47b	NA NA	SV-6540E * SV-6507E *	Hydrogen Sample Outlet	NA NA
47C	NA NA	SV-6540F * SV-6507F *	Hydrogen Sample Outlet	NA NA
47D	NA NA	SV-6540G * SV-6507G *	Hydrogen Sample Return	NA NA
48A	SIAS-B SIAS-A	MOV-6900 MOV-6901	Containment Vent Isolation	≤ 20** ≤ 15 ≤ 20** ≤ 15

8503270146 850321
PDR ADOCK 05000317
PDR

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

<u>PENETRATION NO.</u>	<u>ISOLATION CHANNEL</u>	<u>ISOLATION VALVE IDENTIFICATION NO.</u>	<u>FUNCTION</u>	<u>ISOLATION TIME (SECONDS)</u>
44	NA	238-1	Fire Protection	NA
	NA	238-1		NA
	NA	MOV-6200 *		NA
47A	NA	SV-6540A *	Hydrogen Sample Outlet	NA
	NA	SV-6507A *		NA
47B	NA	SV-6540E *	Hydrogen Sample Outlet	NA
	NA	SV-6507E *		NA
47C	NA	SV-6540F *	Hydrogen Sample Outlet	NA
	NA	SV-6507F *		NA
47D	NA	SV-6540G *	Hydrogen Sample Return	NA
	NA	SV-6507G *		NA
48A	SIAS A SIAS B	MOV-6900 MOV-6901	Containment Vent Isolation	20 ≤ 15 20 ≤ 15