



P.O. Box 300
Seabrook, NH 03874
Telephone (603) 474-9521
Facsimile (603) 474-2987

Ted C. Feigenbaum
Senior Vice President and
Chief Nuclear Officer

NYN-92139

October 9, 1992

United States Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Document Control Desk

Reference: Facility Operating License No. NPF-86, Docket No. 50-443

Subject: Steam Generator Tube Plugging Report for the Second Inservice Inspection

Gentlemen:

Pursuant to Seabrook Station Technical Specification 4.4.5.5.a, North Atlantic has specified herein the number of tubes plugged in each steam generator during the second Inservice Inspection.

A total of 4813 tubes were inspected in two of the four steam generators (S/G A: 2412 D: 2401). No defective tubes, that is a tube with a wall loss equal to or greater than 40%, were identified and therefore no tubes were plugged.

One Alloy 660 plug was removed from the hot leg side of Steam Generator A and replaced with an Alloy 690 plug. This plug replacement was performed in response to NRC Bulletin No. 89-01, "Failure of Westinghouse Steam Generator Tube Mechanical Plugs."

Per the requirements of Technical Specification 4.4.5.5.b, the complete results of the Steam Generator Tube Inservice Inspection will be submitted prior to October 1, 1993.

Should you have any questions regarding this matter, please contact Mr. James M. Peschel, Regulatory Compliance Manager, at (603) 474-9521 extension 3772.

Very truly yours,

A handwritten signature in dark ink, appearing to read "Ted C. Feigenbaum", is written over a large, stylized circular flourish.

Ted C. Feigenbaum

TCF:ALL/act

160033

9210160230 921009
PDR ADOCK 25000443
G PDR

Member of the Northeast Utilities system

IE31 10

United States Nuclear Regulatory Commission
Attention: Document Control Desk

October 9, 1992
Page two

cc: Mr. Thomas T. Martin
Regional Administrator
U. S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19466

Mr. Gordon E. Edison, Sr. Project Manager
Project Directorate 1-3
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Noel Dudley
NRC Senior Resident Inspector
P.O. Box 1149
Seabrook, NH 03874