

Memorandum



July 10, 1996
JAFF-96-0275

U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555

Attention: Document Control Desk

SUBJECT: OPERATING STATUS REPORT

Reference: DCCKET NO. 50-333

Dear Sir:

Enclosed please find the James A. FitzPatrick Nuclear Power Plant Operating Status Report for the month of **June 1996**.


If there are any questions concerning this report, please contact Russ Flagg, Performance Engineering, at (315) 349-6768.

Very truly yours,



MICHAEL J. COLOMB
PLANT MANAGER

ad MJC:RGF:mac
Enclosure

CC: F. Edler 
JAF Department Heads
White Plains Office
JTS File
RMS, JAF

9607170007 960630
PDR ADOCK 05000333
R PDR

170006

1/1
1124

**NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATING DATA REPORT**

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: July 9, 1996
COMPLETED BY: RUSSELL FLAGG
TELEPHONE: (315)349-6768

OPERATING STATUS

1. Unit Name: FITZPATRICK
2. Reporting Period: 960601 - 960630
3. Licensed Thermal Power (MWT): 2436
4. Nameplate Rating (Gross MWE): 883.0
5. Design Electrical Rating (Net MWE): 816.0
6. Maximum Dependable Capacity (Gross MWE) 789.0
7. Maximum Dependable Capacity (Net MWE) 761.6

NOTES:

8. If changes occur in capacity ratings (Items 3-7) since last report, give reasons: _____
9. Power level to which restricted, if any (Net MWE): _____
10. Reasons for restrictions, if any: _____

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. Hours in Reporting Period:	720.0	4367.0	183456.0
12. Number of Hours Reactor was Critical:	720.0	4114.1	129923.7
13. Reactor Reserve Shutdown Hours:	0	0	0
14. Hours Generator On-Line:	720.0	4034.3	125633.3
15. Unit Reserve Shutdown Hours:	0	0	0
16. Gross Thermal Energy Generated (MWH):	1722168.0	9627740.0	278795412.0
17. Gross Electrical Energy Generated (MWH):	575350.0	3240540.0	94624800.0
18. Net Electrical Energy Generated (MWH):	559025.0	3136235.0	90952830.0
19. Unit Service Factor:	100.0	92.4	68.5
20. Unit Availability Factor:	100.0	92.4	68.5
21. Unit Capacity Factor (using MDC Net):	101.95	94.3	70.4
22. Unit Capacity Factor (using DER Net):	95.15	88.0	60.8
23. Unit Forced Outage Rate:	0.00	7.6	10.8

24. Shutdowns scheduled over next 6 months (type, date, and duration of each):
Refueling outage 10/26/96 - 45 days

25. If shutdown at end of report period, estimated date of startup: _____

26. Units in Test Status (prior to commercial operation):
- | | FORECAST | ACHIEVED |
|----------------------|----------|----------|
| Initial Criticality | _____ | _____ |
| Initial Electricity | _____ | _____ |
| Commercial Operation | _____ | _____ |

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
AVERAGE DAILY UNIT POWER LEVEL

REPORT MONTH: June 1996

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: July 9, 1996
COMPLETED BY: RUSSELL FLAGG
TELEPHONE: (315)349-6768

DAY	NET AVERAGE DAILY POWER LEVEL	DAY	NET AVERAGE DAILY POWER LEVEL
1	796	17	786
2	796	18	783
3	793	19	790
4	793	20	795
5	790	21	791
6	789	22	791
7	789	23	791
8	578	24	791
9	702	25	791
10	776	26	791
11	795	27	789
12	792	28	685
13	793	29	788
14	790	30	783
15	788		
16	789		

**NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
UNIT SHUTDOWNS REPORT**

REPORT MONTH: June 1996

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: July 9, 1996
COMPLETED BY: RUSSELL FLAGG
TELEPHONE: (315)349-6768

NO.	DATE	TYPE	D U H R O A U T R I S T I O N	R E A S O N	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT	S Y C S O T D E E M	C O M C P O D N E N T	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE

F: FORCED
S: SCHEDULED

2
REASON:
A. EQUIPMENT FAILURE (EXPLAIN)
B. MAINTENANCE OR TEST
C. REFUELING
D. REGULATORY RESTRICTION
E. OPERATOR TRAINING AND LICENSE EXAMINATION
F. ADMINISTRATIVE
G. OPERATIONAL ERROR (EXPLAIN)
H. OTHER (EXPLAIN)

3
METHOD:
1. MANUAL
2. MANUAL SCRAM
3. AUTOMATIC SCRAM
4. CONTINUED
5. REDUCED LOAD
9. OTHER

4
EXHIBIT G -INSTRUCTIONS
FOR PREPARATION OF DATA ENTRY
SHEETS FOR LICENSEE EVENT
REPORT (LER) FILE (NUREG-0161)

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
NARRATIVE SUMMARY OF OPERATING EXPERIENCE

REPORT MONTH: June 1996

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: July 9, 1996
COMPLETED BY: R. FLAGG
TELEPHONE: (315) 349-6768

The FitzPatrick plan remained in operation at approximately 100% power throughout the reporting period with the following exception:

A downpower to approximately 56% power was performed on 6/8/96 to perform condenser waterbox defishing, scram time testing and rod pattern adjustments.