



## Nebraska Public Power District

GENERAL OFFICE  
P.O. BOX 499, COLUMBUS, NEBRASKA 68602-0499  
TELEPHONE (402) 564-8561  
FAX (402) 563-5551

NSD921020  
October 15, 1992

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Subject: Revision to Proposed Change No. 100 to Technical Specifications  
Elimination of Main Steam Line Radiation Monitor  
Scram and Isolation Functions  
Cooper Nuclear Station  
NRC Docket No. 50-298, DPR-46

Reference: Letter from G. R. Horn (NPPD) to NRC dated May 4, 1992, "Elimination  
of Main Steam Line Radiation Monitor Scram and Isolation Functions,  
Cooper Nuclear Station, NRC Docket No. 50-298, DPR-46"

The Nebraska Public Power District (District) requests that Proposed Change No. 100, submitted May 4, 1992 (Reference), be revised to accurately reference the relocation of the Mechanical Vacuum Pump Isolation surveillance requirements requested in that proposed change. Proposed Change No. 100 requested the NRC to revise the Cooper Nuclear Station (CNS) Technical Specifications to eliminate the operability requirements, action statements, and associated surveillance requirements for the Main Steam Line Radiation Monitor (MSLRM) scram and Group 1 Containment Isolation functions.

Currently, Section 4.2.D.5 on page 48 of the CNS Technical Specifications references Tables 4.1.1, 4.1.2, and 4.2.D as the location for the Mechanical Vacuum Pump Isolation surveillance requirements. Proposed Change No. 100, if approved, would relocate these surveillance requirements to Tables 4.2.A and 4.2.D of the CNS Technical Specifications. However, in Proposed Change No. 100, the District inadvertently omitted the revision to Section 4.2.D.5 which would correctly reference the proposed relocation of these surveillance requirements, i.e., deleting reference to Tables 4.1.1 and 4.1.2, and adding reference to Table 4.2.A. The attached proposed revision to page 48 of the CNS Technical Specifications, if included with Proposed Change No. 100, would correct this deficiency. Therefore, the District requests that the attached revision be incorporated in Proposed Change No. 100.

9210230015 921015  
PDR ADOCK 05000298  
P PDR


*Adol*

U. S. Nuclear Regulatory Commission  
Page 2 of 2  
October 15, 1992

Since this revision to Proposed Change No. 100 is editorial in nature, this revision does not impact the District's Significant Hazards evaluation contained in the reference.

Please contact me if you have any questions or require any additional information.

Sincerely,



G. R. Horn  
Nuclear Power Group Manager

GRH/MJB

Attachment

cc: H.R. Borchert  
Department of Health  
State of Nebraska

NRC Regional Administrator  
Region IV  
Arlington, TX

NRC Resident Inspector  
Cooper Nuclear Station