

Public Service  
Electric and Gas  
Company

Steven E. Miltenberger

Public Service Electric and Gas Company P.O. Box 236, Hancocks Bridge, NJ 08038 609-339-4199

Vice President and Chief Nuclear Officer

OCT 28 1992

NLR-N92144

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

COMPLETION OF REQUIRED ACTIONS UNDER IE BULLETIN 88-10  
MOLDED CASE CIRCUIT BREAKERS  
SALEM AND HOPE CREEK GENERATING STATIONS  
DOCKET NOS. 50-272, 50-311, AND 50-354

On November 7, 1989, Public Service Electric and Gas Company (PSE&G) forwarded its response (NLR-N89225) to IE Bulletin 88-10, Supplement 1. That response provided a commitment to; 1) establish traceability for molded case circuit breakers (MCCB) purchased between August 1, 1983 and August 1, 1988 and installed in safety-related applications, and 2) replace MCCB's identified under Item 1 which were determined to be non-traceable. PSE&G committed to complete review/replacement of non-traceable MCCB's prior to restart from the tenth, sixth and fourth refueling outages for Salem Units 1 and 2, and Hope Creek, respectively. The status of these activities is summarized in the following paragraphs.

All committed activities relating to IE Bulletin 88-10 for Salem Unit 1 were accomplished in accordance with the committed schedule. Completion of Unit 2 activities was delayed somewhat due to availability of replacement breakers. This delay was discussed with the NRC Licensing Project Manager for Salem, Mr. J. Stone, and determined to be acceptable. All committed activities relating to IE Bulletin 88-10 for Salem Unit 2 are complete at this time.

PSE&G had committed to complete all review/replacement activities for Hope Creek prior to restart from the fourth refueling outage which is presently underway. The traceability review of MCCB's purchased during the identified period was successful in all cases and therefore no replacements were required at Hope Creek. As such, all committed activity relating to IE Bulletin 88-10 is complete for Hope Creek also.

9211040183 921028  
PDR ADDCK 05000272  
P PDR


JE21 1/0

OCT 28 1992

Completion of these activities fulfills the requirements of IE Bulletin 88-10 and its Supplement for Salem and Hope Creek Generating Stations.

If there are any questions regarding this information, please feel free to contact us.

Sincerely,



C Mr. T. T. Martin, Administrator - Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. J. C. Stone, Licensing Project Manager  
U. S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852

Ms. A. Keller  
U.S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852

Mr. T. P. Johnson (S09)  
USNRC Senior Resident Inspector

Mr. K. Tosch, Chief  
NJ Department of Environmental Protection  
Division of Environmental Quality  
Bureau of Nuclear Engineering  
CN 415  
Trenton, NJ 08625