



BOSTON EDISON

Pilgrim Nuclear Power Station
Rocky Hill Road
Plymouth, Massachusetts 02360

Roy A. Anderson

Senior Vice President - Nuclear

October 26, 1992
BEC0 92-124


U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

License DPR-35
Docket 50-293

Technical Specification Bases Change on
Emergency Diesel Fuel Tank Level Instrumentation

During an Electrical Distribution System Functional Inspection of Pilgrim Station (EDSFI, Report #91-80), the Technical Specification Bases reference to the low level alarm setting on the Emergency Diesel Generator fuel tanks was found to be incorrect. The corrected Bases Section 3.9 (page 198) of the Pilgrim Nuclear Power Station Technical Specifications is attached.

In accordance with 10CFR50.36(a), the Bases are not a legal part of the Technical Specifications. Therefore, Bases changes do not constitute an amendment to the operating license and prior NRC approval is not required. Please incorporate this Bases change into your copy of the Pilgrim Nuclear Power Station Technical Specifications.


R. A. Anderson

GGW/clc/basesedg

Attachment: Technical Specification Bases Page 198

cc: See Page 2

200097

9211050300 921026
PDR ADOCK 0500C293
P PDR

*Foot
11*

BOSTON EDISON COMPANY

U. S. Nuclear Regulatory Commission

Page 2

cc: Mr. R. Eaton, Project Manager
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation
Mail Stop: 14D1
U. S. Nuclear Regulatory Commission
1 White Flint North
11555 Rockville Pike
Rockville, MD 20852

U. S. Nuclear Regulatory Commission
Region 1
475 Allendale Road
King of Prussia PA 19406

Senior NRC Resident Inspector
Pilgrim Nuclear Power Station